

## Appendix A

### Sample Summary Table

Building	Location	Area Description	Analyte	Pre-Clean Results	Post-Clean Results	Units	Clean Area Limit*
103	1st floor, column B33	Freight elevator threshold	Lead	19	13	µg/ft <sup>2</sup>	10
104	2nd floor, column B17	Freight elevator floor	Lead	46	120	µg/ft <sup>2</sup>	10
104	2nd floor, column F50	Top of cabinet in break room	Lead	740	270	µg/ft <sup>2</sup>	10
104F	1st floor, north lobby	Base of stairs	Lead	12	1.6	µg/ft <sup>2</sup>	10
105	1st floor, column C52	Loading dock floor	Lead	15	2500	µg/ft <sup>2</sup>	10
105	1st floor, column B16	Freight elevator floor	Lead	51	19	µg/ft <sup>2</sup>	10
105L	West back stage access	Floor	Lead	16	13	µg/ft <sup>2</sup>	10
105L	Sound room	Bottom shelf	Lead	64	15	µg/ft <sup>2</sup>	10
110	South warehouse	Floor at base of northeast stairs	Lead	770	320	µg/ft <sup>2</sup>	10
115	South end of main area	High windowsill	Lead	110	12	µg/ft <sup>2</sup>	10

\* Clean Area Limit per Brookhaven IH75190=OSHA Housekeeping Limit [PEL (µg/m<sup>3</sup>) x 10 m<sup>3</sup>/100cm<sup>2</sup>] / 15. Lead clean area limit: Brookhaven references EPA/HUD limit for floors, set at 10 µg/sq. ft. as of January 2020.

Indicates results at or above the Clean Area Limit