SUBMETERS AND ANALYTICS: SINGLE-CIRCUIT METER

OPPORTUNITY

Why is GSA interested in submetering and analytics?


- TENANT OR EQUIPMENT-LEVEL BILLING
- FAULT DETECTION & DIAGNOSTICS (FDD)
- IDENTIFY ENERGY CONSERVATION MEASURES (ECMS)

TECHNOLOGY

What are single-circuit meters?

MONITOR SINGLE OR 3-PHASE CIRCUITS INCLUDING PANEL MAINS

Combines a meter, a wireless communication gateway that collects data from multiple meters, non-proprietary current transformers and cloud-based analytics









M&V

Where did Measurement and Verification occur?

NATIONAL RENEWABLE ENERGY LABORATORY (NREL) assessed single-circuit meters at the Cesar Chavez Memorial Building in Denver, Colorado. Technology was provided by Meazon.

RESULTS

How did singlecircuit meters perform in M&V?

<2% ERROR COMPARED TO REFERENCE

Captured load profile trends accurately, even for highvariability loads¹

DAY INSTALLATION

for 6 measured loads; \$470 equipment and \$431 installation per load; equipment bulk purchase estimate \$132/load.²


FDD/ECM


Provides basic faultdetection and energy conservation measures for facilities without a BAS; can also be integrated into GSA's smart building platform, GSALink.³

Accurately Tracks Energy Consumption

 $<\!2\%$ measurement error, except when chillers were online but idling⁴

- _ Meazon
- Reference





DEPLOYMENT

Where does the study recommend deploying single-circuit meters?

TENANT BILLING

Most value for monitoring devices with high power consumption.

Low-cost submetering can also provide FDD for facilities without GSALink and support ECM identification and M&V.

¹Case Study: Field Evaluation of a Low Cost Circuit-Level Electrical Submetering System, Willy Bernal Heredia, Dylan Cutler, Jesse Dean (NREL), January 2021, p.23 ²Ibid, p.25 ³Ibid, p.29 ⁴The decrease in measurement accuracy for low-power loads is consistent with previous CEBT submetering evaluations. New meter design & high accuracy CTs may mitigate measurement errors for low-power loads.

