



September 8, 2021

Diane Czarnecki
Industrial Hygienist
Facilities Management Division
GSA Public Buildings Service – Heartland Region
2300 Main Street
Kansas City, MO 64108

Re: Goodfellow Federal Center
Metals in Settled Dust Sampling – Building 105
Project No. 121244

Dear Ms. Czarnecki:

Thank you for the opportunity to assist the General Services Administration (GSA) with the metals in settled dust sampling investigation of Building 105 located at the Goodfellow Federal Center (GFC) in St. Louis, Missouri. Burns & McDonnell understands that the purpose of the investigation was to provide additional sampling data of existing environmental conditions that are present at GFC that could adversely impact the health and safety of building occupants as well as workers at the facility. The following report summarizes the sample collection activities and the laboratory analytical results of samples submitted.

INTRODUCTION

Per historical use and previous characterization, Burns & McDonnell was contracted to perform settled dust sampling for the analysis of seven (7) of the Resource Conservation and Recovery Act (RCRA) target metals (arsenic, barium, cadmium, chromium, lead, selenium, and silver) from various surfaces within buildings. The purpose of this testing was to further characterize the presence and concentration of target metals in common tenant-occupied areas of the building.

The proposed sampling plan, the number of samples, the sample distribution and general methodology was developed by GSA and Burns & McDonnell. Specific sample locations were determined by sampling personnel while on-site.

Settled dust wipe sampling at Bldg. 105 was conducted on August 25, 2021 by Emily Ahlemeyer and Ashley Anstaett of Burns & McDonnell.

METALS IN SETTLED DUST SAMPLING

Metals in settled dust sampling was conducted within tenant-occupied areas. Dust wipe sampling was conducted in accordance with ASTM Standard E1728: *Standard Practice for Collection of Settled Dust Samples Using Wipe Sampling Methods for Subsequent Lead Determination* and ASTM Standard D6966: *Standard Practice for Collection of Settled Dust Samples Using Wipe Sampling Methods for Subsequent Determination of Metals*. ASTM Standards E1728 and D6966 are consistent with the methodology described in the Housing and Urban Development



Diane Czarnecki
Facilities Management Division
September 8, 2021
Page 2

Guidelines-Appendix 13.1 and 40 CFR 745.63. The Brookhaven National Laboratory's Surface Wipe Sampling Procedure (IH75190) was also used as a guideline.

Dust wipe sampling for the target metals was conducted on a variety of representative surfaces that have the potential of being disturbed by building occupants. A representative surface area of approximately one square foot (1 SF) was measured and delineated with plastic templates. The dust wipe samples were collected using dedicated dust wipe cloths meeting ASTM E1792 Standard. Each dust wipe cloth was pre-moistened and individually wrapped. Each sample was collected by wiping in a back and forth "S" pattern over a measured sampling area using a clean, disposable glove. Then, the wipe was folded over itself and the area was wiped again in a direction perpendicular to the first wipe orientation. Then, the wipe folded over itself again and the area was wiped around the perimeter. The wipe sample was then placed into a labeled, clean container. Dust wipe samples were submitted to Environmental Hazards Services, LLC (EHS) in Richmond, Virginia for Inductively Coupled Plasma (ICP) analysis of metals analysis using Environmental Protection Agency (EPA) method SW846 3050B/6010D. EHS is accredited under the American Industrial Hygiene Association (AIHA) Laboratory Accreditation Program (LAP) identification number LAP-100420.

Whereas the Occupational Safety and Health Administration (OSHA) has not established regulatory limits for surface concentrations of metals, the OSHA Technical Manual Section II: Chapter 2 (III.A) describes a method for calculating "housekeeping" standards, as recommended acceptable surface limits. Brookhaven's IH75190 procedure uses the housekeeping standards to derive a lower, "clean area limit" for non-operational areas that can be accessed or contacted without special training or precautions. Burns & McDonnell calculated clean area limits for metals not included in the Brookhaven procedure, specifically barium, chromium (total), selenium and silver. Wipe results were compared to the Brookhaven procedure's clean area limits for each metal.

Results of the dust wipe samples collected from the building indicate that 9 of the 11 samples contained concentrations of target metals above laboratory reporting limits. The following table identifies the range of results for each of the seven metals that were analyzed. Samples with a "<" sign indicate that the results were below the lab's reportable limit.

Diane Czarnecki
 Facilities Management Division
 September 8, 2021
 Page 3

Table 1. Summary of Dust Wipe Results

Analyte	Lowest Concentration ^(a) (µg/sq. ft) ^(b)	Highest Concentration ^(a) (µg/sq. ft) ^(b)	Clean Area Limit ^(c) µg/sq. ft ^(b)
Silver	<0.3	<0.5	62
Arsenic	<1.5	<2.5	62
Barium	<0.5	6.2	3,094
Cadmium	<0.1	4.2	31
Chromium (Total)	<0.6	1.5	3,094
Lead	<0.5	3.3	10 ^(d)
Selenium	<1.5	<2.5	1,236


- (a) Samples with a “<” sign indicate that the results were below the laboratory’s reporting limit.
- (b) µg/sq. ft = micrograms per square foot of surface area.
- (c) Clean Area Limit per Brookhaven IH75190=OSHA Housekeeping Limit [PEL (µg/m³) x 10 m³/100cm²] / 15.
- (d) Lead clean area limit: Brookhaven references EPA/HUD limit for floors, set at 10 µg/sq. ft. as of January 2020.

Of the 9 samples that had detectable levels of one or more analytes, none of them exceeded the clean area limit.

Burns & McDonnell appreciates the opportunity to work with the GSA on this project. Please contact us if you have any questions regarding this report or if we may be of any additional service.

Sincerely,

(b) (6)



Matt Shanahan, CHMM
 Project Manager

- Attachments:
- Appendix A – Sample Summary Table
 - Appendix B – Laboratory Analysis Report

Information in Appendices A and B is not accessible for people using screen reader technology. If this information is required, it can be furnished upon request by contacting 816-223-6198 or r6environmental@gsa.gov.

APPENDIX A – SAMPLE SUMMARY TABLE

Appendix A
Sample Summary Table

Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
105-W-01	Field blank	--	Arsenic	< 2.50	µg	--
			Barium	< 0.500	µg	--
			Cadmium	< 0.100	µg	--
			Chromium	< 1.00	µg	--
			Lead	< 0.500	µg	--
			Selenium	< 2.50	µg	--
			Silver	< 0.500	µg	--
105-W-02	2nd floor, USDA FSIS lab	Conference room 331, table	Arsenic	< 2.5	µg/ft ²	62
			Barium	< 0.50	µg/ft ²	3,094
			Cadmium	0.15	µg/ft ²	31
			Chromium	< 1.0	µg/ft ²	3,094
			Lead	< 0.50	µg/ft ²	10
			Selenium	< 2.5	µg/ft ²	1,236
			Silver	< 0.50	µg/ft ²	62
105-W-03	2nd floor, USDA FSIS lab	Desk in NE corner, room 342	Arsenic	< 2.5	µg/ft ²	62
			Barium	1.1	µg/ft ²	3,094
			Cadmium	0.16	µg/ft ²	31
			Chromium	< 1.0	µg/ft ²	3,094
			Lead	1.2	µg/ft ²	10
			Selenium	< 2.5	µg/ft ²	1,236
			Silver	< 0.50	µg/ft ²	62

Appendix A

Sample Summary Table

Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
105-W-04	2nd floor, USDA FSIS lab	Break room table	Arsenic	< 2.5	µg/ft ²	62
			Barium	0.56	µg/ft ²	3,094
			Cadmium	0.22	µg/ft ²	31
			Chromium	< 1.0	µg/ft ²	3,094
			Lead	< 0.50	µg/ft ²	10
			Selenium	< 2.5	µg/ft ²	1,236
			Silver	< 0.50	µg/ft ²	62
105-W-05	2nd floor, USDA FSIS lab	Room 317, laptop in NW cubicle	Arsenic	< 2.5	µg/ft ²	62
			Barium	2.8	µg/ft ²	3,094
			Cadmium	0.10	µg/ft ²	31
			Chromium	< 0.99	µg/ft ²	3,094
			Lead	0.58	µg/ft ²	10
			Selenium	< 2.5	µg/ft ²	1,236
			Silver	< 0.50	µg/ft ²	62
105-W-06	2nd floor, USDA FSIS lab	Room 310, paper cutter	Arsenic	< 2.5	µg/ft ²	62
			Barium	6.2	µg/ft ²	3,094
			Cadmium	4.2	µg/ft ²	31
			Chromium	1.5	µg/ft ²	3,094
			Lead	3.3	µg/ft ²	10
			Selenium	< 2.5	µg/ft ²	1,236
			Silver	< 0.50	µg/ft ²	62

Appendix A

Sample Summary Table

Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
105-W-07	1st floor, USDA office area	Table near printer, column F23	Arsenic	< 2.5	µg/ft ²	62
			Barium	1.5	µg/ft ²	3,094
			Cadmium	< 0.10	µg/ft ²	31
			Chromium	< 1.0	µg/ft ²	3,094
			Lead	0.72	µg/ft ²	10
			Selenium	< 2.5	µg/ft ²	1,236
			Silver	< 0.50	µg/ft ²	62
105-W-08	1st floor, USDA office area	Desk near column D18	Arsenic	< 2.5	µg/ft ²	62
			Barium	3.2	µg/ft ²	3,094
			Cadmium	< 0.10	µg/ft ²	31
			Chromium	< 1.0	µg/ft ²	3,094
			Lead	1.3	µg/ft ²	10
			Selenium	< 2.5	µg/ft ²	1,236
			Silver	< 0.50	µg/ft ²	62
105-W-09	1st floor, USDA office area	Conference room table, column J11	Arsenic	< 2.5	µg/ft ²	62
			Barium	< 0.50	µg/ft ²	3,094
			Cadmium	< 0.10	µg/ft ²	31
			Chromium	< 1.0	µg/ft ²	3,094
			Lead	< 0.50	µg/ft ²	10
			Selenium	< 2.5	µg/ft ²	1,236
			Silver	< 0.50	µg/ft ²	62

Appendix A

Sample Summary Table

Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
105-W-10	2nd floor, USDA office area	Printer near column E6	Arsenic	< 1.5	µg/ft ²	62
			Barium	2.4	µg/ft ²	3,094
			Cadmium	< 0.061	µg/ft ²	31
			Chromium	< 0.61	µg/ft ²	3,094
			Lead	0.48	µg/ft ²	10
			Selenium	< 1.5	µg/ft ²	1,236
			Silver	< 0.30	µg/ft ²	62
105-W-11	2nd floor, USDA office area	Desk near column F21	Arsenic	< 2.5	µg/ft ²	62
			Barium	1.2	µg/ft ²	3,094
			Cadmium	< 0.10	µg/ft ²	31
			Chromium	< 1.0	µg/ft ²	3,094
			Lead	0.84	µg/ft ²	10
			Selenium	< 2.5	µg/ft ²	1,236
			Silver	< 0.50	µg/ft ²	62

* Clean Area Limit per Brookhaven IH75190=OSHA Housekeeping Limit [PEL (µg/m³) x 10 m³/100cm²] / 15. Lead clean area limit: Brookhaven references EPA/HUD limit for floors, set at 10 µg/sq. ft. as of January 2020.

APPENDIX B – LABORATORY ANALYSIS REPORT



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Wipe Metals Analysis Report

Client: Burns & McDonnell Engineering
 9400 Ward Pkwy.
 Kansas City, MO 64114

Report Number: 21-08-04936

Received Date: 08/30/2021

Analyzed Date: 08/31/2021

Reported Date: 09/03/2021

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Client Number:
 26-3514

Laboratory Results

Fax Number:
 816-822-3494

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft ²)	Total Metal (ug)	Concentration (ug/ft ²)	Narrative ID
21-08-04936-001	105-W-01	Arsenic (As)		<2.50	---	
		Barium (Ba)		<0.500	---	
		Cadmium (Cd)		<0.100	---	
		Chromium (Cr)		<1.00	---	
		Lead (Pb)		<0.500	---	
		Selenium (Se)		<2.50	---	
		Silver (Ag)		<0.500	---	
21-08-04936-002	105-W-02	Arsenic (As)	1.00	<2.50	<2.5	
		Barium (Ba)	1.00	<0.500	<0.50	
		Cadmium (Cd)	1.00	0.150	0.15	
		Chromium (Cr)	1.00	<1.00	<1.0	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 21-08-04936

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft ²)	Total Metal (ug)	Concentration (ug/ft ²)	Narrative ID
		Lead (Pb)	1.00	<0.500	<0.50	
		Selenium (Se)	1.00	<2.50	<2.5	
		Silver (Ag)	1.00	<0.500	<0.50	
21-08-04936-003	105-W-03	Arsenic (As)	1.00	<2.50	<2.5	
		Barium (Ba)	1.00	1.08	1.1	
		Cadmium (Cd)	1.00	0.165	0.16	
		Chromium (Cr)	1.00	<1.00	<1.0	
		Lead (Pb)	1.00	1.18	1.2	
		Selenium (Se)	1.00	<2.50	<2.5	
		Silver (Ag)	1.00	<0.500	<0.50	
21-08-04936-004	105-W-04	Arsenic (As)	1.00	<2.50	<2.5	
		Barium (Ba)	1.00	0.560	0.56	
		Cadmium (Cd)	1.00	0.225	0.22	
		Chromium (Cr)	1.00	<1.00	<1.0	
		Lead (Pb)	1.00	<0.500	<0.50	
		Selenium (Se)	1.00	<2.50	<2.5	
		Silver (Ag)	1.00	<0.500	<0.50	
21-08-04936-005	105-W-05	Arsenic (As)	1.01	<2.50	<2.5	
		Barium (Ba)	1.01	2.86	2.8	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 21-08-04936

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft ²)	Total Metal (ug)	Concentration (ug/ft ²)	Narrative ID
		Cadmium (Cd)	1.01	0.100	0.10	
		Chromium (Cr)	1.01	<1.00	<0.99	
		Lead (Pb)	1.01	0.580	0.58	
		Selenium (Se)	1.01	<2.50	<2.5	
		Silver (Ag)	1.01	<0.500	<0.50	
21-08-04936-006	105-W-06	Arsenic (As)	1.00	<2.50	<2.5	
		Barium (Ba)	1.00	6.25	6.2	
		Cadmium (Cd)	1.00	4.24	4.2	
		Chromium (Cr)	1.00	1.47	1.5	
		Lead (Pb)	1.00	3.33	3.3	
		Selenium (Se)	1.00	<2.50	<2.5	
		Silver (Ag)	1.00	<0.500	<0.50	
21-08-04936-007	105-W-07	Arsenic (As)	1.00	<2.50	<2.5	
		Barium (Ba)	1.00	1.53	1.5	
		Cadmium (Cd)	1.00	<0.100	<0.10	
		Chromium (Cr)	1.00	<1.00	<1.0	
		Lead (Pb)	1.00	0.725	0.72	
		Selenium (Se)	1.00	<2.50	<2.5	
		Silver (Ag)	1.00	<0.500	<0.50	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 21-08-04936

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft ²)	Total Metal (ug)	Concentration (ug/ft ²)	Narrative ID
21-08-04936-008	105-W-08	Arsenic (As)	1.00	<2.50	<2.5	
		Barium (Ba)	1.00	3.16	3.2	
		Cadmium (Cd)	1.00	<0.100	<0.10	
		Chromium (Cr)	1.00	<1.00	<1.0	
		Lead (Pb)	1.00	1.32	1.3	
		Selenium (Se)	1.00	<2.50	<2.5	
		Silver (Ag)	1.00	<0.500	<0.50	
21-08-04936-009	105-W-09	Arsenic (As)	1.00	<2.50	<2.5	
		Barium (Ba)	1.00	<0.500	<0.50	
		Cadmium (Cd)	1.00	<0.100	<0.10	
		Chromium (Cr)	1.00	<1.00	<1.0	
		Lead (Pb)	1.00	<0.500	<0.50	
		Selenium (Se)	1.00	<2.50	<2.5	
		Silver (Ag)	1.00	<0.500	<0.50	
21-08-04936-010	105-W-10	Arsenic (As)	1.65	<2.50	<1.5	
		Barium (Ba)	1.65	3.88	2.4	
		Cadmium (Cd)	1.65	<0.100	<0.061	
		Chromium (Cr)	1.65	<1.00	<0.61	
		Lead (Pb)	1.65	0.795	0.48	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 21-08-04936

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft ²)	Total Metal (ug)	Concentration (ug/ft ²)	Narrative ID
		Selenium (Se)	1.65	<2.50	<1.5	
		Silver (Ag)	1.65	<0.500	<0.30	
21-08-04936-011	105-W-11	Arsenic (As)	1.00	<2.50	<2.5	
		Barium (Ba)	1.00	1.25	1.2	
		Cadmium (Cd)	1.00	<0.100	<0.10	
		Chromium (Cr)	1.00	<1.00	<1.0	
		Lead (Pb)	1.00	0.835	0.84	
		Selenium (Se)	1.00	<2.50	<2.5	
		Silver (Ag)	1.00	<0.500	<0.50	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 21-08-04936

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft ²)	Total Metal (ug)	Concentration (ug/ft ²)	Narrative ID
-------------------	----------------------	----------	------------------------------	------------------	-------------------------------------	--------------

Sample Narratives:

Analyst: Kailee Guthrie

Method: Mercury (Hg): EPA SW846 7471B

All other metals: EPA SW846 3050B/6010D

(b) (6)



Reviewed By Authorized Signatory:

Tasha Eaddy

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit for each particular metal, based on a 50mL volume. The reporting limit for Cadmium is 0.10ug, Barium, Lead and Silver are 0.50ug, Arsenic and Chromium are 1.0ug, and Selenium is 2.5ug.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. EHS sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of the Environmental Hazards Service, L.L.C. California Certification #2319 NY ELAP #11714.

Legend	ug = microgram	ug/ft ² = micrograms per square foot
	mL = milliliter	ft ² = square foot

ENVIRONMENTAL HAZARDS SERVICES, LLC

Metals Chain of Custody Form

Pg 1 of 1

Company Name		Burns & McDonnell			Account #		26-3514											
Company Address		9400 Ward Parkway			City/State/Zip		Kansas City, MO 64114											
Phone		314-302-4661			Email		eaahlemeyer@burnsmcd.com											
Project Name / Testing Address					GFC / 4300 Goodfellow Blvd													
PO Number		168765			Collected By		Emily Ahlemeyer & Ashley Anstaett											
Turn-Around Time		<input checked="" type="checkbox"/> 3 DAY <input type="checkbox"/> 2 DAY <input type="checkbox"/> 1 DAY <input type="checkbox"/> SAME DAY OR WEEKEND - Must Call Ahead																
LAB NUMBER	Client Sample ID	Collection Date & Time	METALS						Other Metals	PARTICULATES				AIR			WIPES	
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP		CA 17 Total	Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM-10	Total Time		Flow Rate
														Mins.	L/min.	Total Liters	AREA Circle The Unit of Measurement Used cm or <u>in</u>	
1	105-W-01	8/25/2021; 1225						Ag, As, Ba, Cd, Cr, Pb, Se										NA x NA
2	105-W-02	8/25/2021; 1227																12 x 12
3	105-W-03	8/25/2021; 1233																12 x 12
4	105-W-04	8/25/2021; 1236																12 x 12
5	105-W-05	8/25/2021; 1241																14 x 10
6	105-W-06	8/25/2021; 1246																12 x 12
7	105-W-07	8/25/2021; 1255																12 x 12
8	105-W-08	8/25/2021; 1300																12 x 12
9	105-W-09	8/25/2021; 1304																12 x 12
10	105-W-10	8/25/2021; 1310																19 x 12.5
11	105-W-11	8/25/2021; 1317																12 x 12
12																		x
13																		x
14																		x
15																		x
Released By:		Ashley Anstaett			Date:		8/27/2021			Time:		1000						
Signature:		(b) (6)																

LAB USE ONLY - BELOW THIS LINE


Received By: T Johnson

Signature: (b) (6)

Date: 8 / 30 / 21 Time: 12 : 15 AM PM

Portal Contact Added

21-08-04936



Due Date:
09/02/2021
(Thursday)
EL MM-L