



July 18, 2022

Diane Czarnecki
Industrial Hygienist
Facilities Management Division
GSA Public Buildings Service – Heartland Region
2300 Main Street
Kansas City, MO 64108

Re: Goodfellow Federal Center
Metals in Settled Dust Sampling – Building 106
Project No. 121244

Dear Ms. Czarnecki:

Thank you for the opportunity to assist the General Services Administration (GSA) with the metals in settled dust sampling investigation of Building 106 located at the Goodfellow Federal Center (GFC) in St. Louis, Missouri. Burns & McDonnell understands that the purpose of the investigation was to provide additional sampling data of existing environmental conditions that are present at GFC that could adversely impact the health and safety of building occupants as well as workers at the facility. The following report summarizes the sample collection activities and the laboratory analytical results of samples submitted.

INTRODUCTION

Per historical use and previous characterization, Burns & McDonnell was contracted to perform settled dust sampling for the analysis of seven (7) of the Resource Conservation and Recovery Act (RCRA) target metals (arsenic, barium, cadmium, chromium, lead, selenium, and silver) from various surfaces within buildings. The purpose of this testing was to further characterize the presence and concentration of target metals in common tenant-occupied areas of the building.

The proposed sampling scheme, the number of samples, the sample distribution and general methodology was developed by GSA and Burns & McDonnell. Specific sample locations were determined by sampling personnel while on-site.

Settled dust wipe sampling at Bldg. 106 was conducted on June 15, 2022 by Ashley Anstaett of Burns & McDonnell.

METALS IN SETTLED DUST SAMPLING

Metals in settled dust sampling was conducted primarily within tenant-occupied areas. Dust wipe sampling was conducted in accordance with ASTM Standard E1728: *Standard Practice for Collection of Settled Dust Samples Using Wipe Sampling Methods for Subsequent Lead Determination* and ASTM Standard D6966: *Standard Practice for Collection of Settled Dust Samples Using Wipe Sampling Methods for Subsequent Determination of Metals*. ASTM Standards E1728 and D6966 are consistent with the methodology described in the Housing and

Diane Czarnecki
Facilities Management Division
July 18, 2022
Page 2

Urban Development Guidelines-Appendix 13.1 and 40 CFR 745.63. The Brookhaven National Laboratory's Surface Wipe Sampling Procedure (IH75190) was also used as a guideline.

Dust wipe sampling for the target metals was conducted on a variety of representative surfaces that have the potential of being disturbed by building occupants. A representative surface area of approximately one square foot (1 SF) was measured and delineated with plastic templates. The dust wipe samples were collected using dedicated dust wipe cloths meeting ASTM E1792 Standard. Each dust wipe cloth was pre-moistened and individually wrapped. Each sample was collected by wiping in a back and forth "S" pattern over a measured sampling area using a clean, disposable glove. Then, the wipe was folded over itself and the area was wiped again in a direction perpendicular to the first wipe orientation. Then, the wipe folded over itself again and the area was wiped around the perimeter. The wipe sample was then placed into a labeled, clean container. Dust wipe samples were submitted to Environmental Hazards Services, LLC (EHS) in Richmond, Virginia for Inductively Coupled Plasma (ICP) analysis of metals analysis using Environmental Protection Agency (EPA) method SW846 3050B/6010D. EHS is accredited under the American Industrial Hygiene Association (AIHA) Laboratory Accreditation Program (LAP) identification number LAP-100420.

Whereas the Occupational Safety and Health Administration (OSHA) has not established regulatory limits for surface concentrations of metals, the OSHA Technical Manual Section II: Chapter 2 (III.A) describes a method for calculating "housekeeping" standards, as recommended acceptable surface limits. Brookhaven's IH75190 procedure uses the housekeeping standards to derive a lower, "clean area limit" for non-operational areas that can be accessed or contacted without special training or precautions. Burns & McDonnell calculated clean area limits for metals not included in the Brookhaven procedure, specifically barium, chromium (total), selenium and silver. Wipe results were compared to the Brookhaven procedure's clean area limits for each metal.

Results of the dust wipe samples collected from the building indicate that 1 of the 3 samples contained concentrations of target metals above laboratory reporting limits. The following table identifies the range of results for each of the seven metals that were analyzed. Samples with a "<" sign indicate that the results were below the lab's reportable limit.

Diane Czarnecki
 Facilities Management Division
 July 18, 2022
 Page 3

Table 1. Summary of Dust Wipe Results


Analyte	Lowest Concentration ^(a) (µg/sq. ft) ^(b)	Highest Concentration ^(a) (µg/sq. ft) ^(b)	Clean Area Limit ^(c) µg/sq. ft ^(b)
Silver	<0.5	<0.5	62
Arsenic	<2.5	<2.5	62
Barium	<0.5	0.5	3,094
Cadmium	<0.1	<0.1	31
Chromium (Total)	<1.0	<1.0	3,094
Lead	<0.5	0.6	10 ^(d)
Selenium	<2.5	<2.5	1,236

- (a) Samples with a “<” sign indicate that the results were below the laboratory’s reporting limit.
- (b) µg/sq. ft = micrograms per square foot of surface area.
- (c) Clean Area Limit per Brookhaven IH75190=OSHA Housekeeping Limit [(PEL (µg/m³) x 10 m³/100cm²) x 929cm²/sq.ft.] / 15.
- (d) Lead clean area limit: Brookhaven references EPA/HUD limit for floors, set at 10 µg/sq. ft. as of January 2020.

Of the 1 samples that had detectable levels of one or more analytes, none of them exceeded the clean area limit.

Burns & McDonnell appreciates the opportunity to work with the GSA on this project. Please contact us if you have any questions regarding this report or if we may be of any additional service.

Sincerely,

(b) (6)


Matt Shanahan, CHMM
 Project Manager

- Attachments:
 Appendix A – Sample Summary Table
 Appendix B – Laboratory Analysis Report

Information in Appendices A and B is not accessible for people using screen reader technology. If this information is required, it can be furnished upon request by contacting 816-223-6198 or r6environmental@gsa.gov.

APPENDIX A – SAMPLE SUMMARY TABLE

Appendix A
Sample Summary Table

Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
106-W-01	Security check in	Tall desk in front of work station	Arsenic	< 2.5	µg/ft ²	62
			Barium	< 0.50	µg/ft ²	3,094
			Cadmium	< 0.10	µg/ft ²	31
			Chromium	< 1.0	µg/ft ²	3,094
			Lead	< 0.50	µg/ft ²	10
			Selenium	< 2.5	µg/ft ²	1,236
			Silver	< 0.50	µg/ft ²	62
106-W-02	Security check in	Floor tile in front of no exit door	Arsenic	< 2.5	µg/ft ²	62
			Barium	0.54	µg/ft ²	3,094
			Cadmium	< 0.10	µg/ft ²	31
			Chromium	< 1.0	µg/ft ²	3,094
			Lead	0.58	µg/ft ²	10
			Selenium	< 2.5	µg/ft ²	1,236
			Silver	< 0.50	µg/ft ²	62
106-W-03	Field blank	--	Arsenic	< 2.50	µg	--
			Barium	< 0.500	µg	--
			Cadmium	< 0.100	µg	--
			Chromium	< 1.00	µg	--
			Lead	< 0.500	µg	--
			Selenium	< 2.50	µg	--
			Silver	< 0.500	µg	--

* Clean Area Limit per Brookhaven IH75190=OSHA Housekeeping Limit $[(PEL (\mu\text{g}/\text{m}^3) \times 10 \text{ m}^3/100\text{cm}^2)] \times 929\text{cm}^2/\text{sq. ft.} / 15$. Lead clean area limit: Brookhaven references EPA/HUD limit for floors, set at 10 µg/sq. ft. as of January 2020.

APPENDIX B – LABORATORY ANALYSIS REPORT



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Wipe Metals Analysis Report

Client: Burns & McDonnell Engineering
 9400 Ward Pkwy.
 Kansas City, MO 64114

Report Number: 22-06-03541

Received Date: 06/17/2022

Analyzed Date: 06/25/2022

Reported Date: 06/27/2022

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Client Number:
26-3514

Laboratory Results

Fax Number:
816-822-3494

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft ²)	Total Metal (ug)	Concentration (ug/ft ²)	Narrative ID
22-06-03541-001	106-W-01	Arsenic (As)	1.00	<2.50	<2.5	L01
		Barium (Ba)	1.00	<0.500	<0.50	L01
		Cadmium (Cd)	1.00	<0.100	<0.10	L01
		Chromium (Cr)	1.00	<1.00	<1.0	L01
		Lead (Pb)	1.00	<0.500	<0.50	L01
		Selenium (Se)	1.00	<2.50	<2.5	L01
		Silver (Ag)	1.00	<0.500	<0.50	L01
22-06-03541-002	106-W-02	Arsenic (As)	1.00	<2.50	<2.5	
		Barium (Ba)	1.00	0.545	0.54	
		Cadmium (Cd)	1.00	<0.100	<0.10	
		Chromium (Cr)	1.00	<1.00	<1.0	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 22-06-03541

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft ²)	Total Metal (ug)	Concentration (ug/ft ²)	Narrative ID
		Lead (Pb)	1.00	0.580	0.58	
		Selenium (Se)	1.00	<2.50	<2.5	
		Silver (Ag)	1.00	<0.500	<0.50	
22-06-03541-003	106-W-03	Arsenic (As)		<2.50	<2.5	
		Barium (Ba)		<0.500	<0.50	
		Cadmium (Cd)		<0.100	<0.10	
		Chromium (Cr)		<1.00	<1.0	
		Lead (Pb)		<0.500	<0.50	
		Selenium (Se)		<2.50	<2.5	
		Silver (Ag)		<0.500	<0.50	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 22-06-03541

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft ²)	Total Metal (ug)	Concentration (ug/ft ²)	Narrative ID
-------------------	----------------------	----------	------------------------------	------------------	-------------------------------------	--------------

Sample Narratives:

L01: LCS and/or LCSD percent recoveries for Se were outside acceptable control limits.

Analyst: Anthony Dee

Method: Mercury (Hg): EPA SW846 7471B

All other metals: EPA SW846 3050B/6010D

(b) (6)

Reviewed By Authorized Signatory:

Tasha Eaddy

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit for each particular metal, based on a 50mL volume. The reporting limit for Cadmium is 0.10ug, Barium, Lead and Silver are 0.50ug, Arsenic and Chromium are 1.0ug, and Selenium is 2.5ug.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. These sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of Environmental Hazards Services, L.L.C. NY ELAP #11714.

Legend	ug = microgram	ug/ft ² = micrograms per square foot
	mL = milliliter	ft ² = square foot

ENVIRONMENTAL HAZARDS SERVICES, LLC

Metals Chain of Custody Form

Pg 1 of 1

Company Name: Burns & McDonnell	Account #: 26-3514
Company Address: 9400 Ward Parkway	City/State/Zip: Kansas City, MO 64114
Phone: 314-302-4661	Email: eapulcher@burnsmcd.com
Project Name / Testing Address: GFC / 4300 Goodfellow Blvd	
PO Number: 168765	Collected By: A. Anstatt
Turn-Around Time: <input checked="" type="checkbox"/> 5 DAY <input type="checkbox"/> 3 DAY <input type="checkbox"/> 2 DAY <input type="checkbox"/> 1 DAY <input type="checkbox"/> SAME DAY OR WEEKEND - Must Call Ahead	

LAB NUMBER	Client Sample ID	Collection Date & Time	METALS						PARTICULATES			AIR		WIPES AREA <small>Circle The Unit of Measurement Used</small> cm or (in)				
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP	CA 17 Total	Other Metals <small>Ag, As, Ba, Cd, Cr, Pb, Se</small>	Total Nuisance Dust	Respirable Dust	TSP Gravimetric		TSP Pb	PM 10	Total Time <small>Mins</small>	Flow Rate <small>l/min</small>
100-W-01		6/15/22 0709																12 x 12
100-W-02		0712																12 x 12
100-W-03		0709																NA x NA
																		X
																		X
																		X
																		X
																		X
																		X
																		X
																		X
																		X
																		X
																		X
																		X
																		X
																		X
Released By:	A. Anstatt		Date: 6/15/22						Time: 1630									
Signature:	(b) (6)																	

LAB USE ONLY - BELOW THIS LINE

Received By: TALW

Signature: (b) (6)

Date: 6/17/22 Time: 12:15p AM PM

Portal Contact Added

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010

RESULTS VIA CLIENT PORTAL AVAILABLE @ www.leadlab.com

22-06-03541

Due Date:
06/24/2022
(Friday)
EL MM-L