



June 02, 2010

Jeff Smith
OCCU-TEC INC.
6501 E. Commerce
Suite 230
Kansas City, MO 64120-

Bureau Veritas Work Order No.: A1006012

Reference: 90031

Dear Jeff Smith:

Bureau Veritas North America, Inc. received 26 samples on 6/1/2010 10:41:43 AM and reported on 6/2/2010 9:14:13 AM for the analyses presented in the following report.

The results apply only to the samples analyzed in this project. Please note that any unused portion of the samples will be discarded after a thirty-day holding period, unless you have requested otherwise.

We appreciate the opportunity to assist you. If you have any questions concerning the report, please contact the analyst whose name appears on the report or myself at (770) 499-7701.

Sincerely,

(b) (6)

Tiffany Dixon
Microscopist

Bureau Veritas North America, Inc.

Health, Safety, and Environmental Services
3380 Chastain Meadows Parkway, Suite 300
Kennesaw, GA 30144

Main: (770) 499-7701
Fax: (770) 499-7511
www.us.bureauveritas.com



CASE NARRATIVE

Date: 02-Jun-10

CLIENT: OCCU-TEC INC.

Project: 90031

Work Order No A1006012

Report Date: 02-Jun-10

ANALYTICAL METHOD FOR ASBESTOS IN BULK SAMPLES USING POLARIZED LIGHT MICROSCOPY (PLM)

Use of EPA/600/R-93/116 satisfies applicable requirements of the USEPA's "Interim Method for the Determination of Asbestos in Bulk Insulation Sample", EPA-600/M4-82-020, December 1982, published as Appendix E to Subpart E of 40CFR763. Bulk samples analyzed by New York State methods follow stratified point counting methods (198.1) or Method 198.6 for PLM non-friable organically bound materials (NYSDOH Lab Code –11645). Percentages are visual estimations of asbestos >10:1 aspect ratio. The reliable limit of quantitation of the method is 1%, although asbestos may be qualitatively detected at concentrations less than 1%. Samples for which asbestos is detected at <1% are reported as trace, "<1%". "None Detected" indicates that no asbestos fibers were observed. NESHAP requires point counting of a bulk sample when the result is <10% by a method other than point counting. EPA, however states that if 3 mounts of the sample are analyzed and the asbestos percentage is <10% by visual estimation, the client may elect to assume the amount to be greater than 1% or require verification by point counting. If the result by point counting is different than the result obtained by visual estimation, the point count result will be used. Sample friability or non-friability noted on the report is a requirement for the State of California and refers only to the condition of the sample under macroscopic examination. It does not imply friability or non-friability for the sample as collected or observed in the field as determined by the person collecting the sample. The Kennesaw, Georgia lab is accredited by NVLAP –Lab Code 101125-0.

(a)Polarized- light microscopy is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. Quantitative electron microscopy is currently the only method that can be used to determine if this material can be considered or treated as non-asbestos containing. When analysis of such materials by PLM yields results negative for the presence of asbestos, Bureau Veritas recommends utilizing quantitative transmission electron microscopy (TEM). For more information, contact the laboratory.

References

McCrone, Walter C. 1980. The Asbestos Particle Atlas. Ann Arbor, MI: Ann Arbor Science Publishers, Inc.

United States Environmental Protection Agency. Environmental Monitoring Systems Laboratory. 1982. Interim Method for the Determination of Asbestos in Bulk Insulation Samples. EPA-600/M4-82-020. Washington: GPO, December.

United States Environmental Protection Agency. Method for the Determination of Asbestos in Bulk



CLIENT: OCCU-TEC INC.

Project: 90031

Work Order No A1006012

Report Date: 02-Jun-10

Building Materials. EPA-600/R-93/116, July 1993 (PLM)

Fed. Reg. Vol. 55, No.224, 11/20/90, p.48415 (NESHAP)

EPA Memorandum 5/8/1991 –NESHAP Clarifications

NYSDOH Methods 198.1/198.6



ANALYTICAL RESULTS

Date: 02-Jun-10

CLIENT: OCCU-TEC INC.

Sample Type: Bulk

Work Order No.: A1006012

Date Received: 6/1/2010

Client Reference: 90031

Report Date: 02-Jun-10

Method Reference: EPA-600/M4-82-020/EPA/600/R-93/116/NYELAP 198.1

Lab ID	Client Sample ID	Analyst	Date Sampled	Date Analyzed			
001A	RT-01-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	100	Homogeneous Black Roofing Material	None Detected		Cellulose fiber	10%	Binder/Filler Tar
002A	RT-02-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	100	Homogeneous Silver Roofing Material	None Detected		Cellulose fiber	3%	Binder/Filler
003A	RC-03-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	100	Homogeneous Gray Roofing Caulk	None Detected		Non-Detected		Binder/Filler
004A	DWJC-04-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	5	Homogeneous White Joint Compound	None Detected		Cellulose fiber	90%	Binder/Filler
(2)	15	Homogeneous White Tape	None Detected		Cellulose fiber	90%	Binder/Filler
(4)	80	Homogeneous White Drywall	None Detected		Fibrous glass	3%	Binder/Filler
					Cellulose fiber	10%	
005A	DWJC-04-02	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	40	Homogeneous White Joint Compound	None Detected		Cellulose fiber	1%	Binder/Filler
(2)	60	Homogeneous White Drywall	None Detected		Fibrous glass	3%	Binder/Filler
					Cellulose fiber	3%	
006A	DWJC-04-03	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	30	Homogeneous White Joint Compound	None Detected		Cellulose fiber	1%	Binder/Filler
(2)	20	Homogeneous Tan & Silver Tape	None Detected		Cellulose fiber	70%	Binder/Filler
						3%	Foil
(3)	50	Homogeneous White Drywall	None Detected		Fibrous glass	3%	Binder/Filler

The reliable limit of quantitation of the method is 1%, although asbestos may be qualitatively detected at concentrations less than 1%. Samples for which asbestos is detected at <1% are reported as trace, "<1%". "None Detected" indicates that no asbestos fibers were observed.

Analyst(s) Name/Date: (b) (6) 6/2/2010



ANALYTICAL RESULTS

Date: 02-Jun-10

CLIENT: OCCU-TEC INC. **Sample Type:** Bulk
Work Order No.: A1006012 **Date Received:** 6/1/2010
Client Reference: 90031 **Report Date:** 02-Jun-10
Method Reference: EPA-600/M4-82-020/EPA/600/R-93/116/NYELAP 198.1

Lab ID	Client Sample ID	Analyst	Date Sampled	Date Analyzed			
007A	CT-05-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	100	Homogeneous White Ceiling Tile	None Detected		Cellulose fiber Mineral wool	35% 35%	Binder/Filler Paint Perlite
008A	BBMA-06-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	40	Homogeneous Beige Baseboard	None Detected		Non-Detected		Binder/Filler
(2)	55	Homogeneous Beige Mastic	None Detected		Non-Detected		Binder/Filler
(3)	5	Homogeneous White Joint Compound	None Detected		Non-Detected		Binder/Filler
009A	FTM-07-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	99	Homogeneous Off-White Floor Tile	None Detected		Non-Detected		Binder/Filler
(2)	1	Homogeneous Black Mastic	None Detected		Cellulose fiber	5%	Binder/Filler
010A	LN-09-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	100	Homogeneous Yellow Flooring	Chrysotile	3%	Cellulose fiber	5%	Binder/Filler
				Total	3%		
011A	BBMA-10-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	50	Homogeneous Gray Baseboard	None Detected		Non-Detected		Binder/Filler
(2)	40	Homogeneous Yellow Mastic	None Detected		Non-Detected		Binder/Filler
(3)	10	Homogeneous Tan Paper	None Detected		Cellulose fiber	90%	Binder/Filler

Layer Comment: Sample layers were inseparable.

The reliable limit of quantitation of the method is 1%, although asbestos may be qualitatively detected at concentrations less than 1%. Samples for which asbestos is detected at <1% are reported as trace, "<1%". "None Detected" indicates that no asbestos fibers were observed.

Analyst(s) Name/Date: (b) (6)

6/2/2010



ANALYTICAL RESULTS

Date: 02-Jun-10

CLIENT: OCCU-TEC INC.

Sample Type: Bulk

Work Order No.: A1006012

Date Received: 6/1/2010

Client Reference: 90031

Report Date: 02-Jun-10

Method Reference: EPA-600/M4-82-020/EPA/600/R-93/116/NYELAP 198.1

Lab ID	Client Sample ID	Analyst	Date Sampled	Date Analyzed			
012A	FTM-11-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	97	Homogeneous Beige Floor Tile	Chrysotile	10%	Non-Detected		Binder/Filler
(2)	3	Homogeneous Black Mastic	None Detected		Non-Detected		Binder/Filler
				Total	10%		
013A	WP-12-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	50	Homogeneous Brown Paper	None Detected		Cellulose fiber	90%	Binder/Filler
(2)	50	Homogeneous White Drywall	None Detected		Cellulose fiber	5%	Binder/Filler
014A	FTM-13-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	98	Homogeneous Off-White Floor Tile	None Detected		Non-Detected		Binder/Filler
(2)	2	Homogeneous Black/Yellow Mastic	None Detected		Non-Detected		Binder/Filler
015A	STM-14-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	40	Homogeneous Yellow Mastic	None Detected		Non-Detected		Binder/Filler
(2)	60	Homogeneous Brown Flooring	None Detected		Non-Detected		Binder/Filler
016A	FTM-15-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	40	Homogeneous Yellow Mastic	None Detected		Non-Detected		Binder/Filler
(2)	60	Homogeneous Brown Flooring	None Detected		Non-Detected		Binder/Filler
017A	BBMA-16-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	80	Homogeneous Gray Baseboard	None Detected		Non-Detected		Binder/Filler
(2)	10	Homogeneous Yellow Mastic	None Detected		Cellulose fiber	1%	Binder/Filler
(3)	5	Homogeneous Tan Joint Compound	None Detected		Cellulose fiber	3%	Binder/Filler
(4)	5	Homogeneous Tan Paper	None Detected		Cellulose fiber	90%	Binder/Filler

The reliable limit of quantitation of the method is 1%, although asbestos may be qualitatively detected at concentrations less than 1%. Samples for which asbestos is detected at <1% are reported as trace, "<1%". "None Detected" indicates that no asbestos fibers were observed.

Analyst(s) Name/Date: (b) (6)

6/2/2010



ANALYTICAL RESULTS

Date: 02-Jun-10

CLIENT: OCCU-TEC INC.

Sample Type: Bulk

Work Order No.: A1006012

Date Received: 6/1/2010

Client Reference: 90031

Report Date: 02-Jun-10

Method Reference: EPA-600/M4-82-020/EPA/600/R-93/116/NYELAP 198.1

Lab ID	Client Sample ID	Analyst	Date Sampled	Date Analyzed			
018A	FTM-17-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	95	Homogeneous White Floor Tile	None Detected		Non-Detected		Binder/Filler
(2)	5	Homogeneous Black Mastic	None Detected		Cellulose fiber	5%	Binder/Filler
019A	SK-18-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	100	Homogeneous Gray Sink Coating	None Detected		Cellulose fiber	10%	Binder/Filler
020A	BBMA-19-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	90	Homogeneous White Baseboard	None Detected		Non-Detected		Binder/Filler
(2)	5	Homogeneous Yellow Mastic	None Detected		Non-Detected		Binder/Filler
(3)	5	Homogeneous White Joint Compound	None Detected		Cellulose fiber	10%	Binder/Filler
021A	BBMA-20-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	90	Homogeneous White Baseboard	None Detected		Non-Detected		Binder/Filler
(2)	3	Homogeneous Yellow Mastic	None Detected		Non-Detected		Binder/Filler
(3)	7	Homogeneous Tan Paper	None Detected		Cellulose fiber	80%	Binder/Filler Paint
022A	BBMA-21-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	98	Homogeneous Dark Blue Baseboard	None Detected		Non-Detected		Binder/Filler
(2)	2	Homogeneous Yellow Mastic	None Detected		Non-Detected		Binder/Filler
023A	BBMA-22-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	90	Homogeneous Beige Baseboard	None Detected		Non-Detected		Binder/Filler
(2)	3	Homogeneous Yellow Mastic	None Detected		Non-Detected		Binder/Filler
(3)	7	Homogeneous White Joint Compound	None Detected		Cellulose fiber	1%	Binder/Filler

The reliable limit of quantitation of the method is 1%, although asbestos may be qualitatively detected at concentrations less than 1%. Samples for which asbestos is detected at <1% are reported as trace, "<1%". "None Detected" indicates that no asbestos fibers were observed.

Analyst(s) Name/Date: (b) (6) 6/2/2010



ANALYTICAL RESULTS

Date: 02-Jun-10

CLIENT: OCCU-TEC INC.

Sample Type: Bulk

Work Order No.: A1006012

Date Received: 6/1/2010

Client Reference: 90031

Report Date: 02-Jun-10

Method Reference: EPA-600/M4-82-020/EPA/600/R-93/116/NYELAP 198.1

Lab ID	Client Sample ID	Analyst	Date Sampled	Date Analyzed			
024A	FTM-23-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	98	Homogeneous White Floor Tile	None Detected		Non-Detected		Binder/Filler
(2)	2	Homogeneous Black Mastic	None Detected		Cellulose fiber	2%	Binder/Filler
025A	FTM-24-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	98	Homogeneous Gray Floor Tile	None Detected		Non-Detected		Binder/Filler
(2)	2	Homogeneous Black Mastic	None Detected		Cellulose fiber	2%	Binder/Filler
026A	FTM-25-01	NG	04/13/2010	06/01/2010			
Layer	POB	Sample Morphology	Asbestos	%	Other Fibers	%	Particulate
(1)	98	Homogeneous Gray Floor Tile	None Detected		Non-Detected		Binder/Filler
(2)	2	Homogeneous Black & Red Mastic	None Detected		Cellulose fiber	2%	Binder/Filler

Laboratory Limits

Laboratory

Range	R Limit	Quartile Limit
0.1-1	100	+/- 1.482
10-100	100	+/- 22.23
1-10	100	+/- 7.41
Trace	100	+/- 1.482

Nadiya Gapon (NG)

Range	R Limit	Quartile Limit
0.1-1	100	+/- 1.482
10-100	100	+/- 26.676
1-10	100	+/- 5.928
Trace	100	+/- 1.482

The reliable limit of quantitation of the method is 1%, although asbestos may be qualitatively detected at concentrations less than 1%. Samples for which asbestos is detected at <1% are reported as trace, "<1%". "None Detected" indicates that no asbestos fibers were observed.

Analyst(s) Name/Date: (b) (6) 6/2/2010

A1 006012

REQUEST FOR LABORATORY ANALYTICAL SERVICES

For Bureau Veritas Use Only
Bureau Veritas Lab Project No.



BUREAU VERITAS

Bureau Veritas North America, Inc.

Detroit Lab
22345 Roethel Drive
Novi, MI 48375
(800) 806-5887
(248) 344-1770
FAX (248) 344-2655

Atlanta Lab
3380 Chastain Meadows Pk., Suite 300
Kennesaw, GA 30144
(800) 252-9919
(770) 499-7500
FAX (770) 499-7511

Chicago Lab
95 Oakwood Road
Lake Zurich, IL 60047
(888) 576-7522
(847) 726-3320
FAX (847) 726-3323

RUSH ANALYSIS

CONTACT LAB IN ADVANCE
Need Results by: 6/1/10
Charges Authorized? Yes No
(if yes, initial here) JS
Email Results jsmith@occuru.com Fax

Name <u>Jeff Smith</u> Client Job No. <u>90031</u> Company <u>Occu-Test</u> Dept. <u></u>		Name <u>Dave Hartsborn/Gary Adams (GSA)</u> Company <u>GSA</u> Address <u>1500 E. Bannister Road</u> City, State, Zip <u>Kansas City, Mo</u>		PO # <u></u> Call for Credit Card Information <input type="checkbox"/> Direct Bill <input type="checkbox"/>	
Mailing Address <u>4151 N Mulberry Suite 275</u> City, State, Zip <u>Kansas City Mo 64116</u> Telephone No. <u>816 994-3421</u> FAX No. <u></u>		Address <u>1500 E. Bannister Road</u> City, State, Zip <u>Kansas City, Mo</u>		ANALYSIS REQUESTED <u></u>	
Special instructions and/or specific regulatory requirements: <u>Goodfellow # 104E Day Care (MO 0610)</u>		Waters: <input type="checkbox"/> Drinking Water <input type="checkbox"/> Groundwater <input type="checkbox"/> Wastewater		(Enter an 'X' in the box below to indicate request. Enter a 'P' if Preservative added.)	
* Explanation of Preservative		Which state are these from?		Number of Containers	
CLIENT SAMPLE IDENTIFICATION	DATE SAMPLED	TIME SAMPLED	MATRIX/MEDIA	AIR VOLUME (specify units)	FOR LAB USE ONLY
<u>RT-01-01</u>	<u>4-13-10</u>		<u>Pulk</u>		
<u>RT-02-01</u>					
<u>RC-03-01</u>					
<u>QW-5C-04-01</u>					
<u>QW-5C-04-02</u>					
<u>QW-5C-04-03</u>					
<u>CT-05-01</u>					
<u>BBMA-06-01</u>					
<u>FTM-07-01</u>					
<u>LN-09-01</u>					
<u>BBMA-10-01</u>					
<u>FTM-11-01</u>					

CHAIN OF CUSTODY

Collected by: Josh Ashley (print)
 Relinquished by: [Redacted]
 Relinquished by: [Redacted]
 Method of Shipment: Fed Ex

Date: 5-27-10

Sample Condition Upon Receipt: Acceptable Other (explain) 1105

Collector's Signature: [Redacted]
 Received by: [Redacted]
 Received at Lab by: [Redacted]

Date/Time: 6/1/2010 11:41 AM
 Date/Time: 6/1/2010 11:41 AM
 Date/Time: 6/1/2010 11:41 AM

REQUEST FOR LABORATORY ANALYTICAL SERVICES

For Bureau Veritas Use Only
Bureau Veritas Lab Project No.



BUREAU VERITAS

Bureau Veritas North America, Inc.

Detroit Lab
22345 Rosethel Drive
Novi, MI 48375
(800) 806-5887
(248) 344-1770
FAX (248) 344-2655

Atlanta Lab
3380 Chastain Meadows Pky., Suite 300
Kennesaw, GA 30144
(800) 252-9919
(770) 499-7500
FAX (770) 499-7511

Chicago Lab
95 Oakwood Road
Lake Zurich, IL 60047
(888) 576-7522
(847) 726-3320
FAX (847) 726-3923

RUSH ANALYSIS

CONTACT LAB IN ADVANCE

Need Results by: / /
Charges Authorized? Yes No
(If yes, Initial here) _____
Email Results Fax

Name		Client Job No.		PO #		Call for Credit Card Information <input type="checkbox"/> Direct Bill	
Company		Dept.		Name		Company	
Mailing Address		City, State, Zip		Address		City, State, Zip	
Telephone No.		FAX No.		City, State, Zip		City, State, Zip	
Special instructions and/or specific regulatory requirements: (method, limit of detection, etc.)							
* Explanation of Preservative							
CLIENT SAMPLE IDENTIFICATION	DATE SAMPLED	TIME SAMPLED	MATRIX/MEDIA	AIR VOLUME (specify units)	ANALYSIS REQUESTED (Enter an 'X' in the box below to indicate request. Enter a 'P' if Preservative added.)*		
W.P. 12-01	4-13-01		Bulk		X		
FTM-13-01							
S.T.M-14-01							
FTM-15-01							
BBMA-16-01							
FTM-17-01							
SK-18-01							
BBMA-19-01							
BBMA-20-01							
BBMA-21-01							
BBMA-22-01							
FTM-23-01							
Collected by:				Collector's Signature			
Relinquished by:				Received by:			
Relinquished by:				Received by:			
Method of Shipment:				Received at Lab by:			
Date				Sample Condition Upon receipt: <input type="checkbox"/> Acceptable <input checked="" type="checkbox"/> Other (explain) 110			
Authorized by:				Date			

(Client Signature MUST Accompany Request)

REQUEST FOR LABORATORY ANALYTICAL SERVICES

For Bureau Veritas Use Only
Bureau Veritas Lab Project No.



BUREAU VERITAS

Bureau Veritas North America, Inc.

Detroit Lab
22345 Rosethel Drive
Novi, MI 48375
(800) 806-5887
(248) 344-1770
FAX (248) 344-2655

Atlanta Lab
3380 Chastain Meadows Pkwy., Suite 300
Kennesaw, GA 30144
(800) 252-9919
(770) 499-7500
FAX (770) 499-7511

Chicago Lab
95 Oakwood Road
Lake Zurich, IL 60047
(888) 576-7522
(847) 726-3320
FAX (847) 726-3323

RUSH ANALYSIS

CONTACT LAB IN ADVANCE

Need Results by: / /
Charges Authorized? Yes No
(If yes, Initial here) _____
Email Results Fax

Name		Client Job No.		PO #		Call for Credit Card Information <input type="checkbox"/> Direct Bill <input type="checkbox"/>	
Company		Dept.		Name		Company	
Mailing Address				Address		City, State, Zip	
City, State, Zip		FAX No.		Telephone No.		City, State, Zip	
Special instructions and/or specific regulatory requirements: (method, limit of detection, etc.)		Soils: Which state are these from?		Waters: <input type="checkbox"/> Drinking Water <input type="checkbox"/> Groundwater <input type="checkbox"/> Wastewater		ANALYSIS REQUESTED (Enter an 'X' in the box below to indicate request. Enter a 'P' if Preservative added.)	
* Explanation of Preservative		DATE SAMPLED		TIME SAMPLED		MATRIX/MEDIA	
CLIENT SAMPLE IDENTIFICATION		AIR VOLUME (specify units)		Collector's Signature		Date/Time	
ETM-24-01 ✓		4-13-10		BULK		(b) (6)	
ETM-25-01 ✓		-6		↓		Received by:	
						Date/Time	
						Received by:	
						Date/Time	
						Received at Lab by:	
						Date/Time	
						Sample Condition Upon Receipt: <input type="checkbox"/> Acceptable <input checked="" type="checkbox"/> Other (explain) 1105	
Method of Shipment:		Date		S-27-10		Other (explain)	
Authorized by:		Date		S-27-10		Other (explain)	
Chain of Custody:		Date		S-27-10		Other (explain)	
Collected by:		Date/Time		S-27-10		Other (explain)	
Relinquished by:		Date/Time		S-27-10		Other (explain)	
Relinquished by:		Date/Time		S-27-10		Other (explain)	
Method of Shipment:		Date		S-27-10		Other (explain)	
Authorized by:		Date		S-27-10		Other (explain)	

(Client Signature MUST Accompany Request)