

| Asset Number | Date | Time | Floor | Location / Plumbing Outlet (For Publication) | Number of Filters | Filter(s) Inspected | Filter(s) Replaced | Cold Flow Rate (GPM) | Hot Flow Rate (GPM) | Mixed Flow Rate (GPM) |
|--------------|----------|----------|------------|---|-------------------|---------------------|--------------------|----------------------|---------------------|-----------------------|
| 2944316 | 1/8/2024 | 2:25 AM | Floor 07 | 7W-1 Women's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944318 | 1/8/2024 | 2:28 AM | Floor 07 | 7W-1 Women's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.42 |
| 2944317 | 1/8/2024 | 2:28 AM | Floor 07 | 7W-1 Women's Restroom East - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | 0.44 |
| 2944309 | 1/8/2024 | 2:32 AM | Floor 07 | 7M-1 Men's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944308 | 1/8/2024 | 2:33 AM | Floor 07 | 7M-1 Men's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944291 | 1/8/2024 | 2:39 AM | Floor 07 | C707-Janitor's Closet-Mop/Slop Sink | 1 | ☑ | ☐ | 2.4 | | |
| 2944304 | 1/8/2024 | 2:42 AM | Floor 07 | 7M-2 Men's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.42 |
| 2944305 | 1/8/2024 | 2:44 AM | Floor 07 | 7M-2 Men's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.42 |
| 2944303 | 1/8/2024 | 2:44 AM | Floor 07 | 7W-2 Women's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944302 | 1/8/2024 | 2:44 AM | Floor 07 | 7W-2 Women's Restroom West - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | 0.48 |
| 2944301 | 1/8/2024 | 2:44 AM | Floor 07 | 7W-2 Women's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.54 |
| 2944333 | 1/8/2024 | 2:45 AM | Floor 08 | 8W-2 Women's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944262 | 1/8/2024 | 2:59 AM | Floor 06 | C607-Janitor's Closet - Mop/Slop Sink | 1 | ☑ | ☐ | 2.16 | | |
| 2944287 | 1/8/2024 | 3:09 AM | Floor 06 | 6W-1 Women's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944289 | 1/8/2024 | 3:10 AM | Floor 06 | 6W-1 Women's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944288 | 1/8/2024 | 3:10 AM | Floor 06 | 6W-1 Women's Restroom East - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | 0.54 |
| 2944280 | 1/8/2024 | 3:11 AM | Floor 06 | 6M-1 Men's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.42 |
| 2944279 | 1/8/2024 | 3:11 AM | Floor 06 | 6M-1 Men's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944273 | 1/8/2024 | 3:20 AM | Floor 06 | 6W-2 Women's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944272 | 1/8/2024 | 3:20 AM | Floor 06 | 6W-2 Women's Restroom West - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | 0.48 |
| 2944275 | 1/8/2024 | 3:21 AM | Floor 06 | 6M-2 Men's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.42 |
| 2944274 | 1/8/2024 | 3:21 AM | Floor 06 | 6M-2 Men's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.42 |
| 2944271 | 1/8/2024 | 3:26 AM | Floor 06 | 6W-2 Women's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944398 | 1/8/2024 | 3:31 AM | Floor 10 | 10M-1 Men's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.42 |
| 2944058 | 1/8/2024 | 3:50 AM | Floor 01 | 108-4 Cafe Prep. - Kitchen Faucet-Small | 1 | ☑ | ☐ | 72 | 1.2 | |
| 2944258 | 1/8/2024 | 10:21 AM | Floor 05 | 5W-1 Women's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944257 | 1/8/2024 | 10:21 AM | Floor 05 | 5W-1 Women's Restroom East - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | 0.42 |
| 2944256 | 1/8/2024 | 10:21 AM | Floor 05 | 5W-1 Women's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944249 | 1/8/2024 | 10:50 AM | Floor 05 | 5M-1 Men's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944248 | 1/8/2024 | 10:50 AM | Floor 05 | 5M-1 Men's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944240 | 1/8/2024 | 11:00 AM | Floor 05 | C507 Janitor's Closet - Mop/Slop Sink | 1 | ☑ | ☐ | 1.87 | | |
| 2944237 | 1/8/2024 | 11:00 AM | Floor 05 | 5M-2 Men's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.42 |
| 2944236 | 1/8/2024 | 11:00 AM | Floor 05 | 5M-2 Men's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944235 | 1/8/2024 | 11:10 AM | Floor 05 | 5W-2 Women's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944234 | 1/8/2024 | 11:10 AM | Floor 05 | 5W-2 Women's Restroom West - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | 0.80 |
| 2944233 | 1/8/2024 | 11:10 AM | Floor 05 | 5W-2 Women's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944218 | 1/8/2024 | 11:30 AM | Floor 04 | C407 Janitor's Closet-Mop/Slop Sink | 1 | ☑ | ☐ | 1.76 | | |
| 2944215 | 1/8/2024 | 11:40 AM | Floor 04 | 4M-2 Men's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944214 | 1/8/2024 | 11:40 AM | Floor 04 | 4M-2 Men's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | |
| 2944213 | 1/8/2024 | 11:40 AM | Floor 04 | 4W-2 Women West-Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944212 | 1/8/2024 | 11:40 AM | Floor 04 | 4W-2 Women's Restroom West - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | 0.48 |
| 2944211 | 1/8/2024 | 11:40 AM | Floor 04 | 4W-2 Women's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944413 | 1/8/2024 | 12:00 PM | Floor 02EC | E201 Restroom - Lavatory Faucet | 1 | ☑ | ☐ | | | 0.48 |
| 2944202 | 1/8/2024 | 1:00 PM | Floor 04 | 4M-1 Men's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944201 | 1/8/2024 | 1:00 PM | Floor 04 | 4M-1 Men's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944200 | 1/8/2024 | 1:10 PM | Floor 04 | 4W-1 Women's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | |
| 2944199 | 1/8/2024 | 1:10 PM | Floor 04 | 4W-1 Women's Restroom East - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | |
| 2944198 | 1/8/2024 | 1:10 PM | Floor 04 | 4W-1 Women's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944191 | 1/8/2024 | 1:30 PM | Floor 03 | 3W-1 Women's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944190 | 1/8/2024 | 1:30 PM | Floor 03 | 3W-1 Women's Restroom East - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | 0.48 |
| 2944189 | 1/8/2024 | 1:30 PM | Floor 03 | 3W-1 Women's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944182 | 1/8/2024 | 1:50 PM | Floor 03 | 3M-1 Men's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944181 | 1/8/2024 | 1:50 PM | Floor 03 | 3M-1 Men's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944177 | 1/8/2024 | 2:00 PM | Floor 03 | 3M-2 Men's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944176 | 1/8/2024 | 2:10 PM | Floor 03 | 3W-2 Women's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944175 | 1/8/2024 | 2:10 PM | Floor 03 | 3W-2 Women's Restroom West - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | 0.48 |
| 2944174 | 1/8/2024 | 2:10 PM | Floor 03 | 3W-2 Women's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944158 | 1/8/2024 | 2:40 PM | Floor 02 | 2M-1 Men's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944157 | 1/8/2024 | 2:40 PM | Floor 02 | 2M-1 Men's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944156 | 1/8/2024 | 2:50 PM | Floor 02 | 2W-1 Women's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944155 | 1/8/2024 | 2:50 PM | Floor 02 | 2W-1 Women's Restroom East - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | 0.48 |
| 2944154 | 1/8/2024 | 2:54 PM | Floor 02 | 2W-1 Women's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944147 | 1/8/2024 | 3:10 PM | Floor 02 | 2M-2 Men's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944146 | 1/8/2024 | 3:10 PM | Floor 02 | 2M-2 Men's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944145 | 1/8/2024 | 3:20 PM | Floor 02 | 2W-2 Women's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.42 |
| 2944144 | 1/8/2024 | 3:20 PM | Floor 02 | 2W-2 Women's Restroom West - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | 0.48 |
| 2944143 | 1/8/2024 | 3:20 PM | Floor 02 | 2W-2 Women's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944136 | 1/8/2024 | 3:30 PM | Floor 02 | C207 Janitor's Closet-Mop/Slop Sink | 1 | ☑ | ☐ | | | |
| 2944105 | 1/8/2024 | 3:40 PM | Floor 01 | 1U-1 Loading Dock - Lavatory Faucet | 2 | ☑ | ☐ | | | 0.48 |
| 2944103 | 1/8/2024 | 3:40 PM | Floor 01 | 114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink | 2 | ☑ | ☐ | 2.5 | | |
| 2944100 | 1/8/2024 | 3:50 PM | Floor 01 | C105-1 Janitor's Closet - Mop/Slop Sink | 1 | ☑ | ☐ | 3.33 | | |
| 2944410 | 1/8/2024 | 4:00 PM | Floor 10 | Suite 1015 GSA Kitchenette Faucet (1000-03) | 2 | ☑ | ☐ | 0.72 | | |

| | | | | | | | | | | |
|---------|-----------|----------|----------|--|---|---|---|------|------|------|
| 2944082 | 1/8/2024 | 4:00 PM | Floor 01 | 1W-2 Women's Restroom South - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944081 | 1/8/2024 | 4:00 PM | Floor 01 | 1W-2 Women's Restroom South - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944070 | 1/8/2024 | 4:10 PM | Floor 01 | 1M-2 Men's Restroom South - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944069 | 1/8/2024 | 4:10 PM | Floor 01 | 1M-2 Men's Restroom South - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944076 | 1/8/2024 | 4:30 PM | Floor 01 | 1W-1 Women's Restroom North - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944075 | 1/8/2024 | 4:30 PM | Floor 01 | 1W-1 Women's Restroom North - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | 0.48 |
| 2944074 | 1/8/2024 | 4:30 PM | Floor 01 | 1W-1 Women's Restroom North - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944064 | 1/8/2024 | 4:50 PM | Floor 01 | 1M-1 Men's Restroom North - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944063 | 1/8/2024 | 4:50 PM | Floor 01 | 1M-1 Men's Restroom North - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | 0.48 |
| 2944062 | 1/8/2024 | 4:50 PM | Floor 01 | 1M-1 Men's Restroom North - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944057 | 1/8/2024 | 5:00 PM | Floor 01 | 108-4 Cafe Prep. - Kitchen Faucet-Large | 1 | ☑ | ☑ | 1.03 | 1.03 | |
| 2944055 | 1/8/2024 | 5:10 PM | Floor LL | CLL09-1 Janitor's Closet - Mop/Slop Sink | 1 | ☑ | ☐ | 2.0 | | |
| 2944045 | 1/8/2024 | 5:30 PM | Floor LL | LLM-1 Men-Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944044 | 1/8/2024 | 5:40 PM | Floor LL | LLM-1 Men-Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944041 | 1/8/2024 | 5:40 PM | Floor LL | LLW-1 Women-Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944399 | 1/8/2024 | 7:19 PM | Floor 10 | 10M-1 Men's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944392 | 1/8/2024 | 7:25 PM | Floor 10 | 10W-2 Women's Restroom West - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | 0.43 |
| 2944391 | 1/8/2024 | 7:25 PM | Floor 10 | 10W-2 Women's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.42 |
| 2944393 | 1/8/2024 | 7:25 PM | Floor 10 | 10W-2 Women's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.42 |
| 2944394 | 1/8/2024 | 7:28 PM | Floor 10 | 10M-2 Men's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944395 | 1/8/2024 | 7:29 PM | Floor 10 | 10M-2 Men's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944380 | 1/8/2024 | 7:59 PM | Floor 10 | C1007-Janitor's Closet-Mop/Slop Sink | 1 | ☑ | ☐ | 2.44 | | |
| 2944407 | 1/8/2024 | 8:10 PM | Floor 10 | 10W-1 Women's Restroom East - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | 0.48 |
| 2944408 | 1/8/2024 | 8:10 PM | Floor 10 | 10W-1 Women's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.54 |
| 2944406 | 1/8/2024 | 8:11 PM | Floor 10 | 10W-1 Women's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.54 |
| 2944378 | 1/8/2024 | 8:20 PM | Floor 09 | 9W-1 Women's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.42 |
| 2944377 | 1/8/2024 | 8:20 PM | Floor 09 | 9W-1 Women's Restroom East - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | 0.42 |
| 2944376 | 1/8/2024 | 8:22 PM | Floor 09 | 9W-1 Women's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944350 | 1/8/2024 | 8:29 PM | Floor 09 | C907-Janitor's Closet-Mop/Slop Sink | 1 | ☑ | ☐ | 2.16 | | |
| 2944369 | 1/8/2024 | 8:30 PM | Floor 09 | 9M-1 Men's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944368 | 1/8/2024 | 8:30 PM | Floor 09 | 9M-1 Men's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944365 | 1/8/2024 | 8:35 PM | Floor 09 | 9M-2 Men's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944364 | 1/8/2024 | 8:35 PM | Floor 09 | 9M-2 Men's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.45 |
| 2944363 | 1/8/2024 | 8:44 PM | Floor 09 | 9W-2 Women's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.42 |
| 2944362 | 1/8/2024 | 8:44 PM | Floor 09 | 9W-2 Women's Restroom West - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | 0.48 |
| 2944361 | 1/8/2024 | 8:44 PM | Floor 09 | 9W-2 Women's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944322 | 1/8/2024 | 8:58 PM | Floor 08 | C807-Janitor's Closet-Mop/Slop Sink | 1 | ☑ | ☐ | 2.88 | | |
| 2944346 | 1/8/2024 | 9:03 PM | Floor 08 | 8W-1 Women's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944347 | 1/8/2024 | 9:07 PM | Floor 08 | 8W-1 Women's Restroom East - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | 0.42 |
| 2944348 | 1/8/2024 | 9:07 PM | Floor 08 | 8W-1 Women's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944338 | 1/8/2024 | 9:10 PM | Floor 08 | 8M-1 Men's Restroom East - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.42 |
| 2944339 | 1/8/2024 | 9:10 PM | Floor 08 | 8M-1 Men's Restroom East - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944334 | 1/8/2024 | 9:18 PM | Floor 08 | 8M-2 Men's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.44 |
| 2944335 | 1/8/2024 | 9:20 PM | Floor 08 | 8M-2 Men's Restroom West - Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.44 |
| 2944332 | 1/8/2024 | 9:20 PM | Floor 08 | 8W-2 Women's Restroom West - Lavatory Faucet-Center | 1 | ☑ | ☐ | | | 0.48 |
| 2944331 | 1/8/2024 | 9:20 PM | Floor 08 | 8W-2 Women's Restroom West - Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.45 |
| 2944261 | 1/9/2024 | 8:02 AM | Floor 06 | Suite 614 Room-Kitchen Faucet (610-03) | 2 | ☑ | ☐ | 1.20 | 1.20 | |
| 2944416 | 1/9/2024 | 8:11 AM | Floor 06 | Suite 608 Kitchen - Faucet | 2 | ☑ | ☐ | 0.85 | 1.50 | |
| 2944290 | 1/9/2024 | 8:17 AM | Floor 06 | Suite 620 Break Room-Kitchen Faucet (608-12) | 2 | ☑ | ☑ | 1.30 | | |
| 2945145 | 1/9/2024 | 8:28 AM | Floor 06 | Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture) | 1 | ☑ | ☐ | | | 0.83 |
| 2944278 | 1/9/2024 | 8:30 AM | Floor 06 | Suite 615 Break Room-Kitchen Faucet (607-06) | 2 | ☑ | ☐ | 1.20 | 1.20 | |
| 2945143 | 1/9/2024 | 8:45 AM | Floor 06 | Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture) | 2 | ☑ | ☐ | | | 0.69 |
| 2944319 | 1/9/2024 | 8:58 AM | Floor 07 | Suite 710 Faucet (710-03) | 2 | ☑ | ☐ | 1.20 | 1.20 | |
| 2944296 | 1/9/2024 | 9:04 AM | Floor 07 | Suite 707-01 Break Room - Faucet (707-2) | 2 | ☑ | ☐ | 1.03 | 0.93 | |
| 2944321 | 1/9/2024 | 9:16 AM | Floor 08 | Suite 810 Kitchen Faucet | 1 | ☑ | ☐ | 1.30 | 1.00 | |
| 2944349 | 1/9/2024 | 9:31 AM | Floor 08 | Suite 808A Break Room Faucet (809-02) | 1 | ☑ | ☐ | 1.20 | 0.78 | |
| 2944355 | 1/9/2024 | 9:47 AM | Floor 09 | Suite 907A Break Room Faucet (907-22) | 2 | ☑ | ☐ | 1.15 | 1.11 | |
| 2944379 | 1/9/2024 | 9:48 AM | Floor 09 | Suite 908 Break Room Faucet (908-15) | 2 | ☑ | ☐ | 1.30 | 1.20 | |
| 2944356 | 1/9/2024 | 10:06 AM | Floor 09 | Suite 910A Faucet (910-05) | 2 | ☑ | ☑ | 0.90 | | |
| 2944409 | 1/9/2024 | 10:08 AM | Floor 10 | Suite 1009C Break Room-Kitchen Faucet (1009-19) | 2 | ☑ | ☐ | 1.30 | 1.20 | |
| 2944259 | 1/9/2024 | 10:23 AM | Floor 05 | Suite 530 Kitchenette - Faucet (509-10) | 2 | ☑ | ☐ | 1.2 | 0.78 | |
| 2944411 | 1/9/2024 | 10:25 AM | Floor 10 | Suite 1008 Break Room-Kitchen Faucet (1009-07) | 2 | ☑ | ☐ | 1.50 | 1.00 | |
| 2944227 | 1/9/2024 | 10:42 AM | Floor 05 | Suite 535 Break Room-Kitchen Faucet (507-36) | 2 | ☑ | ☐ | 1.20 | 1.20 | |
| 2944386 | 1/9/2024 | 10:57 AM | Floor 10 | Suite 1010 Kitchenette Faucet | 2 | ☑ | ☐ | 1.15 | 1.36 | |
| 2944418 | 1/9/2024 | 11:00 AM | Floor 05 | Suite 532 Lactation Room - Faucet | 2 | ☑ | ☐ | 1.20 | 1.00 | |
| 2944385 | 1/9/2024 | 11:22 AM | Floor 10 | Suite 1010 Lavatory Faucet | 1 | ☑ | ☐ | | | 0.48 |
| 2944228 | 1/9/2024 | 12:48 PM | Floor 05 | 540 Faucet (507-26) | 2 | ☑ | ☐ | 1.00 | 1.10 | |
| 2945142 | 1/9/2024 | 1:04 PM | Floor 05 | 540 Faucet (507-26) A (Second fixture) | 2 | ☑ | ☐ | 1.30 | | |
| 2944226 | 1/9/2024 | 1:06 PM | Floor 04 | Suite 540 Kitchenette - Faucet (507-25) | 2 | ☑ | ☐ | 1.11 | 0.96 | |
| 2944247 | 1/9/2024 | 1:22 PM | Floor 05 | Suite 540 Training Lobby - Faucet (507-12) | 2 | ☑ | ☐ | 1.2 | | |
| 2945147 | 1/9/2024 | 1:27 PM | Floor 05 | Suite 540 CBP Open Area Kitchenette - Faucet (507-15) | 2 | ☑ | ☐ | 1.03 | 0.78 | |
| 2944320 | 1/9/2024 | 2:00 PM | Floor 07 | Suite 707-10 Faucet (707-07) | 2 | ☑ | ☐ | 1.20 | 0.90 | |
| 2944224 | 1/10/2024 | 8:03 AM | Floor 04 | Suite 420 Kitchenette - Faucet (NE) - South | 2 | ☑ | ☐ | 1.2 | 1.2 | |
| 2944223 | 1/10/2024 | 8:16 AM | Floor 04 | Suite 416 Kitchenette - Faucet (NE) - North | 2 | ☑ | ☐ | 1.2 | 1.1 | |
| 2944225 | 1/10/2024 | 8:20 AM | Floor 04 | Suite 435 Kitchenette Faucet (SE) | 2 | ☑ | ☐ | 1.04 | 1.03 | |

| | | | | | | | | | | |
|---------|-----------|----------|----------|--|---|---|---|------|------|------|
| 2945144 | 1/10/2024 | 8:25 AM | Floor 04 | Suite 435 Kitchenette Faucet (SE) A (Second fixture) | 2 | ☑ | ☐ | | 0.52 | |
| 2944222 | 1/10/2024 | 8:31 AM | Floor 04 | Suite 415 Kitchenette - Faucet (N) | 2 | ☑ | ☐ | 1.6 | | |
| 2944221 | 1/10/2024 | 8:45 AM | Floor 04 | Suite 410 Kitchenette Faucet (NW) | 2 | ☑ | ☐ | 1.12 | 1.2 | |
| 2944164 | 1/10/2024 | 8:47 AM | Floor 02 | Break Room North West - Kitchen Faucet (207-14) | 2 | ☑ | ☐ | 1.3 | | |
| 2944165 | 1/10/2024 | 9:01 AM | Floor 02 | Break Room North East Kitchen - Faucet (207-39) | 2 | ☑ | ☐ | 1.1 | 1.2 | |
| 2944166 | 1/10/2024 | 9:15 AM | Floor 02 | Break Room South East Kitchen - Faucet (207-49) | 2 | ☑ | ☐ | 1.3 | 1.2 | |
| 2944107 | 1/10/2024 | 9:25 AM | Floor 01 | 123-05 Health Unit - Sink/Faucet | 2 | ☑ | ☐ | 1.2 | 1.2 | 1.11 |
| 2944059 | 1/10/2024 | 9:32 AM | Floor 01 | GSA Suite Kitchenette-Sink/Faucet | 2 | ☑ | ☑ | 1.2 | 1.36 | |
| 2944110 | 1/10/2024 | 9:35 AM | Floor 01 | 123-07 Health Unit-Lavatory Faucet | 2 | ☑ | ☐ | | | 0.48 |
| 2944108 | 1/10/2024 | 9:40 AM | Floor 01 | 123-08 Health Unit-Lavatory Faucet | 2 | ☑ | ☐ | | | 0.48 |
| 2944097 | 1/10/2024 | 9:47 AM | Floor 01 | 128-02 Lactation Room B-Sink/Faucet | 2 | ☑ | ☐ | 1.2 | 1.2 | |
| 2944114 | 1/10/2024 | 9:55 AM | Floor 01 | 126-05 Men-Lavatory Faucet-Left | 2 | ☑ | ☐ | | | 0.48 |
| 2944099 | 1/10/2024 | 10:00 AM | Floor 01 | 128-04 Lactation Room D-Sink/Faucet | 2 | ☑ | ☐ | 1.2 | 1.2 | |
| 2944120 | 1/10/2024 | 10:05 AM | Floor 01 | 126-06 Shower Room - Shower-North-Left | 1 | ☑ | ☐ | | | 2.30 |
| 2944115 | 1/10/2024 | 10:10 AM | Floor 01 | 126-05 Men-Lavatory Faucet-Center | 2 | ☑ | ☐ | | | 0.48 |
| 2944121 | 1/10/2024 | 10:11 AM | Floor 01 | 126-06 Shower Room-Shower-North-Center | 1 | ☑ | ☐ | | | 2.50 |
| 2944122 | 1/10/2024 | 10:12 AM | Floor 01 | 126-06 Shower Room - Shower-North-Right | 1 | ☑ | ☐ | | | 3.00 |
| 2944098 | 1/10/2024 | 10:12 AM | Floor 01 | 128-03 Lactation Room C-Sink/Faucet | 2 | ☑ | ☐ | 1.2 | 1.1 | |
| 2944116 | 1/10/2024 | 10:13 AM | Floor 01 | 126-05 Men-Lavatory Faucet-Right | 2 | ☑ | ☐ | | | |
| 2944123 | 1/10/2024 | 10:13 AM | Floor 01 | 126-06 Shower Room - Shower-South-Left | 1 | ☑ | ☐ | | | 2.14 |
| 2944124 | 1/10/2024 | 10:14 AM | Floor 01 | 126-06 Shower Room-Shower-South-Center | 1 | ☑ | ☐ | | | 2.40 |
| 2944125 | 1/10/2024 | 10:15 AM | Floor 01 | 126-06 Shower Room - Shower-South-Right | 1 | ☑ | ☐ | | | 2.73 |
| 2944127 | 1/10/2024 | 10:16 AM | Floor 01 | 126-02 Women-Lavatory Faucet-Center | 1 | ☑ | ☐ | | | 0.48 |
| 2944096 | 1/10/2024 | 10:29 AM | Floor 01 | 128-01 Lactation Room A-Sink/Faucet | 2 | ☑ | ☐ | 1.2 | 1.2 | |
| 2944422 | 1/10/2024 | 10:44 AM | Floor 01 | 119-02 Mailroom - Faucet | 2 | ☑ | ☐ | 1.7 | 1.7 | |
| 2944126 | 1/10/2024 | 10:45 AM | Floor 01 | 126-02 Women-Lavatory Faucet-Left | 1 | ☑ | ☐ | | | 0.48 |
| 2944128 | 1/10/2024 | 10:48 AM | Floor 01 | 126-02 Women-Lavatory Faucet-Right | 1 | ☑ | ☐ | | | 0.48 |
| 2944132 | 1/10/2024 | 10:50 AM | Floor 01 | 126-03 Women-Shower-1st from L to R | 1 | ☑ | ☐ | | | 2.30 |
| 2944133 | 1/10/2024 | 10:51 AM | Floor 01 | 126-03 Women-Shower-2nd from L to R | 1 | ☑ | ☐ | | | 2.50 |
| 2944134 | 1/10/2024 | 10:52 AM | Floor 01 | 126-03 Women-Shower-3rd from L to R | 1 | ☑ | ☐ | | | 2.50 |
| 2944089 | 1/10/2024 | 10:56 AM | Floor 01 | 119-19 Food Storage Room-Sink/Faucet | 2 | ☑ | ☐ | 1.7 | 1.7 | |
| 2944106 | 1/10/2024 | 11:05 AM | Floor 01 | 113-6 JLL Kitchenette-Kitchen Faucet | 2 | ☑ | ☐ | 2.0 | 2.0 | |
| 2944086 | 1/10/2024 | 11:12 AM | Floor 01 | 119-21 Faucet/Eyewash | 2 | ☑ | ☐ | 1.7 | 1.6 | |
| 2944087 | 1/10/2024 | 11:27 AM | Floor 01 | 119-16A Shower | 2 | ☑ | ☐ | | | 1.20 |
| 2944088 | 1/10/2024 | 11:39 AM | Floor 01 | 119-17 Toilet/Sink Combo | 2 | ☑ | ☐ | | | |
| 2944090 | 1/10/2024 | 11:55 AM | Floor 01 | 119-11 Toilet/Sink Combo | 2 | ☑ | ☐ | | | |
| 2944091 | 1/10/2024 | 12:35 PM | Floor 01 | 119-10 Toilet/Sink Combo | 2 | ☑ | ☐ | | | |
| 2944092 | 1/10/2024 | 12:52 PM | Floor 01 | 119-07 Toilet/Sink Combo-Left | 2 | ☑ | ☐ | | | |
| 2944093 | 1/10/2024 | 1:09 PM | Floor 01 | 119-07 Toilet/Sink Combo-Right | 2 | ☑ | ☐ | | | |
| 2944095 | 1/10/2024 | 1:30 PM | Floor 01 | 119-08 Toilet/Sink Combo-Right | 2 | ☑ | ☐ | | | |
| 2944094 | 1/10/2024 | 1:47 PM | Floor 01 | 119-08 Toilet/Sink Combo-Left | 2 | ☑ | ☐ | | | |
| 2944054 | 1/10/2024 | 3:00 PM | Floor LL | LL15 Break Room-Kitchen Faucet | 2 | ☑ | ☑ | 1.1 | 0.5 | |
| 2944052 | 1/10/2024 | 3:10 PM | Floor LL | LL15 Women's Restroom - Lavatory Faucet | 1 | ☑ | ☐ | | | 0.48 |
| 2944050 | 1/10/2024 | 3:20 PM | Floor LL | LL15 Men's Restroom - Lavatory Faucet | 1 | ☑ | ☐ | | | 0.48 |
| 2944421 | 1/10/2024 | 3:30 PM | Floor LL | Print, Postal Sorting Area Faucet | 2 | ☑ | ☐ | 1.3 | | |
| 2944163 | 1/10/2024 | 4:00 PM | Floor 02 | 234 Kitchen Faucet (209-04) | 2 | ☑ | ☑ | 1.32 | 1.0 | |
| 2944135 | 1/10/2024 | 10:53 AM | Floor 01 | 126-03 Women-Shower-4th from L to R | 1 | ☑ | ☐ | | | 2.80 |

985 Federal Building
Weekly .2 Micron Filter Inspection Exception Report
From 01/07/2024 to 01/12/2024

There is no record of inspection for the fixtures/filters listed below for the planned inspection date. GSA is working with maintenance contractor to ensure all filters are inspected and inspections are logged accordingly.

Outlets w/Filters that are not included in the log

| Planned Date | Asset Number | Publication Description |
|---------------------|---------------------|---------------------------------------|
| 1/8/2024 | 2944040 | LLW-1 Women-Lavatory Faucet-Left |
| 1/9/2024 | 2944419 | Suite. 540 Kitchenette - Faucet |
| 1/9/2024 | 2944260 | Suite 520 Kitchenette Faucet (508-13) |