

Date	Time	Floor	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
11/6/2023	4:37 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	8:00 AM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			3.04
11/6/2023	8:04 AM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			4.65
11/6/2023	8:25 AM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	8:25 AM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.42
11/6/2023	8:28 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/6/2023	8:40 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	8:43 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.68
11/6/2023	8:43 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.61
11/6/2023	8:45 AM	Floor 07	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.66
11/6/2023	9:00 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.60
11/6/2023	9:02 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.66
11/6/2023	9:02 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.64
11/6/2023	9:02 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/6/2023	9:02 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/6/2023	9:30 AM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	9:47 AM	Floor LL	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.42
11/6/2023	10:29 AM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.42
11/6/2023	10:56 AM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	11:01 AM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.78
11/6/2023	11:09 AM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	11:09 AM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/6/2023	11:09 AM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.42
11/6/2023	11:49 AM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			3.52
11/6/2023	1:17 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	1:17 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	1:31 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.42
11/6/2023	1:31 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	1:31 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.42
11/6/2023	2:05 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	2:05 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.3
11/6/2023	2:30 PM	Floor 10	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	2:30 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	2:30 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	3:11 PM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			3.96
11/6/2023	3:30 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	3:30 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	4:00 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	4:00 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	4:00 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	4:23 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	4:23 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	4:23 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	4:37 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	5:28 PM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			3.88
11/6/2023	5:46 PM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	5:46 PM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	6:15 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	6:15 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	6:15 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	6:20 PM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	6:20 PM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/6/2023	8:12 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/6/2023	8:18 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.66
11/6/2023	8:24 PM	Floor 08	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/7/2023	1:00 AM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.66
11/7/2023	1:00 AM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	1:00 AM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input type="checkbox"/>	<input type="checkbox"/>			0.72
11/7/2023	1:00 AM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input type="checkbox"/>	<input type="checkbox"/>			0.66
11/7/2023	2:00 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/7/2023	2:00 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.61
11/7/2023	2:00 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	2:00 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	2:00 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	2:00 AM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.6
11/7/2023	2:00 AM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.64
11/7/2023	2:00 AM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			

Date	Time	Floor	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
11/7/2023	2:00 AM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	2:00 AM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	2:00 AM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.66
11/7/2023	2:00 AM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.6
11/7/2023	2:00 AM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.66
11/7/2023	2:00 AM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.66
11/7/2023	2:00 AM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.6
11/7/2023	2:00 AM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.6
11/7/2023	2:00 AM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/7/2023	2:00 AM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.66
11/7/2023	2:00 AM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/7/2023	2:00 AM	Floor 02	C207 Janitor's Closet-Mop/Slop Sink	1	<input type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	3:00 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.59
11/7/2023	3:00 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.53
11/7/2023	3:00 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/7/2023	3:00 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/7/2023	3:00 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/7/2023	3:00 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.66
11/7/2023	3:00 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/7/2023	3:00 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	3:00 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	3:00 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	8:11 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2.64	0.63	
11/7/2023	8:11 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2.45	0.9	
11/7/2023	8:15 AM	Floor 06	Suite 620 Break Room-Kitchen Faucet (608-12)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.32	1.08	
11/7/2023	8:40 AM	Floor 05	Suite 614 Room-Kitchen Faucet (610-03)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.44	1.36	
11/7/2023	8:59 AM	Floor 06	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.49	0.52	
11/7/2023	9:24 AM	Floor 06	Suite 707-01 Break Room - Faucet (707-2)	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	3.48	1.11	
11/7/2023	9:39 AM	Floor 07	Suite 710 Faucet (710-03)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.12	0.96	
11/7/2023	10:07 AM	Floor 07	Suite 707-10 Faucet (707-07)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.86	0.63	
11/7/2023	10:48 AM	Floor 07	Suite 808A Break Room Faucet (809-02)	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.56	0.63	
11/7/2023	10:49 AM	Floor 08	Suite 810 Kitchen Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.12	1.04	
11/7/2023	11:24 AM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.08	-	
11/7/2023	11:43 AM	Floor 08	Suite 907A Break Room Faucet (907-22)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.08	-	
11/7/2023	11:52 AM	Floor 09	Suite 910A Faucet (910-05)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.16	0.8	
11/7/2023	12:52 PM	Floor 02EC	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			
11/7/2023	1:15 PM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	0.96	
11/7/2023	1:28 PM	Floor 09	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.92	0.92	
11/7/2023	1:35 PM	Floor 10	Suite 1010 Kitchenette Faucet	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1	0.72	
11/7/2023	1:47 PM	Floor 05	Suite 1010 Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/7/2023	2:21 PM	Floor 05	540 Faucet (507-26)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.16	1.04	
11/7/2023	2:32 PM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	2:32 PM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	2:34 PM	Floor 04	540 Faucet (507-26) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.4	0.85	
11/7/2023	2:47 PM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/7/2023	2:48 PM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	2:48 PM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	2:49 PM	Floor 05	Suite 540 Kitchenette - Faucet (507-25)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.3	1.03	
11/7/2023	2:59 PM	Exterior	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	3:07 PM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	3:07 PM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	3:15 PM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.2	1.08	
11/7/2023	3:38 PM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	3:39 PM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	3:39 PM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	4:00 PM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	4:04 PM	Floor 02	1U-1 Loading Dock - Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.54
11/7/2023	4:04 PM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	4:27 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/7/2023	4:27 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	4:41 PM	Floor 10	E201 Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	4:42 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.48
11/7/2023	4:42 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
11/7/2023	1:00 AM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>			0.63
11/8/2023	8:05 AM	Floor 10	Suite 532 Lactation Room - Faucet	2	<input type="checkbox"/>	<input type="checkbox"/>	1.15	1	
11/8/2023	8:09 AM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.24	0.92	
11/8/2023	8:28 AM	Floor 10	Suite 530 Kitchenette - Faucet (509-10)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.28	1.04	

Date	Time	Floor	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
11/8/2023	8:50 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	✓	✓	1.12	0.72	
11/8/2023	9:00 AM	Floor LL	Suite 410 Kitchenette Faucet (NW)	2	✓	☐	1.2	1.2	
11/8/2023	9:00 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	✓	☐			0.69
11/8/2023	9:15 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	✓	☐	1.2	1.1	
11/8/2023	9:29 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	✓	☐	1.2	0.84	
11/8/2023	9:58 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	✓	✓	1.16	0.72	
11/8/2023	10:00 AM	Floor 04	Break Room North West - Kitchen Faucet (207-14)	2	✓	☐	1.2		
11/8/2023	10:11 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	✓	☐	1.28	1.08	
11/8/2023	10:32 AM	Floor 02	GSA Suite Kitchenette-Sink/Faucet	2	✓	☐	1.2	1.32	
11/8/2023	10:40 AM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	✓	☐	1.08	1.07	
11/8/2023	10:45 AM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	✓	☐	1.2	1.2	
11/8/2023	10:57 AM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	✓	☐	1.2	1.1	
11/8/2023	11:11 AM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	✓	☐	1.1	1.1	
11/8/2023	11:29 AM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	✓	☐	1	1	
11/8/2023	11:30 AM	Floor 01	123-05 Health Unit - Sink/Faucet	2	✓	☐	1.08	1.11	1.08
11/8/2023	11:30 AM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	✓	☐			0.54
11/8/2023	11:30 AM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	✓	☐			0.48
11/8/2023	11:42 AM	Floor 01	119-02 Mailroom - Faucet	2	✓	☐	1.8	1.3	
11/8/2023	12:34 PM	Floor 01	119-16A Shower	2	✓	☐	1.4	1.3	
11/8/2023	12:47 PM	Floor 01	119-21 Faucet/Eyewash	2	✓	☐	1.7	0.93	
11/8/2023	1:05 PM	Floor 01	119-17 Toilet/Sink Combo	2	✓	☐			-
11/8/2023	1:30 PM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	✓	☐			0.54
11/8/2023	1:30 PM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	✓	☐			0.54
11/8/2023	1:30 PM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	✓	☐			0.54
11/8/2023	1:30 PM	Floor 01	126-03 Women-Shower-1st from L to R	1	✓	☐	1.42	1.42	
11/8/2023	1:30 PM	Floor 01	126-03 Women-Shower-2nd from L to R	1	✓	☐		2.5	2.5
11/8/2023	1:30 PM	Floor 01	126-03 Women-Shower-3rd from L to R	1	✓	☐	2.3	2.3	
11/8/2023	1:30 PM	Floor 01	126-03 Women-Shower-4th from L to R	1	✓	☐	2.3	2.3	
11/8/2023	1:34 PM	Floor 01	119-11 Toilet/Sink Combo	2	✓	☐			
11/8/2023	1:55 PM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	✓	☐	1.8	1.7	
11/8/2023	2:00 PM	Floor 01	119-08 Toilet/Sink Combo-Left	2	✓	☐			
11/8/2023	2:20 PM	Floor 01	119-08 Toilet/Sink Combo-Right	2	✓	☐			
11/8/2023	2:35 PM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	✓	☐			0.48
11/8/2023	2:35 PM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	✓	☐			0.54
11/8/2023	2:35 PM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	✓	☐			
11/8/2023	2:35 PM	Floor 01	126-06 Shower Room - Shower-North-Left	1	✓	☐	1.42	1.42	
11/8/2023	2:35 PM	Floor 01	126-06 Shower Room-Shower-North-Center	1	✓	☐	1.5	1.5	
11/8/2023	2:35 PM	Floor 01	126-06 Shower Room - Shower-North-Right	1	✓	☐	1.85	1.85	
11/8/2023	2:35 PM	Floor 01	126-06 Shower Room - Shower-South-Left	1	✓	☐	1.07	1.07	
11/8/2023	2:35 PM	Floor 01	126-06 Shower Room - Shower-South-Right	1	✓	☐	1.3	1.3	
11/8/2023	2:36 PM	Floor 01	126-06 Shower Room-Shower-South-Center	1	✓	☐	1.87	1.87	
11/8/2023	4:45 PM	Floor 01	119-07 Toilet/Sink Combo-Right	2	✓	☐			
11/8/2023	5:30 PM	Floor 01	LL15 Men's Restroom - Lavatory Faucet	1	✓	☐			0.48
11/8/2023	5:30 PM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	✓	☐			0.48
11/8/2023	5:30 PM	Floor LL	LL15 Break Room-Kitchen Faucet	2	✓	☐	1.4	n/a	
11/8/2023	5:30 PM	Floor LL	Print, Postal Sorting Area Faucet	2	✓	✓	1.8	n/a	