

Date	Time	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
2/26/2024	12:01 AM	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	12:03 AM	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	12:05 AM	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	12:05 AM	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	12:13 AM	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	12:15 AM	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	12:24 AM	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	12:25 AM	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	12:29 AM	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	12:29 AM	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	12:29 AM	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	12:35 AM	C707-Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>		2.3		
2/26/2024	1:10 AM	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	1:16 AM	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	1:22 AM	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	1:22 AM	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	1:22 AM	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	1:36 AM	C407 Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		2.6		
2/26/2024	1:36 AM	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	1:40 AM	4W-2 Women West-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	1:40 AM	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	1:40 AM	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	1:52 AM	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	1:53 AM	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	1:53 AM	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	1:58 AM	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	1:58 AM	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	2:07 AM	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	2:07 AM	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	2:07 AM	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	2:15 AM	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	2:17 AM	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	2:17 AM	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	2:20 AM	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	2:20 AM	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	2:23 AM	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	2:25 AM	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	2:27 AM	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	2:27 AM	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	2:27 AM	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	2:41 AM	1U-1 Loading Dock - Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	2:50 AM	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		4.8		
2/26/2024	3:00 AM	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	3:00 AM	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	3:06 AM	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	3:06 AM	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.42
2/26/2024	3:06 AM	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	3:18 AM	108-4 Cafe Prep. - Kitchen Faucet-Small	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.5	0.65	1.2	
2/26/2024	3:18 AM	108-4 Cafe Prep. - Kitchen Faucet-Large	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.5	0.65	1.16	
2/26/2024	3:32 AM	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	3:38 AM	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	3:42 AM	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	3:42 AM	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	3:46 AM	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	3:47 AM	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	3:49 AM	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.23	0.92	
2/26/2024	3:49 AM	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	3:49 AM	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	3:49 AM	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	3:56 AM	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	3:56 AM	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	3:59 AM	C607-Janitor's Closet - Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>		2.1		
2/26/2024	3:59 AM	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	3:59 AM	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	3:59 AM	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/26/2024	3:59 AM	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48

Date	Time	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
2/26/2024	3:59 AM	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/26/2024	4:06 AM	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.42
2/26/2024	4:06 AM	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.42
2/26/2024	4:12 AM	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/26/2024	4:17 AM	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/26/2024	4:17 AM	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/26/2024	4:17 AM	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/26/2024	4:21 AM	LLM-1 Men-Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/26/2024	4:22 AM	C507 Janitor's Closet - Mop/Slop Sink	1	☑	☑		2.3		
2/26/2024	4:23 AM	LLM-1 Men-Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/26/2024	4:29 AM	LLW-1 Women-Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/26/2024	4:31 AM	LLW-1 Women-Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/26/2024	5:24 AM	E201 Restroom - Lavatory Faucet	1	☑	☐	0.5			0.42
2/26/2024	10:38 PM	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/26/2024	10:38 PM	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/26/2024	10:38 PM	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/26/2024	10:43 PM	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/26/2024	10:46 PM	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/26/2024	10:53 PM	C1007-Janitor's Closet-Mop/Slop Sink	1	☑	☐		1.9		
2/26/2024	11:03 PM	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/26/2024	11:06 PM	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/26/2024	11:06 PM	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/26/2024	11:09 PM	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/26/2024	11:09 PM	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/26/2024	11:13 PM	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.42
2/26/2024	11:13 PM	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/26/2024	11:14 PM	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/26/2024	11:19 PM	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/26/2024	11:19 PM	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/26/2024	11:21 PM	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.42
2/26/2024	11:24 PM	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.42
2/26/2024	11:28 PM	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/26/2024	11:28 PM	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/26/2024	11:33 PM	C907-Janitor's Closet-Mop/Slop Sink	1	☑	☐		2.0		
2/26/2024	11:42 PM	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/26/2024	11:42 PM	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/26/2024	11:49 PM	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/26/2024	11:50 PM	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/26/2024	11:50 PM	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/26/2024	11:54 PM	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/26/2024	11:58 PM	C807-Janitor's Closet-Mop/Slop Sink	1	☑	☐		3.7		
2/26/2024	11:28 PM	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/26/2024	4:11 AM	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/27/2024	8:00 AM	Suite 615 Break Room-Kitchen Faucet (607-06)	2	☑	☐	1.5	1.2	1.2	
2/27/2024	8:00 AM	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	☑	☐	1.5		0.83	
2/27/2024	8:12 AM	Suite 620 Break Room-Kitchen Faucet (608-12)	2	☑	☐	1.5	1.2	1.2	
2/27/2024	8:12 AM	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	☑	☐	1.5		0.83	
2/27/2024	8:24 AM	Suite 614 Room-Kitchen Faucet (610-03)	2	☑	☐	1.5	1.2	1.2	
2/27/2024	8:36 AM	Suite 608 Kitchen - Faucet	2	☑	☐	1.5	1.2	1.2	
2/27/2024	8:49 AM	Suite 707-01 Break Room - Faucet (707-2)	2	☑	☐	1.5	1.2	1.1	
2/27/2024	9:01 AM	Suite 707-10 Faucet (707-07)	2	☑	☐	1.5	1.2	1	
2/27/2024	9:14 AM	Suite 710 Faucet (710-03)	2	☑	☐	1.5	1.2	1.1	
2/27/2024	9:27 AM	Suite 808A Break Room Faucet (809-02)	1	☑	☐	1.5	1.2	1.0	
2/27/2024	9:40 AM	Suite 810 Kitchen Faucet	1	☑	☐	1.5	1.1	1.1	
2/27/2024	9:55 AM	Suite 908 Break Room Faucet (908-15)	2	☑	☐	1.5	1.2	1.1	
2/27/2024	10:08 AM	Suite 907A Break Room Faucet (907-22)	2	☑	☐	1.5	1.2	1.0	
2/27/2024	10:20 AM	Suite 910A Faucet (910-05)	2	☑	☐	1.5	1.1	1.1	
2/27/2024	10:33 AM	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	☑	☐	1.5	1.2	1.2	
2/27/2024	10:46 AM	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	☑	☐	1.5	1.1	1.2	
2/27/2024	11:00 AM	Suite 1010 Kitchenette Faucet	2	☑	☐	1.5	1.2	1.1	
2/27/2024	11:12 AM	Suite 1010 Lavatory Faucet	1	☑	☐	1.5			0.48
2/27/2024	11:24 AM	Suite 530 Kitchenette - Faucet (509-10)	2	☑	☐	1.5	1.2	1.2	
2/27/2024	11:37 AM	Suite 520 Kitchenette Faucet (508-13)	2	☑	☐	1.5	1	1.1	
2/27/2024	12:50 PM	Suite 532 Lactation Room - Faucet	2	☑	☐	1.5	1.1	1.1	
2/27/2024	1:02 PM	Suite 535 Break Room-Kitchen Faucet (507-36)	2	☑	☐	1.5	1.2	1.2	
2/27/2024	1:15 PM	540 Faucet (507-26) A (Second fixture)	2	☑	☐	1.5	1.3	1.2	

Date	Time	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
2/27/2024	1:30 PM	540 Faucet (507-26)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.1	
2/27/2024	1:45 PM	Suite 540 Kitchenette - Faucet (507-25)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.1	
2/27/2024	2:01 PM	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/27/2024	2:15 PM	Suite 540 Training Lobby - Faucet (507-12)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/28/2024	8:02 AM	Suite 420 Kitchenette - Faucet (NE) - South	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.1	
2/28/2024	8:06 AM	Suite 435 Kitchenette Faucet (SE)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.07		0.96
2/28/2024	8:06 AM	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5			0.56
2/28/2024	8:14 AM	Suite 415 Kitchenette - Faucet (N)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/28/2024	8:26 AM	Suite 410 Kitchenette Faucet (NW)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.1	
2/28/2024	8:39 AM	Break Room North West - Kitchen Faucet (207-14)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.0	
2/28/2024	8:53 AM	Break Room North East Kitchen - Faucet (207-39)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.0	
2/28/2024	8:53 AM	234 Kitchen Faucet (209-04)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.3	1.07	
2/28/2024	9:05 AM	Break Room South East Kitchen - Faucet (207-49)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/28/2024	9:15 AM	123-05 Health Unit - Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			1.15
2/28/2024	9:18 AM	128-01 Lactation Room A-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/28/2024	9:25 AM	123-07 Health Unit-Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/28/2024	9:40 AM	128-04 Lactation Room D-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.1	
2/28/2024	9:45 AM	123-08 Health Unit-Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/28/2024	9:51 AM	128-03 Lactation Room C-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/28/2024	10:03 AM	GSA Suite Kitchenette-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.2	
2/28/2024	10:06 AM	126-02 Women-Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/28/2024	10:14 AM	119-02 Mailroom - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>		1.6	1.3	
2/28/2024	10:16 AM	126-02 Women-Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/28/2024	10:16 AM	126-02 Women-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/28/2024	10:25 AM	119-19 Food Storage Room-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6	1.7	1.6	
2/28/2024	10:37 AM	119-16A Shower	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>				1.2
2/28/2024	10:37 AM	126-03 Women-Shower-1st from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.14
2/28/2024	10:47 AM	126-03 Women-Shower-2nd from L to R	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2			1.2
2/28/2024	10:47 AM	126-03 Women-Shower-3rd from L to R	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2			1.03
2/28/2024	10:49 AM	119-21 Faucet/Eyewash	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>		1.7	1.4	
2/28/2024	10:57 AM	126-03 Women-Shower-4th from L to R	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2			1.76
2/28/2024	11:01 AM	119-17 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/28/2024	11:08 AM	126-05 Men-Lavatory Faucet-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/28/2024	11:08 AM	126-05 Men-Lavatory Faucet-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			
2/28/2024	11:13 AM	119-11 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/28/2024	11:18 AM	126-05 Men-Lavatory Faucet-Center	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/28/2024	11:25 AM	119-10 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/28/2024	12:40 PM	119-07 Toilet/Sink Combo-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/28/2024	12:57 PM	119-07 Toilet/Sink Combo-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/28/2024	1:10 PM	119-08 Toilet/Sink Combo-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/28/2024	1:23 PM	119-08 Toilet/Sink Combo-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/28/2024	1:45 PM	113-6 JLL Kitchenette-Kitchen Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/28/2024	2:29 PM	126-06 Shower Room - Shower-North-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.14
2/28/2024	2:29 PM	126-06 Shower Room-Shower-North-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.3
2/28/2024	2:29 PM	126-06 Shower Room - Shower-North-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.3
2/28/2024	2:39 PM	126-06 Shower Room - Shower-South-Left	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2			1.76
2/28/2024	5:30 PM	Print, Postal Sorting Area Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>		1.66	1.57	
2/28/2024	5:45 PM	LL15 Break Room-Kitchen Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	0.96	0.96	
2/28/2024	6:00 PM	LL15 Men's Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/28/2024	6:18 PM	LL15 Women's Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48

985 Federal Building
Weekly .2 Micron Filter Inspection Exception Report
From 02/25/2024 to 03/02/2024

There is no record of inspection for the fixtures/filters listed below for the planned inspection date. GSA is working with maintenance contractor to ensure all filters are inspected and inspections are logged accordingly.

Outlets w/Filters that are not included in the log

Planned Date	Asset Number	Publication Description
2/26/2024	2944317	7W-1 Women's Restroom East - Lavatory Faucet-Center
2/26/2024	2944309	7M-1 Men's Restroom East - Lavatory Faucet-Right
2/26/2024	2944308	7M-1 Men's Restroom East - Lavatory Faucet-Left
2/26/2024	2944274	6M-2 Men's Restroom West - Lavatory Faucet-Left
2/26/2024	2944214	4M-2 Men's Restroom West - Lavatory Faucet-Left
2/26/2024	2944177	3M-2 Men's Restroom West - Lavatory Faucet-Right
2/26/2024	2944136	C207 Janitor's Closet-Mop/Slop Sink
2/26/2024	2944100	C105-1 Janitor's Closet - Mop/Slop Sink
2/26/2024	2944074	1W-1 Women's Restroom North - Lavatory Faucet-Left
2/26/2024	2944055	CLL09-1 Janitor's Closet - Mop/Slop Sink
2/27/2024	2944419	Suite. 540 Kitchenette - Faucet
2/28/2024	2944223	Suite 416 Kitchenette - Faucet (NE) - North
2/28/2024	2944124	126-06 Shower Room-Shower-South-Center
2/28/2024	2944125	126-06 Shower Room - Shower-South-Right
2/28/2024	2944097	128-02 Lactation Room B-Sink/Faucet