

Date	Time	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
2/5/2024	2:04 AM	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	☑	☐		2.4		
2/5/2024	2:25 AM	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	2:25 AM	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/5/2024	2:30 AM	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/5/2024	2:37 AM	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	2:45 AM	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.42
2/5/2024	2:45 AM	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/5/2024	2:46 AM	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	2:46 AM	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/5/2024	2:46 AM	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/5/2024	2:46 AM	1U-1 Loading Dock - Lavatory Faucet	2	☑	☐	0.5			0.54
2/5/2024	2:51 AM	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/5/2024	2:53 AM	C607-Janitor's Closet - Mop/Slop Sink	1	☑	☐		2.14		
2/5/2024	2:58 AM	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	2:58 AM	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/5/2024	3:00 AM	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	3:00 AM	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/5/2024	3:01 AM	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	3:04 AM	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.42
2/5/2024	3:06 AM	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	3:10 AM	C507 Janitor's Closet - Mop/Slop Sink	1	☑	☐		1.92		
2/5/2024	3:10 AM	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	3:11 AM	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	3:11 AM	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/5/2024	3:11 AM	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/5/2024	3:11 AM	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/5/2024	3:15 AM	108-4 Cafe Prep. - Kitchen Faucet-Large	1	☑	☐	1.5	1.8	1.8	
2/5/2024	3:17 AM	108-4 Cafe Prep. - Kitchen Faucet-Small	1	☑	☐	1.5	1.8	1.8	
2/5/2024	3:23 AM	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/5/2024	3:24 AM	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	3:30 AM	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	☑	☐	1.5	0.68	1.08	
2/5/2024	3:35 AM	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	3:36 AM	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/5/2024	3:41 AM	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	☑	☐		1.8		
2/5/2024	3:52 AM	LLM-1 Men-Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	3:56 AM	LLW-1 Women-Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	4:07 AM	C407 Janitor's Closet-Mop/Slop Sink	1	☑	☐		1.8		
2/5/2024	9:51 AM	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	9:57 AM	C807-Janitor's Closet-Mop/Slop Sink	1	☑	☐		1.9		
2/5/2024	8:16 PM	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/5/2024	8:16 PM	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	8:22 PM	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/5/2024	8:22 PM	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/5/2024	8:22 PM	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	8:50 PM	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/5/2024	8:50 PM	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	8:55 PM	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/5/2024	8:55 PM	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/5/2024	8:55 PM	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	8:56 PM	C1007-Janitor's Closet-Mop/Slop Sink	1	☑	☐		2.2		
2/5/2024	9:04 PM	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	9:06 PM	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/5/2024	9:07 PM	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/5/2024	9:13 PM	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/5/2024	9:15 PM	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	9:16 PM	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	9:16 PM	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/5/2024	9:18 PM	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	9:20 PM	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	☑	☑	0.5			0.18
2/5/2024	9:22 PM	4W-2 Women West-Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	9:23 PM	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/5/2024	9:24 PM	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	☑	☐	0.5			0.48
2/5/2024	9:24 PM	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/5/2024	9:26 PM	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	☑	☐	0.5			0.48
2/5/2024	9:26 PM	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	☑	☐	0.5			0.48
2/5/2024	9:32 PM	C907-Janitor's Closet-Mop/Slop Sink	1	☑	☐		1.9		

Date	Time	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
2/5/2024	9:38 PM	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	9:39 PM	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	9:43 PM	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	9:43 PM	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	9:44 PM	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	9:45 PM	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	9:45 PM	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	9:48 PM	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	9:49 PM	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	9:50 PM	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	9:51 PM	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	10:00 PM	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	10:02 PM	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	10:03 PM	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	10:04 PM	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	10:06 PM	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	10:08 PM	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	10:14 PM	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	10:15 PM	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	10:15 PM	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	10:15 PM	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	10:18 PM	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	10:19 PM	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.42
2/5/2024	10:20 PM	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	10:21 PM	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	10:21 PM	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	10:21 PM	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	10:24 PM	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	10:25 PM	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	10:26 PM	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	10:28 PM	C707-Janitor's Closet-Mop/Slop Sink	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>		2.1		
2/5/2024	10:52 PM	E201 Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	11:10 PM	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	11:11 PM	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	11:13 PM	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	11:44 PM	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	11:45 PM	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	11:47 PM	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.36
2/5/2024	11:48 PM	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	11:49 PM	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/5/2024	2:38 AM	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/6/2024	8:00 AM	Suite 620 Break Room-Kitchen Faucet (608-12)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/6/2024	8:07 AM	Suite 615 Break Room-Kitchen Faucet (607-06)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.11	1.07	
2/6/2024	8:07 AM	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5		0.86	
2/6/2024	8:18 AM	Suite 608 Kitchen - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.0	
2/6/2024	8:30 AM	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5		0.75	
2/6/2024	8:30 AM	Suite 710 Faucet (710-03)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/6/2024	8:41 AM	Suite 707-01 Break Room - Faucet (707-2)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.03	1.11	
2/6/2024	8:41 AM	Suite 707-10 Faucet (707-07)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/6/2024	8:53 AM	Suite 810 Kitchen Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/6/2024	9:04 AM	Suite 808A Break Room Faucet (809-02)	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.0	
2/6/2024	9:11 AM	Suite 910A Faucet (910-05)	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.5	0.71	1.3	
2/6/2024	9:16 AM	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.2	
2/6/2024	9:27 AM	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.1	
2/6/2024	9:41 AM	Suite 530 Kitchenette - Faucet (509-10)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/6/2024	9:49 AM	Suite 908 Break Room Faucet (908-15)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.25	0.93	
2/6/2024	10:06 AM	Suite 907A Break Room Faucet (907-22)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.3	0.93	
2/6/2024	10:29 AM	Suite 614 Room-Kitchen Faucet (610-03)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.3	1.25	
2/6/2024	10:52 AM	540 Faucet (507-26) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.3	1.11	
2/6/2024	10:52 AM	540 Faucet (507-26)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.1	
2/6/2024	11:09 AM	Suite 540 Kitchenette - Faucet (507-25)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.11	1.07	
2/6/2024	11:50 AM	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.07	0.9	
2/6/2024	12:45 PM	Suite 535 Break Room-Kitchen Faucet (507-36)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1	
2/6/2024	1:04 PM	Suite 540 Training Lobby - Faucet (507-12)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	0.85	
2/6/2024	1:06 PM	Suite 532 Lactation Room - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1	
2/6/2024	1:51 PM	Suite 1010 Kitchenette Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.0	

Date	Time	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
2/6/2024	2:13 PM	Suite 1010 Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5			0.48
2/7/2024	8:00 AM	Suite 420 Kitchenette - Faucet (NE) - South	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/7/2024	8:12 AM	Suite 415 Kitchenette - Faucet (N)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/7/2024	8:15 AM	Suite 435 Kitchenette Faucet (SE)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.08	1.08	
2/7/2024	8:20 AM	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5		0.66	
2/7/2024	8:24 AM	Suite 416 Kitchenette - Faucet (NE) - North	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/7/2024	8:36 AM	Break Room North West - Kitchen Faucet (207-14)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1	
2/7/2024	8:48 AM	Break Room North East Kitchen - Faucet (207-39)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.1	
2/7/2024	9:00 AM	Break Room South East Kitchen - Faucet (207-49)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/7/2024	9:00 AM	234 Kitchen Faucet (209-04)	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.12	
2/7/2024	9:14 AM	GSA Suite Kitchenette-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.2	
2/7/2024	9:20 AM	123-05 Health Unit - Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			1.12
2/7/2024	9:24 AM	123-07 Health Unit-Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/7/2024	9:25 AM	128-01 Lactation Room A-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/7/2024	9:35 AM	123-08 Health Unit-Lavatory Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/7/2024	9:36 AM	128-02 Lactation Room B-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.1	1.2	
2/7/2024	9:47 AM	128-04 Lactation Room D-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/7/2024	9:55 AM	126-02 Women-Lavatory Faucet-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/7/2024	9:58 AM	128-03 Lactation Room C-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.2	1.2	
2/7/2024	10:00 AM	126-02 Women-Lavatory Faucet-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/7/2024	10:00 AM	126-05 Men-Lavatory Faucet-Center	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/7/2024	10:05 AM	126-02 Women-Lavatory Faucet-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/7/2024	10:09 AM	119-02 Mailroom - Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>		1.7	0.88	
2/7/2024	10:20 AM	119-19 Food Storage Room-Sink/Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6	1.7	0.84	
2/7/2024	10:25 AM	126-03 Women-Shower-1st from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.5
2/7/2024	10:27 AM	126-03 Women-Shower-2nd from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.5
2/7/2024	10:29 AM	126-03 Women-Shower-3rd from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.3
2/7/2024	10:31 AM	126-03 Women-Shower-4th from L to R	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.5
2/7/2024	10:32 AM	119-21 Faucet/Eyewash	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>		1.7	1.5	
2/7/2024	10:35 AM	126-05 Men-Lavatory Faucet-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/7/2024	10:43 AM	119-16A Shower	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>				1.2
2/7/2024	10:54 AM	119-17 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/7/2024	11:00 AM	126-06 Shower Room - Shower-North-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.3
2/7/2024	11:06 AM	119-11 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/7/2024	11:06 AM	126-06 Shower Room-Shower-North-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.3
2/7/2024	11:10 AM	126-06 Shower Room - Shower-North-Right	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.3
2/7/2024	11:15 AM	126-06 Shower Room - Shower-South-Left	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.3
2/7/2024	11:18 AM	119-10 Toilet/Sink Combo	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/7/2024	11:20 AM	126-06 Shower Room-Shower-South-Center	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2			2.3
2/7/2024	11:30 AM	119-07 Toilet/Sink Combo-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/7/2024	11:50 AM	113-6 JLL Kitchenette-Kitchen Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.5	1.84	2.0	
2/7/2024	12:40 PM	119-07 Toilet/Sink Combo-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/7/2024	12:55 PM	119-08 Toilet/Sink Combo-Right	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/7/2024	1:00 PM	LL15 Men's Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.5			0.48
2/7/2024	1:10 PM	119-08 Toilet/Sink Combo-Left	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1.6			
2/7/2024	1:10 PM	LL15 Women's Restroom - Lavatory Faucet	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0.5			0.38
2/7/2024	1:20 PM	LL15 Break Room-Kitchen Faucet	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1.5	1.08	0.5	
2/7/2024	1:25 PM	Print, Postal Sorting Area Faucet	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>		1.76	1.76	

985 Federal Building
Weekly .2 Micron Filter Inspection Exception Report
From 02/04/2024 to 02/10/2024

There is no record of inspection for the fixtures/filters listed below for the planned inspection date. GSA is working with maintenance contractor to ensure all filters are inspected and inspections are logged accordingly.

Outlets w/Filters that are not included in the log

Planned Date	Asset Number	Publication Description
2/5/2024	2944200	4W-1 Women's Restroom East - Lavatory Faucet-Right
2/5/2024	2944199	4W-1 Women's Restroom East - Lavatory Faucet-Center
2/5/2024	2944198	4W-1 Women's Restroom East - Lavatory Faucet-Left
2/5/2024	2944155	2W-1 Women's Restroom East - Lavatory Faucet-Center
2/5/2024	2944154	2W-1 Women's Restroom East - Lavatory Faucet-Left
2/5/2024	2944136	C207 Janitor's Closet-Mop/Slop Sink
2/5/2024	2944100	C105-1 Janitor's Closet - Mop/Slop Sink
2/5/2024	2944075	1W-1 Women's Restroom North - Lavatory Faucet-Center
2/5/2024	2944074	1W-1 Women's Restroom North - Lavatory Faucet-Left
2/5/2024	2944062	1M-1 Men's Restroom North - Lavatory Faucet-Left
2/5/2024	2944044	LLM-1 Men-Lavatory Faucet-Left
2/5/2024	2944040	LLW-1 Women-Lavatory Faucet-Left
2/6/2024	2944419	Suite. 540 Kitchenette - Faucet
2/6/2024	2944260	Suite 520 Kitchenette Faucet (508-13)
2/7/2024	2944221	Suite 410 Kitchenette Faucet (NW)
2/7/2024	2944164	Break Room North West - Kitchen Faucet (207-14)
2/7/2024	2944116	126-05 Men-Lavatory Faucet-Right
2/7/2024	2944125	126-06 Shower Room - Shower-South-Right