

Color key:

Below established thresholds for legionella, metals, and total coliform/E. coli
Above established thresholds for legionella, metals, and total coliform/E. coli
Positive for legionella, but below the established threshold

Notes:

- [1] U.S. EPA Primary Drinking Water Standards establish action levels for lead and copper as 15 ppb and 1,300 ppb, respectively.
- [2] CDC guidance defines < 1 CFU/mL for potable sources and < 10 CFU/mL for non-potable sources as thresholds for systems where legionella growth appears to be well controlled.
- [3] ppb means parts per billion.
- [4] CFU/mL means Colony Forming Units per milliliter.
- [5] GU/mL means Genomic Units per milliliter.
- [6] ND means Legionella was not detected in the sample analyzed.
- [7] Positive, <LOQ means Legionella was detected, but below the limit of quantification (LOQ). This result is generally considered a very low level of concentration.
- [8] Column headers indicate when samples were pulled pre or post-filter.

985 Michigan Federal Building Water Testing Summary				Biweekly Round 1 (11/7 - 11/8)		Biweekly Round 2 (11/20 - 11/21)		Biweekly Round 3 (12/5 - 12/6)		Biweekly Round 4 (12/19 - 12/20)		Biweekly Round 5 (1/2 - 1/3)		Biweekly Round 6 (1/16 - 1/17)		Biweekly Round 7 (1/30 - 1/31)		Biweekly Round 8 (2/13 - 2/14)		Biweekly Round 9 (2/27 - 2/28)				
Plumbing Outlet Unique Identifier (for publication)	Floor	Analysis	Units	PRE FILTER	POST FILTER	PRE FILTER	POST FILTER	PRE FILTER	POST FILTER	PRE FILTER	POST FILTER	PRE FILTER	POST FILTER	PRE FILTER	POST FILTER	PRE FILTER	POST FILTER	PRE FILTER	POST FILTER	PRE FILTER	POST FILTER			
LL15-1 Meter Room-Water Main Service Line	LL	E.Coli	--				Absent		Absent		Absent		Absent		Absent					Absent	Absent			
LL15-1 Meter Room-Water Main Service Line	LL	Total Coliform	--				Absent		Absent		Absent		Absent		Absent					Absent	Absent			
LL15-1 Meter Room-Water Main Service Line	LL	Lead	ppb		0.49		20		5.4		33		16		0.49	0.57				0	0			
LL15-1 Meter Room-Water Main Service Line	LL	Copper	ppb		2.9		130		21		210		84		9.4	38				70	80			
LL15-1 Meter Room-Water Main Service Line	LL	Legionella Culture	CFU/mL		ND		ND		ND		ND		ND		ND	ND				ND	ND			
LL16 Fire Pump Room-Water Main Service Line	LL	E.Coli	--				Absent		Absent		Absent		Absent		Absent					Absent	Absent			
LL16 Fire Pump Room-Water Main Service Line	LL	Total Coliform	--				Absent		Absent		Absent		Absent		Absent					Absent	Absent			
LL16 Fire Pump Room-Water Main Service Line	LL	Lead	ppb		6.9		4.2		5.3		0.49		0.49		0.49	0.49				21	0			
LL16 Fire Pump Room-Water Main Service Line	LL	Copper	ppb		0.52		37		26		14		31		1.3	3.2				70	40			
LL16 Fire Pump Room-Water Main Service Line	LL	Legionella Culture	CFU/mL		ND		ND		ND		ND		ND		ND	ND				ND	ND			
Print, Postal Sorting Area Faucet	LL	Copper	ppb	300	290	100	290	280	310	470	330	350	380	62	260	360				300	480	430	290	
Print, Postal Sorting Area Faucet	LL	E.Coli	--		Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent				Absent	Absent	Absent	Absent	
Print, Postal Sorting Area Faucet	LL	Lead	ppb	0.49	0.49	0.49	0.49	0.49	0.49	0.66	0.49	0.49	0.49	0.6	0.49	0.89				0	0	0	0	
Print, Postal Sorting Area Faucet	LL	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent				Absent	Absent	Absent	Absent	
Print, Postal Sorting Area Faucet	LL	Legionella Culture	CFU/mL	ND	ND	ND	ND	8.2	ND	710	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
LLW-1 Women-Lavatory Faucet-Left	LL	E.Coli	--																					
LLW-1 Women-Lavatory Faucet-Left	LL	Total Coliform	--																					
LLW-1 Women-Lavatory Faucet-Left	LL	Lead	ppb																					
LLW-1 Women-Lavatory Faucet-Left	LL	Copper	ppb																					
LLW-1 Women-Lavatory Faucet-Left	LL	Legionella Culture	CFU/mL																					
LLW-1 Women-Lavatory Faucet-Right	LL	Legionella Culture	CFU/mL		ND		ND		ND		ND		ND		ND		ND		ND		ND	ND		
LLW-1 Women-Lavatory Faucet-Right	LL	Copper	ppb		350		1900		370		590		350		800		350		650		380		420	520
LLW-1 Women-Lavatory Faucet-Right	LL	E.Coli	--				Absent		Absent		Absent		Absent		Absent		Absent		Absent		Absent		Absent	
LLW-1 Women-Lavatory Faucet-Right	LL	Lead	ppb		0.49		24		1.7		2.1		0.49		2.4		0.49		1.5		0.49		1.2	0.49
LLW-1 Women-Lavatory Faucet-Right	LL	Total Coliform	--				Absent		Absent		Absent		Absent		Absent		Absent		Absent		Absent		Absent	
LLM-1 Men-Lavatory Faucet-Left	LL	Legionella Culture	CFU/mL																					
LLM-1 Men-Lavatory Faucet-Left	LL	Copper	ppb				1400		440															
LLM-1 Men-Lavatory Faucet-Left	LL	E.Coli	--				Absent		Absent															
LLM-1 Men-Lavatory Faucet-Left	LL	Lead	ppb				16		0.49															
LLM-1 Men-Lavatory Faucet-Left	LL	Total Coliform	--				Absent		Absent															
LLM-1 Men-Lavatory Faucet-Right	LL	Legionella Culture	CFU/mL		ND		ND		ND		ND		ND		ND		ND		ND		ND	ND		
LLM-1 Men-Lavatory Faucet-Right	LL	Copper	ppb		450				810		400		780		390		520		410		590		440	560
LLM-1 Men-Lavatory Faucet-Right	LL	E.Coli	--				Absent		Absent		Absent		Absent		Absent		Absent		Absent		Absent		Absent	
LLM-1 Men-Lavatory Faucet-Right	LL	Lead	ppb		0.49				4.2		0.49		3.2		0.49		1.7		0.49		4.2		0.49	0.49
LLM-1 Men-Lavatory Faucet-Right	LL	Total Coliform	--				Absent		Absent		Absent		Absent		Absent		Absent		Absent		Absent		Absent	
LL Corridor North - Drinking Fountain-Left	LL	Legionella Culture	CFU/mL																					
LL Corridor North - Drinking Fountain-Left	LL	Copper	ppb																					
LL Corridor North - Drinking Fountain-Left	LL	E.Coli	--																					

LL Corridor North - Drinking Fountain-Left	LL	Lead	ppb																		
LL Corridor North - Drinking Fountain-Left	LL	Total Coliform	--																		
LL15 Men's Restroom - Lavatory Faucet	LL	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
LL15 Men's Restroom - Lavatory Faucet	LL	Copper	ppb	370	230	1100	210	850	570	1500	650	1500	520	1700	640	1400	1300	1100	1200		
LL15 Men's Restroom - Lavatory Faucet	LL	E.Coli	--		Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		
LL15 Men's Restroom - Lavatory Faucet	LL	Lead	ppb	0.49	2.9	0.49	1.2	0.49	1	0.49	1.4	0.49	1.6	0.49	7.7	9	0	0	0		
LL15 Men's Restroom - Lavatory Faucet	LL	Total Coliform	--		Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		
LL15 Women's Restroom - Lavatory Faucet	LL	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
LL15 Women's Restroom - Lavatory Faucet	LL	Copper	ppb	320	1100	780	1300	760	1000	1500	680	1600	610	1700	1300	1400	1400	1100	1100		
LL15 Women's Restroom - Lavatory Faucet	LL	E.Coli	--		Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		
LL15 Women's Restroom - Lavatory Faucet	LL	Lead	ppb	0.49	5.1	0.59	25	0.49	5.4	0.49	3.7	0.49	2.4	0.49	2.6	4	0	3	0		
LL15 Women's Restroom - Lavatory Faucet	LL	Total Coliform	--		Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		
LL15 Break Room-Kitchen Faucet	LL	E.Coli	--		Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		
LL15 Break Room-Kitchen Faucet	LL	Total Coliform	--		Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		
LL15 Break Room-Kitchen Faucet	LL	Lead	ppb	0.49	14	1.2	2.5	0.49	1.4	0.49	1.3	0.49	0.84	0.49	260	1	0	1	0		
LL15 Break Room-Kitchen Faucet	LL	Copper	ppb	300	320	160	170	360	250	310	140	340	140	310	0.49	150	200	460	230		
LL15 Break Room-Kitchen Faucet	LL	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
CLL09-1 Janitor's Closet - Mop/Slop Sink	LL	Legionella Culture	CFU/mL		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
CLL09-1 Janitor's Closet - Mop/Slop Sink	LL	Copper	ppb	350	140	140	310	160	280	120	220	150	140	93	120	260	120	600	130		
CLL09-1 Janitor's Closet - Mop/Slop Sink	LL	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		
CLL09-1 Janitor's Closet - Mop/Slop Sink	LL	Lead	ppb	3.5	0.64	8.9	11	5.4	43	3.5	0.65	0.49	0.49	2	0.49	3.9	0	0	5	2	
CLL09-1 Janitor's Closet - Mop/Slop Sink	LL	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Present	Absent	Absent	Absent	Absent	Present	Absent	Absent	Absent	Absent	Absent		
108-4 Cafe Prep. - Kitchen Faucet-Large	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
108-4 Cafe Prep. - Kitchen Faucet-Large	1	Copper	ppb	1200	140	1200	140	950	1100	1600	650	1700	430	980	650	1600	890	230	840	200	
108-4 Cafe Prep. - Kitchen Faucet-Large	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	
108-4 Cafe Prep. - Kitchen Faucet-Large	1	Lead	ppb	0.59	0.49	0.49	0.49	0.67	0.49	0.69	0.49	0.62	0.49	0.49	0.49	0.49	0	0	1	0	
108-4 Cafe Prep. - Kitchen Faucet-Large	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	
108-4 Cafe Prep. - Kitchen Faucet-Small	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
108-4 Cafe Prep. - Kitchen Faucet-Small	1	Copper	ppb	850	820	2000	390	890	270	850	690	770	600	590	440	1200	1000	540	970	710	
108-4 Cafe Prep. - Kitchen Faucet-Small	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	
108-4 Cafe Prep. - Kitchen Faucet-Small	1	Lead	ppb	0.49	0.49	1	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.66	0	0	0	0	
108-4 Cafe Prep. - Kitchen Faucet-Small	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	
GSA Suite Kitchenette-Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
GSA Suite Kitchenette-Sink/Faucet	1	Copper	ppb	360	310	310	260	1000	240	500	330	290	270	570	310	700	600	270	160	100	
GSA Suite Kitchenette-Sink/Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	
GSA Suite Kitchenette-Sink/Faucet	1	Lead	ppb	2.1	0.49	0.49	0.49	1.2	0.49	1.4	0.49	0.6	0.49	0.5	0.49	0.5	0	0	0	0	
GSA Suite Kitchenette-Sink/Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	
1 Corridor South - Drinking Fountain-Left	1	Legionella Culture	CFU/mL																		
1 Corridor South - Drinking Fountain-Left	1	Copper	ppb																		
1 Corridor South - Drinking Fountain-Left	1	E.Coli	--																		
1 Corridor South - Drinking Fountain-Left	1	Lead	ppb																		
1 Corridor South - Drinking Fountain-Left	1	Total Coliform	--																		
1M-1 Men's Restroom North - Lavatory Faucet-Left	1	Legionella Culture	CFU/mL																		
1M-1 Men's Restroom North - Lavatory Faucet-Left	1	Copper	ppb																		
1M-1 Men's Restroom North - Lavatory Faucet-Left	1	E.Coli	--																		
1M-1 Men's Restroom North - Lavatory Faucet-Left	1	Lead	ppb																		
1M-1 Men's Restroom North - Lavatory Faucet-Left	1	Total Coliform	--																		
1M-1 Men's Restroom North - Lavatory Faucet-Cen	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	2	ND	ND	ND	1.2	ND	4.4	ND	ND	ND
1M-1 Men's Restroom North - Lavatory Faucet-Cen	1	Copper	ppb	860	370	2100	250	5900	440	2000	480	2100	620	3600	880	1800	25000	770	460	460	
1M-1 Men's Restroom North - Lavatory Faucet-Cen	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	
1M-1 Men's Restroom North - Lavatory Faucet-Cen	1	Lead	ppb	19	0.49	13	0.49	25	0.49	9.2	0.49	9.2	0.49	18	0.49	14	40	0	0	0	
1M-1 Men's Restroom North - Lavatory Faucet-Cen	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	
1M-1 Men's Restroom North - Lavatory Faucet-Righ	1	Legionella Culture	CFU/mL																		
1M-1 Men's Restroom North - Lavatory Faucet-Righ	1	Copper	ppb																		
1M-1 Men's Restroom North - Lavatory Faucet-Righ	1	E.Coli	--																		
1M-1 Men's Restroom North - Lavatory Faucet-Righ	1	Lead	ppb																		
1M-1 Men's Restroom North - Lavatory Faucet-Righ	1	Total Coliform	--																		

1M-2 Men's Restroom South - Lavatory Faucet-Left	1	Legionella Culture	CFU/mL					ND	ND	ND	ND	ND	ND	ND	ND	ND					
1M-2 Men's Restroom South - Lavatory Faucet-Left	1	Copper	ppb					6500	520	550	600	800	810	860	1000	1000					
1M-2 Men's Restroom South - Lavatory Faucet-Left	1	E.Coli	--					Absent	Absent	Absent	Absent	Absent	Absent	Absent							
1M-2 Men's Restroom South - Lavatory Faucet-Left	1	Lead	ppb					43	0.49	3.2	0.49	2.5	0.49	2.6	0.49	8.4					
1M-2 Men's Restroom South - Lavatory Faucet-Left	1	Total Coliform	--					Absent	Absent	Absent	Absent	Absent	Absent	Absent							
1M-2 Men's Restroom South - Lavatory Faucet-Righ	1	Legionella Culture	CFU/mL	ND	ND	0.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			ND	ND	
1M-2 Men's Restroom South - Lavatory Faucet-Righ	1	Copper	ppb	1400	370	1200	330	4700	580	330	700	570	860	350	1200	710		1400	1900	3200	1400
1M-2 Men's Restroom South - Lavatory Faucet-Righ	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent
1M-2 Men's Restroom South - Lavatory Faucet-Righ	1	Lead	ppb	17	0.49	6.3	0.49	18	0.49	2	0.49	1.5	0.49	1.7	0.49	2.4		2	0	2	0
1M-2 Men's Restroom South - Lavatory Faucet-Righ	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent
1W-1 Women's Restroom North - Lavatory Faucet-L	1	Legionella Culture	CFU/mL																		
1W-1 Women's Restroom North - Lavatory Faucet-L	1	Copper	ppb																		
1W-1 Women's Restroom North - Lavatory Faucet-L	1	E.Coli	--																		
1W-1 Women's Restroom North - Lavatory Faucet-L	1	Lead	ppb																		
1W-1 Women's Restroom North - Lavatory Faucet-L	1	Total Coliform	--																		
1W-1 Women's Restroom North - Lavatory Faucet-C	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND					
1W-1 Women's Restroom North - Lavatory Faucet-C	1	Copper	ppb	1500	640	3500	370	2000	550	920	560	1300	780	970	1100	1100					
1W-1 Women's Restroom North - Lavatory Faucet-C	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent						
1W-1 Women's Restroom North - Lavatory Faucet-C	1	Lead	ppb	7.9	0.49	10	0.87	36	0.49	4.4	0.49	7.5	0.49	6.3	0.49	3.4					
1W-1 Women's Restroom North - Lavatory Faucet-C	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent						
1W-1 Women's Restroom North - Lavatory Faucet-F	1	Legionella Culture	CFU/mL																	ND	ND
1W-1 Women's Restroom North - Lavatory Faucet-F	1	Copper	ppb															3900	1200	1200	680
1W-1 Women's Restroom North - Lavatory Faucet-F	1	E.Coli	--															Absent	Absent	Absent	Absent
1W-1 Women's Restroom North - Lavatory Faucet-F	1	Lead	ppb															6	0	0	0
1W-1 Women's Restroom North - Lavatory Faucet-F	1	Total Coliform	--															Absent	Absent	Absent	Absent
1W-2 Women's Restroom South - Lavatory Faucet-I	1	Legionella Culture	CFU/mL					ND	ND	0.4	ND	ND	ND	ND	ND	ND					
1W-2 Women's Restroom South - Lavatory Faucet-I	1	Copper	ppb					510	570	570	660	530	760	830	1200	460					
1W-2 Women's Restroom South - Lavatory Faucet-I	1	E.Coli	--					Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent						
1W-2 Women's Restroom South - Lavatory Faucet-I	1	Lead	ppb					6.7	0.49	1.9	0.49	3.9	0.49	1.4	0.49	4.3					
1W-2 Women's Restroom South - Lavatory Faucet-I	1	Total Coliform	--					Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent						
1W-2 Women's Restroom South - Lavatory Faucet-I	1	Legionella Culture	CFU/mL	ND	ND	0.4	ND	ND	ND	4.8	ND	9.4	ND	ND	ND	ND				2	ND
1W-2 Women's Restroom South - Lavatory Faucet-I	1	Copper	ppb	200	220	750	320	3500	660	500	590	560	840	800	1300	360		360	1800	620	1200
1W-2 Women's Restroom South - Lavatory Faucet-I	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent
1W-2 Women's Restroom South - Lavatory Faucet-I	1	Lead	ppb	0.49	0.49	0.49	0.49	27	0.49	4.1	0.49	5.1	0.49	3.3	0.49	9.4		6	0	1	0
1W-2 Women's Restroom South - Lavatory Faucet-I	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent
119-21 Faucet/Eyewash	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				ND	ND
119-21 Faucet/Eyewash	1	Copper	ppb	280	280	870	530	220	180	510	190	1200	470	330	290	130		390	340	350	50
119-21 Faucet/Eyewash	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent
119-21 Faucet/Eyewash	1	Lead	ppb	0.98	1.6	0.76	0.75	0.65	0.49	6.4	0.49	0.49	1.6	0.49	0.49	0.49		2	1	2	0
119-21 Faucet/Eyewash	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent
119-16A Shower	1	Legionella Culture	CFU/mL					ND	ND	ND	ND	ND	ND	ND	ND	ND					ND
119-16A Shower	1	Copper	ppb																		200
119-16A Shower	1	E.Coli	--					Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent				Absent	Absent	Absent
119-16A Shower	1	Lead	ppb		0.49			0.77	1.5		0.49		1.1		1.3				1		0
119-16A Shower	1	Total Coliform	--					Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent				Absent	Absent	Absent
119-17 Toilet/Sink Combo	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				ND	ND
119-17 Toilet/Sink Combo	1	Copper	ppb	150	230	880	440	1100	600	360	270	1400	770	360	470	150		190	410	190	270
119-17 Toilet/Sink Combo	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent
119-17 Toilet/Sink Combo	1	Lead	ppb	1.1	0.88	0.96	11	2.4	1.3	0.49	0.49	0.67	0.88	0.49	0.49	0.87		0	0	3	0
119-17 Toilet/Sink Combo	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent
119-19 Food Storage Room-Sink/Faucet	1	Legionella Culture	CFU/mL																		
119-19 Food Storage Room-Sink/Faucet	1	Copper	ppb																		
119-19 Food Storage Room-Sink/Faucet	1	E.Coli	--																		
119-19 Food Storage Room-Sink/Faucet	1	Lead	ppb																		
119-19 Food Storage Room-Sink/Faucet	1	Total Coliform	--																		
119-11 Toilet/Sink Combo	1	Legionella Culture	CFU/mL	ND	ND	0.2	ND	ND	ND	ND	ND	2.4	ND	ND	ND	ND		ND	ND	ND	ND
119-11 Toilet/Sink Combo	1	Copper	ppb	62	54	48	36	70	65	60	60	100	62	74	48	42		90	40	590	40

119-11 Toilet/Sink Combo	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
119-11 Toilet/Sink Combo	1	Lead	ppb	0.49	0.64	0.49	0.49	1.2	0.79	0.89	0.49	2.3	0.54	2.3	0.49	0.49	2	0	21	0
119-11 Toilet/Sink Combo	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
119-10 Toilet/Sink Combo	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	0.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
119-10 Toilet/Sink Combo	1	Copper	ppb	340	66	160	59	72	92	72	50	44	89	52	48	42	370	30	80	150
119-10 Toilet/Sink Combo	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
119-10 Toilet/Sink Combo	1	Lead	ppb	21	0.57	8.6	0.49	0.84	1.5	0.49	0.49	0.49	0.98	0.49	0.49	0.49	5	0	1	0
119-10 Toilet/Sink Combo	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
119-07 Toilet/Sink Combo-Left	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
119-07 Toilet/Sink Combo-Left	1	Copper	ppb	790	500	1100	920	1200	960	290	190	1200	780	1000	840	320	90	20	480	130
119-07 Toilet/Sink Combo-Left	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
119-07 Toilet/Sink Combo-Left	1	Lead	ppb	2.4	0.69	2.3	0.6	1.7	0.49	1.6	0.49	0.61	1	0.49	1.1	5.1	0	0	0	0
119-07 Toilet/Sink Combo-Left	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
119-07 Toilet/Sink Combo-Right	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
119-07 Toilet/Sink Combo-Right	1	Copper	ppb	720	720	530	560	1100	820	200	240	1200	610	1100	770	230	60	30	150	40
119-07 Toilet/Sink Combo-Right	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
119-07 Toilet/Sink Combo-Right	1	Lead	ppb	0.49	0.64	0.72	0.49	1.8	1.3	0.49	1	0.97	2.1	2.6	0.67	2.8	2	0	17	0
119-07 Toilet/Sink Combo-Right	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
119-08 Toilet/Sink Combo-Left	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
119-08 Toilet/Sink Combo-Left	1	Copper	ppb	720	710	640	600	1100	750	200	280	1200	480	1100	430	36	80	30	510	40
119-08 Toilet/Sink Combo-Left	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
119-08 Toilet/Sink Combo-Left	1	Lead	ppb	0.49	0.94	6.8	0.49	7.6	0.83	6.3	0.49	1.6	0.62	1.8	0.49	0.49	1	0	0	0
119-08 Toilet/Sink Combo-Left	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
119-08 Toilet/Sink Combo-Right	1	Legionella Culture	CFU/mL	ND	ND	0.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.2	ND	ND	1.2
119-08 Toilet/Sink Combo-Right	1	Copper	ppb	840	740	690	760	1200	820	180	140	1200	770	680	1200	26	90	20	190	40
119-08 Toilet/Sink Combo-Right	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
119-08 Toilet/Sink Combo-Right	1	Lead	ppb	18	0.49	3.5	0.5	2.6	0.77	0.49	0.49	0.89	0.7	0.74	1.3	0.49	0	0	6	0
119-08 Toilet/Sink Combo-Right	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
128-01 Lactation Room A-Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
128-01 Lactation Room A-Sink/Faucet	1	Copper	ppb	160	270	940	480	1100	680	860	360	360	130	530	350	160	400	210	170	160
128-01 Lactation Room A-Sink/Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
128-01 Lactation Room A-Sink/Faucet	1	Lead	ppb	1.1	0.49	0.49	0.49	2.3	0.49	11	0.49	5.2	0.49	1.2	0.49	0.49	3	0	0	0
128-01 Lactation Room A-Sink/Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
128-02 Lactation Room B-Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
128-02 Lactation Room B-Sink/Faucet	1	Copper	ppb	67	400	420	510	490	470	480	370	86	77	230	170	130	460	60	250	70
128-02 Lactation Room B-Sink/Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
128-02 Lactation Room B-Sink/Faucet	1	Lead	ppb	0.49	0.49	1.4	0.49	0.49	0.49	1.8	0.49	0.49	0.49	0.49	0.49	0.49	0	0	2	0
128-02 Lactation Room B-Sink/Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
128-03 Lactation Room C-Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
128-03 Lactation Room C-Sink/Faucet	1	Copper	ppb	200	120	94	300	1600	520	250	330	240	610	120	100	180	170	50	180	90
128-03 Lactation Room C-Sink/Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
128-03 Lactation Room C-Sink/Faucet	1	Lead	ppb	0.79	0.49	0.59	0.49	1	0.49	0.49	0.49	3.7	0.49	0.49	0.49	0.49	1	0	0	0
128-03 Lactation Room C-Sink/Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
128-04 Lactation Room D-Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
128-04 Lactation Room D-Sink/Faucet	1	Copper	ppb	260	120	590	440	100	180	280	190	140	37	95	400	260	40	90	120	40
128-04 Lactation Room D-Sink/Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
128-04 Lactation Room D-Sink/Faucet	1	Lead	ppb	1.5	0.49	1.1	0.49	0.49	0.49	0.57	0.49	1.5	0.49	0.57	0.49	0.49	0	0	0	0
128-04 Lactation Room D-Sink/Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
119-02 Mailroom - Faucet	1	Legionella Culture	CFU/mL																	
119-02 Mailroom - Faucet	1	Copper	ppb																	
119-02 Mailroom - Faucet	1	E.Coli	--																	
119-02 Mailroom - Faucet	1	Lead	ppb																	
119-02 Mailroom - Faucet	1	Total Coliform	--																	
C105-1 Janitor's Closet - Mop/Slop Sink	1	Legionella Culture	CFU/mL									ND	ND			ND	ND	ND	ND	ND
C105-1 Janitor's Closet - Mop/Slop Sink	1	Copper	ppb									730	550			290	130	170	60	350
C105-1 Janitor's Closet - Mop/Slop Sink	1	E.Coli	--									Absent	Absent				Absent	Absent	Absent	Absent
C105-1 Janitor's Closet - Mop/Slop Sink	1	Lead	ppb									0.49	1.2			0.68	2.1	0	0	0

C105-1 Janitor's Closet - Mop/Slop Sink	1	Total Coliform	--									Absent	Absent				Absent	Absent	Absent	Absent	Absent
1 Corridor North - Drinking Fountain-Left	1	Legionella Culture	CFU/mL																		
1 Corridor North - Drinking Fountain-Left	1	Copper	ppb																		
1 Corridor North - Drinking Fountain-Left	1	E.Coli	--																		
1 Corridor North - Drinking Fountain-Left	1	Lead	ppb																		
1 Corridor North - Drinking Fountain-Left	1	Total Coliform	--																		
114-2 Loading Dock - Janitor's Closet - Mop/Slop Si	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
114-2 Loading Dock - Janitor's Closet - Mop/Slop Si	1	Copper	ppb	200	110	140	100	490	150	210	70	63	99	140		95		270	100	100	60
114-2 Loading Dock - Janitor's Closet - Mop/Slop Si	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent		Absent	Absent	Absent	Absent	
114-2 Loading Dock - Janitor's Closet - Mop/Slop Si	1	Lead	ppb	2.7	0.49	6.5	6.2	3.8	0.49	26	3.3	1.1	0.49	1.2		0.49		3	4	0	0
114-2 Loading Dock - Janitor's Closet - Mop/Slop Si	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent		Absent	Absent	Absent	Absent	
1U-1 Loading Dock - Lavatory Faucet	1	Legionella Culture	CFU/mL				ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1U-1 Loading Dock - Lavatory Faucet	1	Copper	ppb				170	410	270	430	210	210	190	470		190		330			
1U-1 Loading Dock - Lavatory Faucet	1	E.Coli	--			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent				Absent				
1U-1 Loading Dock - Lavatory Faucet	1	Lead	ppb				0.49	1.3	0.49	3.6	0.49	0.49	0.49	2		0.49		0.49			
1U-1 Loading Dock - Lavatory Faucet	1	Total Coliform	--			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent				Absent				
113-6 JLL Kitchenette-Kitchen Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
113-6 JLL Kitchenette-Kitchen Faucet	1	Copper	ppb	190	230	940	180	6000	310	330	320	510	320	230	330	1000		950	360	1100	300
113-6 JLL Kitchenette-Kitchen Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
113-6 JLL Kitchenette-Kitchen Faucet	1	Lead	ppb	0.49	0.49	4.6	0.49	2.9	0.49	0.5	0.49	3.5	0.49	0.51	0.49	0.49		0	0	1	0
113-6 JLL Kitchenette-Kitchen Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
123-05 Health Unit - Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
123-05 Health Unit - Sink/Faucet	1	Copper	ppb	860	500	210	210	620	380	560	590	870	530	210	420	250				240	220
123-05 Health Unit - Sink/Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					Absent	Absent
123-05 Health Unit - Sink/Faucet	1	Lead	ppb	19	0.49	0.93	0.49	7.1	0.49	0.49	0.49	1.3	0.49	0.49	0.49	2.4				4	0
123-05 Health Unit - Sink/Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					Absent	Absent
123-08 Health Unit-Lavatory Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
123-08 Health Unit-Lavatory Faucet	1	Copper	ppb	1300	550	840	370	880	1400	700	350	1900	1800	630	1400	1800				2000	1800
123-08 Health Unit-Lavatory Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					Absent	Absent
123-08 Health Unit-Lavatory Faucet	1	Lead	ppb	9.7	0.49	1.8	0.49	0.76	0.49	22	0.49	1.9	0.49	0.49	0.49	0.49				0	0
123-08 Health Unit-Lavatory Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					Absent	Absent
123-07 Health Unit-Lavatory Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
123-07 Health Unit-Lavatory Faucet	1	Copper	ppb	640	750	490	420	520	600	850	1000	840	1100	1300	1900	810				570	910
123-07 Health Unit-Lavatory Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					Absent	Absent
123-07 Health Unit-Lavatory Faucet	1	Lead	ppb	1.5	0.49	1.5	0.49	1.1	0.49	0.97	0.49	0.61	0.49	0.49	0.49	0.94				0	0
123-07 Health Unit-Lavatory Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					Absent	Absent
126-05 Men-Lavatory Faucet-Left	1	Legionella Culture	CFU/mL																		
126-05 Men-Lavatory Faucet-Left	1	Copper	ppb																		
126-05 Men-Lavatory Faucet-Left	1	E.Coli	--																		
126-05 Men-Lavatory Faucet-Left	1	Lead	ppb																		
126-05 Men-Lavatory Faucet-Left	1	Total Coliform	--																		
126-05 Men-Lavatory Faucet-Center	1	Legionella Culture	CFU/mL	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
126-05 Men-Lavatory Faucet-Center	1	Copper	ppb	130	1100	4.1	340	700	440	760	410	1900	820	1200	1300	1800		1200	920	800	650
126-05 Men-Lavatory Faucet-Center	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					Absent	Absent
126-05 Men-Lavatory Faucet-Center	1	Lead	ppb	1.8	1.8	410	0.49	2.9	0.49	3.3	0.49	10	0.59	6.2	0.49	3.3		6	0	19	0
126-05 Men-Lavatory Faucet-Center	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					Absent	Absent
126-05 Men-Lavatory Faucet-Right	1	Legionella Culture	CFU/mL																		
126-05 Men-Lavatory Faucet-Right	1	Copper	ppb																		
126-05 Men-Lavatory Faucet-Right	1	E.Coli	--																		
126-05 Men-Lavatory Faucet-Right	1	Lead	ppb																		
126-05 Men-Lavatory Faucet-Right	1	Total Coliform	--																		
126-06 Shower Room - Shower-North-Left	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
126-06 Shower Room - Shower-North-Left	1	Copper	ppb	1300	520	320	300	440	360	430	440	1100	1000	1100	1100	990		670	460	3100	300
126-06 Shower Room - Shower-North-Left	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					Absent	Absent
126-06 Shower Room - Shower-North-Left	1	Lead	ppb	1.5	0.49	3.1	0.49	0.62	0.49	0.49	0.49	2.3	0.49	0.49	0.49	0.49		0	0	6	0
126-06 Shower Room - Shower-North-Left	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					Absent	Absent

126-06 Shower Room-Shower-North-Center	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
126-06 Shower Room-Shower-North-Center	1	Copper	ppb	1100	510	220	300	390	390	600	430	1200	680	1100	810	1100		120	210	210	600
126-06 Shower Room-Shower-North-Center	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
126-06 Shower Room-Shower-North-Center	1	Lead	ppb	1.6	0.49	0.49	0.49	0.49	0.49	0.61	0.49	0.96	0.49	1.8	0.49	1.4		0	0	0	0
126-06 Shower Room-Shower-North-Center	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
126-06 Shower Room - Shower-North-Right	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
126-06 Shower Room - Shower-North-Right	1	Copper	ppb	1100	550	250	320	470	260	470	260	1200	490	990	1000	1400		190	130	1400	180
126-06 Shower Room - Shower-North-Right	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
126-06 Shower Room - Shower-North-Right	1	Lead	ppb	4.7	0.49	0.49	0.49	0.49	0.49	0.49	0.49	4.4	0.49	0.49	0.49	0.55		0	0	4	0
126-06 Shower Room - Shower-North-Right	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
126-06 Shower Room - Shower-South-Left	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
126-06 Shower Room - Shower-South-Left	1	Copper	ppb	1800	610	1200	340	1500	510	770	450	1300	590	1100	930	1200		190	210	580	210
126-06 Shower Room - Shower-South-Left	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
126-06 Shower Room - Shower-South-Left	1	Lead	ppb	2.6	0.49	1.4	0.49	1.5	0.49	0.98	0.49	0.65	0.49	0.49	0.49	0.85		0	0	0	0
126-06 Shower Room - Shower-South-Left	1	Total Coliform	--	Absent	Absent	Absent	Absent	Present	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
126-06 Shower Room-Shower-South-Center	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
126-06 Shower Room-Shower-South-Center	1	Copper	ppb	590	530	340	290	1000	390	340	370	1300	560	1000	940	1200		210	150	6700	230
126-06 Shower Room-Shower-South-Center	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
126-06 Shower Room-Shower-South-Center	1	Lead	ppb	0.49	0.49	0.52	0.49	1.4	0.49	0.49	0.49	0.7	0.49	0.49	0.49	0.54		0	0	20	0
126-06 Shower Room-Shower-South-Center	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
126-06 Shower Room - Shower-South-Right	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
126-06 Shower Room - Shower-South-Right	1	Copper	ppb	360	400	530	290	550	330	420	390	1200	830	1100	920	1200		200	190	180	200
126-06 Shower Room - Shower-South-Right	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
126-06 Shower Room - Shower-South-Right	1	Lead	ppb	0.82	0.49	2	0.49	1.8	0.49	0.49	0.49	0.49	0.49	0.49	0.69		0	0	0	0	
126-06 Shower Room - Shower-South-Right	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
126-02 Women-Lavatory Faucet-Left	1	Legionella Culture	CFU/mL																		
126-02 Women-Lavatory Faucet-Left	1	Copper	ppb																		
126-02 Women-Lavatory Faucet-Left	1	E.Coli	--																		
126-02 Women-Lavatory Faucet-Left	1	Lead	ppb																		
126-02 Women-Lavatory Faucet-Left	1	Total Coliform	--																		
126-02 Women-Lavatory Faucet-Center	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
126-02 Women-Lavatory Faucet-Center	1	Copper	ppb	960	880	1800	560	660	590	500	630	1700	1000	1400	1100	120		1700	1000	1600	1000
126-02 Women-Lavatory Faucet-Center	1	E.Coli	--	Absent	Absent		Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
126-02 Women-Lavatory Faucet-Center	1	Lead	ppb	0.66	0.58	12	1.1	1.8	0.49	1.6	0.49	15	1.1	2.1	0.9	0.49		2	0	18	0
126-02 Women-Lavatory Faucet-Center	1	Total Coliform	--	Absent	Absent		Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
126-02 Women-Lavatory Faucet-Right	1	Legionella Culture	CFU/mL																		
126-02 Women-Lavatory Faucet-Right	1	Copper	ppb																		
126-02 Women-Lavatory Faucet-Right	1	E.Coli	--																		
126-02 Women-Lavatory Faucet-Right	1	Lead	ppb																		
126-02 Women-Lavatory Faucet-Right	1	Total Coliform	--																		
126-03 Women-Shower-1st from L to R	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
126-03 Women-Shower-1st from L to R	1	Copper	ppb		530	310	290	490	340	450	260	1200	390	1200	770	1500		230	200	220	480
126-03 Women-Shower-1st from L to R	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
126-03 Women-Shower-1st from L to R	1	Lead	ppb		0.49	0.49	0.49	0.49	0.49	0.58	0.49	0.84	0.49	0.62	0.49	0.7		0	0	0	0
126-03 Women-Shower-1st from L to R	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
126-03 Women-Shower-2nd from L to R	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
126-03 Women-Shower-2nd from L to R	1	Copper	ppb	410	570	270	320	570	360	380	250	1200	440	950	960	1100		160	220	260	100
126-03 Women-Shower-2nd from L to R	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
126-03 Women-Shower-2nd from L to R	1	Lead	ppb	0.49	0.49	0.49	0.49	0.49	0.49	0.5	0.49	0.49	0.49	0.49	0.49	0.5		0	0	0	0
126-03 Women-Shower-2nd from L to R	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
126-03 Women-Shower-3rd from L to R	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
126-03 Women-Shower-3rd from L to R	1	Copper	ppb	220	440	220	280	490	360	440	230	1300	430	1200	1100	1200		160	140	150	180
126-03 Women-Shower-3rd from L to R	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
126-03 Women-Shower-3rd from L to R	1	Lead	ppb	2.2	0.49	0.49	0.49	0.9	0.49	0.79	0.49	0.6	0.49	0.89	0.52	0.49		0	0	0	0
126-03 Women-Shower-3rd from L to R	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
126-03 Women-Shower-4th from L to R	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
126-03 Women-Shower-4th from L to R	1	Copper	ppb	100	320	250	240	410	290	280	200	1100	290	870	560	690		140	150	100	80

126-03 Women-Shower-4th from L to R	1	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	
126-03 Women-Shower-4th from L to R	1	Lead	ppb	0.49	0.49	0.49	0.49	0.56	0.49	0.49	0.49	1.2	0.49	0.49	0.49	0.49	0	0	0	0	
126-03 Women-Shower-4th from L to R	1	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	
2 Corridor West - Drinking Fountain-Left	2	Legionella Culture	CFU/mL																		
2 Corridor West - Drinking Fountain-Left	2	Copper	ppb																		
2 Corridor West - Drinking Fountain-Left	2	E.Coli	--																		
2 Corridor West - Drinking Fountain-Left	2	Lead	ppb																		
2 Corridor West - Drinking Fountain-Left	2	Total Coliform	--																		
2W-2 Women's Restroom West - Lavatory Faucet-L	2	Legionella Culture	CFU/mL																		
2W-2 Women's Restroom West - Lavatory Faucet-L	2	Copper	ppb																		
2W-2 Women's Restroom West - Lavatory Faucet-L	2	E.Coli	--																		
2W-2 Women's Restroom West - Lavatory Faucet-L	2	Lead	ppb																		
2W-2 Women's Restroom West - Lavatory Faucet-L	2	Total Coliform	--																		
2W-2 Women's Restroom West - Lavatory Faucet-C	2	Legionella Culture	CFU/mL	ND	ND	1.2	ND	ND	ND	1.2	ND	0.2	ND	ND	ND	ND	ND	ND	ND	ND	
2W-2 Women's Restroom West - Lavatory Faucet-C	2	Copper	ppb	1800	130	390	230	390	290	580	170	400	150	420		230	140	450	210	310	260
2W-2 Women's Restroom West - Lavatory Faucet-C	2	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	Absent	Absent
2W-2 Women's Restroom West - Lavatory Faucet-C	2	Lead	ppb	18	0.49	3.2	0.58	2.9	0.49	4.4	0.49	3.8	0.49	1.8		3.4	0.49	4	0	0	0
2W-2 Women's Restroom West - Lavatory Faucet-C	2	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Present	Absent	Absent	Absent	Absent	Absent
2W-2 Women's Restroom West - Lavatory Faucet-R	2	Legionella Culture	CFU/mL																		
2W-2 Women's Restroom West - Lavatory Faucet-R	2	Copper	ppb																		
2W-2 Women's Restroom West - Lavatory Faucet-R	2	E.Coli	--																		
2W-2 Women's Restroom West - Lavatory Faucet-R	2	Lead	ppb																		
2W-2 Women's Restroom West - Lavatory Faucet-R	2	Total Coliform	--																		
2M-2 Men's Restroom West - Lavatory Faucet-Left	2	Legionella Culture	CFU/mL																		
2M-2 Men's Restroom West - Lavatory Faucet-Left	2	Copper	ppb																		
2M-2 Men's Restroom West - Lavatory Faucet-Left	2	E.Coli	--																		
2M-2 Men's Restroom West - Lavatory Faucet-Left	2	Lead	ppb																		
2M-2 Men's Restroom West - Lavatory Faucet-Left	2	Total Coliform	--																		
2M-2 Men's Restroom West - Lavatory Faucet-Righ	2	Legionella Culture	CFU/mL	6	ND	ND	ND	ND	ND	2.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
2M-2 Men's Restroom West - Lavatory Faucet-Righ	2	Copper	ppb	230	200	380	360	520	320	480	120	350	110	640		340	130	730	100	490	130
2M-2 Men's Restroom West - Lavatory Faucet-Righ	2	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	Absent	Absent
2M-2 Men's Restroom West - Lavatory Faucet-Righ	2	Lead	ppb	4	1.3	2.6	1.1	3.5	0.49	3.7	0.49	3.9	0.49	7.3		6.2	0.49	30	0	6	0
2M-2 Men's Restroom West - Lavatory Faucet-Righ	2	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	Absent	Absent
2W-1 Women's Restroom East - Lavatory Faucet-Le	2	Legionella Culture	CFU/mL																		
2W-1 Women's Restroom East - Lavatory Faucet-Le	2	Copper	ppb																		
2W-1 Women's Restroom East - Lavatory Faucet-Le	2	E.Coli	--																		
2W-1 Women's Restroom East - Lavatory Faucet-Le	2	Lead	ppb																		
2W-1 Women's Restroom East - Lavatory Faucet-Le	2	Total Coliform	--																		
2W-1 Women's Restroom East - Lavatory Faucet-C	2	Legionella Culture	CFU/mL	ND	ND	ND	ND		ND	0.8	ND	1.8	ND	ND	ND	ND	ND			ND	ND
2W-1 Women's Restroom East - Lavatory Faucet-C	2	Copper	ppb	820	140	850	160	420	260	1200	280	420	220	1100		130	160			580	200
2W-1 Women's Restroom East - Lavatory Faucet-C	2	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	Absent	Absent
2W-1 Women's Restroom East - Lavatory Faucet-C	2	Lead	ppb	11	0.87	11	0.94	1.8	0.49	24	0.49	1.7	1	4.7		0.49	0.49			0	0
2W-1 Women's Restroom East - Lavatory Faucet-C	2	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	Absent	Absent
2W-1 Women's Restroom East - Lavatory Faucet-R	2	Legionella Culture	CFU/mL															ND	ND		
2W-1 Women's Restroom East - Lavatory Faucet-R	2	Copper	ppb															710	220		
2W-1 Women's Restroom East - Lavatory Faucet-R	2	E.Coli	--															Absent	Absent		
2W-1 Women's Restroom East - Lavatory Faucet-R	2	Lead	ppb															4	0		
2W-1 Women's Restroom East - Lavatory Faucet-R	2	Total Coliform	--															Absent	Absent		
2M-1 Men's Restroom East - Lavatory Faucet-Left	2	Legionella Culture	CFU/mL																		
2M-1 Men's Restroom East - Lavatory Faucet-Left	2	Copper	ppb																		
2M-1 Men's Restroom East - Lavatory Faucet-Left	2	E.Coli	--																		
2M-1 Men's Restroom East - Lavatory Faucet-Left	2	Lead	ppb																		
2M-1 Men's Restroom East - Lavatory Faucet-Left	2	Total Coliform	--																		
2M-1 Men's Restroom East - Lavatory Faucet-Righ	2	Legionella Culture	CFU/mL	ND	ND	56	ND	ND	ND	0.2	ND	15	ND	ND	ND	ND	ND	2	ND	ND	ND
2M-1 Men's Restroom East - Lavatory Faucet-Righ	2	Copper	ppb	290	140	210	150	680	270	20000	310	560	240	400		750	350	2200	310	2200	360
2M-1 Men's Restroom East - Lavatory Faucet-Righ	2	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	Absent	Absent
2M-1 Men's Restroom East - Lavatory Faucet-Righ	2	Lead	ppb	4	0.49	4	0.49	6.2	0.49	56	0.49	3.3	0.49	3		5.2	0.49	9	0	7	0

2M-1 Men's Restroom East - Lavatory Faucet-Right	2	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	
234 Kitchen Faucet (209-04)	2	Legionella Culture	CFU/mL			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
234 Kitchen Faucet (209-04)	2	Copper	ppb			1300	920	270	210	730	270	1700	1100	240		300	410	330	210	190	220
234 Kitchen Faucet (209-04)	2	E.Coli	--			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent	Absent
234 Kitchen Faucet (209-04)	2	Lead	ppb			1.1	0.49	0.49	0.49	0.49	0.49	0.76	0.49	0.57		0.49	0.49	5	0	0	0
234 Kitchen Faucet (209-04)	2	Total Coliform	--			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent	Absent
Break Room North West - Kitchen Faucet (207-14)	2	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Break Room North West - Kitchen Faucet (207-14)	2	Copper	ppb	1000	780	1400	1100	210	190	510	210	1300	990	140		240	310	320	110	200	160
Break Room North West - Kitchen Faucet (207-14)	2	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent	Absent
Break Room North West - Kitchen Faucet (207-14)	2	Lead	ppb	0.73	0.49	0.55	0.49	0.49	0.49	2.4	0.49	0.49	0.49	0.49		0.49	0.49	0	0	0	0
Break Room North West - Kitchen Faucet (207-14)	2	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent	Absent
Break Room North East Kitchen - Faucet (207-39)	2	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Break Room North East Kitchen - Faucet (207-39)	2	Copper	ppb	2900	140	2100	760	300	360	1600	470	8400	630	190		470	440	510	440	240	320
Break Room North East Kitchen - Faucet (207-39)	2	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent	Absent
Break Room North East Kitchen - Faucet (207-39)	2	Lead	ppb	5	0.49	1.6	0.49	1	0.49	1.7	0.49	8.7	0.49	0.82		0.49	0.49	1	0	0	0
Break Room North East Kitchen - Faucet (207-39)	2	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent	Absent
Break Room South East Kitchen - Faucet (207-49)	2	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Break Room South East Kitchen - Faucet (207-49)	2	Copper	ppb	84	110	960	1100	100	93	600	130	1300	770	39		200	260	560	60	150	50
Break Room South East Kitchen - Faucet (207-49)	2	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent	Absent
Break Room South East Kitchen - Faucet (207-49)	2	Lead	ppb	0.49	0.49	0.55	0.49	1.1	0.49	0.8	0.49	0.56	0.49	0.49		0.49	0.49	14	0	0	0
Break Room South East Kitchen - Faucet (207-49)	2	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent	Absent
E201 Restroom - Lavatory Faucet	2	Legionella Culture	CFU/mL																		
E201 Restroom - Lavatory Faucet	2	Copper	ppb																		
E201 Restroom - Lavatory Faucet	2	E.Coli	--																		
E201 Restroom - Lavatory Faucet	2	Lead	ppb																		
E201 Restroom - Lavatory Faucet	2	Total Coliform	--																		
C207 Janitor's Closet-Mop/Slop Sink	2	Legionella Culture	CFU/mL																		
C207 Janitor's Closet-Mop/Slop Sink	2	Copper	ppb																		
C207 Janitor's Closet-Mop/Slop Sink	2	E.Coli	--																		
C207 Janitor's Closet-Mop/Slop Sink	2	Lead	ppb																		
C207 Janitor's Closet-Mop/Slop Sink	2	Total Coliform	--																		
3W-2 Women's Restroom West - Lavatory Faucet-L	3	Legionella Culture	CFU/mL																		
3W-2 Women's Restroom West - Lavatory Faucet-L	3	Copper	ppb																		
3W-2 Women's Restroom West - Lavatory Faucet-L	3	E.Coli	--																		
3W-2 Women's Restroom West - Lavatory Faucet-L	3	Lead	ppb																		
3W-2 Women's Restroom West - Lavatory Faucet-L	3	Total Coliform	--																		
3W-2 Women's Restroom West - Lavatory Faucet-C	3	Legionella Culture	CFU/mL	ND	ND	ND	ND	0.8	ND	1.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.8
3W-2 Women's Restroom West - Lavatory Faucet-C	3	Copper	ppb	870	110	430	320	310	300	430	230	210	270	280	230	400		290	260	390	310
3W-2 Women's Restroom West - Lavatory Faucet-C	3	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent
3W-2 Women's Restroom West - Lavatory Faucet-C	3	Lead	ppb	64	0.49	8.8	2.9	5.2	1.9	6.4	1.2	4.3	0.53	4.8	0.49	5.5		0	0	0	0
3W-2 Women's Restroom West - Lavatory Faucet-C	3	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent
3W-2 Women's Restroom West - Lavatory Faucet-R	3	Legionella Culture	CFU/mL																		
3W-2 Women's Restroom West - Lavatory Faucet-R	3	Copper	ppb																		
3W-2 Women's Restroom West - Lavatory Faucet-R	3	E.Coli	--																		
3W-2 Women's Restroom West - Lavatory Faucet-R	3	Lead	ppb																		
3W-2 Women's Restroom West - Lavatory Faucet-R	3	Total Coliform	--																		
3M-2 Men's Restroom West - Lavatory Faucet-Right	3	Legionella Culture	CFU/mL	ND	ND	ND	ND	4.4	1.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
3M-2 Men's Restroom West - Lavatory Faucet-Right	3	Copper	ppb	330	340	1400	400	1400	230	300	320	160	150	200	240	780		540	250	670	220
3M-2 Men's Restroom West - Lavatory Faucet-Right	3	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
3M-2 Men's Restroom West - Lavatory Faucet-Right	3	Lead	ppb	5.3	1.5	69	1.3	18	0.69	1.4	0.49	1.6	0.49	2.3	0.49	28		0	1	40	0
3M-2 Men's Restroom West - Lavatory Faucet-Right	3	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Present	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
3M-1 Men's Restroom East - Lavatory Faucet-Left	3	Legionella Culture	CFU/mL																		
3M-1 Men's Restroom East - Lavatory Faucet-Left	3	Copper	ppb																		
3M-1 Men's Restroom East - Lavatory Faucet-Left	3	E.Coli	--																		
3M-1 Men's Restroom East - Lavatory Faucet-Left	3	Lead	ppb																		
3M-1 Men's Restroom East - Lavatory Faucet-Left	3	Total Coliform	--																		
3M-1 Men's Restroom East - Lavatory Faucet-Right	3	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	8.4	0.8	ND	0.4



3M-1 Men's Restroom East - Lavatory Faucet-Right	3	Copper	ppb	210	98	170	130	1000	200	1900	300	570	230	430	240	290		2200	230	690	280
3M-1 Men's Restroom East - Lavatory Faucet-Right	3	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
3M-1 Men's Restroom East - Lavatory Faucet-Right	3	Lead	ppb	26	0.7	5.9	0.99	110	0.98	25	0.59	24	0.49	16	0.65	1.5		32	2	13	0
3M-1 Men's Restroom East - Lavatory Faucet-Right	3	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
3W-1 Women's Restroom East - Lavatory Faucet-Le	3	Legionella Culture	CFU/mL																		
3W-1 Women's Restroom East - Lavatory Faucet-Le	3	Copper	ppb																		
3W-1 Women's Restroom East - Lavatory Faucet-Le	3	E.Coli	--																		
3W-1 Women's Restroom East - Lavatory Faucet-Le	3	Lead	ppb																		
3W-1 Women's Restroom East - Lavatory Faucet-Le	3	Total Coliform	--																		
3W-1 Women's Restroom East - Lavatory Faucet-C	3	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
3W-1 Women's Restroom East - Lavatory Faucet-C	3	Copper	ppb	770	260	500	110	520	170	580	260	710	340	780	330	1000		550	370	380	480
3W-1 Women's Restroom East - Lavatory Faucet-C	3	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
3W-1 Women's Restroom East - Lavatory Faucet-C	3	Lead	ppb	30	1.3	41	0.49	15	0.64	19	0.83	26	0.57	20	0.99	20		8	0	2	0
3W-1 Women's Restroom East - Lavatory Faucet-C	3	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
3W-1 Women's Restroom East - Lavatory Faucet-R	3	Legionella Culture	CFU/mL																		
3W-1 Women's Restroom East - Lavatory Faucet-R	3	Copper	ppb																		
3W-1 Women's Restroom East - Lavatory Faucet-R	3	E.Coli	--																		
3W-1 Women's Restroom East - Lavatory Faucet-R	3	Lead	ppb																		
3W-1 Women's Restroom East - Lavatory Faucet-R	3	Total Coliform	--																		
3 Corridor East - Drinking Fountain-Left	3	Legionella Culture	CFU/mL																		
3 Corridor East - Drinking Fountain-Left	3	Copper	ppb																		
3 Corridor East - Drinking Fountain-Left	3	E.Coli	--																		
3 Corridor East - Drinking Fountain-Left	3	Lead	ppb																		
3 Corridor East - Drinking Fountain-Left	3	Total Coliform	--																		
C307 Janitor's Closet-Mop/Slop Sink	3	Legionella Culture	CFU/mL			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
C307 Janitor's Closet-Mop/Slop Sink	3	Copper	ppb			980	290	790	95	310	770	290	520	90	230	570					
C307 Janitor's Closet-Mop/Slop Sink	3	E.Coli	--			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					
C307 Janitor's Closet-Mop/Slop Sink	3	Lead	ppb			29	5.6	9.2	0.54	2.5	1.6	2.2	1.2	0.64	0.49	0.71					
C307 Janitor's Closet-Mop/Slop Sink	3	Total Coliform	--			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					
4W-1 Women's Restroom East - Lavatory Faucet-Le	4	Legionella Culture	CFU/mL																		
4W-1 Women's Restroom East - Lavatory Faucet-Le	4	Copper	ppb																		
4W-1 Women's Restroom East - Lavatory Faucet-Le	4	E.Coli	--																		
4W-1 Women's Restroom East - Lavatory Faucet-Le	4	Lead	ppb																		
4W-1 Women's Restroom East - Lavatory Faucet-Le	4	Total Coliform	--																		
4W-1 Women's Restroom East - Lavatory Faucet-C	4	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	0.4	ND	ND	ND	ND	ND	ND	2.8	ND	1.2
4W-1 Women's Restroom East - Lavatory Faucet-C	4	Copper	ppb	240	150	1100	110	600	230	700	190	240	220	240		110	180	650	130	410	140
4W-1 Women's Restroom East - Lavatory Faucet-C	4	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
4W-1 Women's Restroom East - Lavatory Faucet-C	4	Lead	ppb	13	1.4	77	0.49	30	0.49	29	0.49	6	0.49	0.49		0.49	0.49	5	0	8	0
4W-1 Women's Restroom East - Lavatory Faucet-C	4	Total Coliform	--	Absent	Absent	Absent	Present	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
4W-1 Women's Restroom East - Lavatory Faucet-R	4	Legionella Culture	CFU/mL																		
4W-1 Women's Restroom East - Lavatory Faucet-R	4	Copper	ppb																		
4W-1 Women's Restroom East - Lavatory Faucet-R	4	E.Coli	--																		
4W-1 Women's Restroom East - Lavatory Faucet-R	4	Lead	ppb																		
4W-1 Women's Restroom East - Lavatory Faucet-R	4	Total Coliform	--																		
4M-1 Men's Restroom East - Lavatory Faucet-Left	4	Legionella Culture	CFU/mL																		
4M-1 Men's Restroom East - Lavatory Faucet-Left	4	Copper	ppb																		
4M-1 Men's Restroom East - Lavatory Faucet-Left	4	E.Coli	--																		
4M-1 Men's Restroom East - Lavatory Faucet-Left	4	Lead	ppb																		
4M-1 Men's Restroom East - Lavatory Faucet-Left	4	Total Coliform	--																		
4M-1 Men's Restroom East - Lavatory Faucet-Right	4	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	2	0.2	ND	ND	ND	ND	ND	0.4	ND	ND
4M-1 Men's Restroom East - Lavatory Faucet-Right	4	Copper	ppb	420	120	410	130	430	200	360	200	380	190	150		380	300	630	240	410	250
4M-1 Men's Restroom East - Lavatory Faucet-Right	4	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
4M-1 Men's Restroom East - Lavatory Faucet-Right	4	Lead	ppb	12	0.89	46	1.4	15	0.49	8.5	0.49	19	0.49	3.7		9	0.49	16	0	11	0
4M-1 Men's Restroom East - Lavatory Faucet-Right	4	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
4W-2 Women's Restroom West - Lavatory Faucet-L	4	Legionella Culture	CFU/mL																		
4W-2 Women's Restroom West - Lavatory Faucet-L	4	Copper	ppb																		
4W-2 Women's Restroom West - Lavatory Faucet-L	4	E.Coli	--																		

4W-2 Women's Restroom West - Lavatory Faucet-L	4	Lead	ppb																	
4W-2 Women's Restroom West - Lavatory Faucet-L	4	Total Coliform	--																	
4W-2 Women's Restroom West - Lavatory Faucet-C	4	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	0.4	ND	ND	ND	ND	ND	ND	0.4	ND	ND	
4W-2 Women's Restroom West - Lavatory Faucet-C	4	Copper	ppb	760	140	1300	110	480	300	200	190	230	220	190	160	100	210	290	280	
4W-2 Women's Restroom West - Lavatory Faucet-C	4	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	
4W-2 Women's Restroom West - Lavatory Faucet-C	4	Lead	ppb	14	0.49	26	1.1	7.5	0.49	5	0.49	3.8	0.49	2.7	4.3	0.49	1	0	0	
4W-2 Women's Restroom West - Lavatory Faucet-C	4	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	
4W-2 Women West-Lavatory Faucet-Right	4	Legionella Culture	CFU/mL																	
4W-2 Women West-Lavatory Faucet-Right	4	Copper	ppb																	
4W-2 Women West-Lavatory Faucet-Right	4	E.Coli	--																	
4W-2 Women West-Lavatory Faucet-Right	4	Lead	ppb																	
4W-2 Women West-Lavatory Faucet-Right	4	Total Coliform	--																	
4M-2 Men's Restroom West - Lavatory Faucet-Left	4	Legionella Culture	CFU/mL																	
4M-2 Men's Restroom West - Lavatory Faucet-Left	4	Copper	ppb																	
4M-2 Men's Restroom West - Lavatory Faucet-Left	4	E.Coli	--																	
4M-2 Men's Restroom West - Lavatory Faucet-Left	4	Lead	ppb																	
4M-2 Men's Restroom West - Lavatory Faucet-Left	4	Total Coliform	--																	
4M-2 Men's Restroom West - Lavatory Faucet-Righ	4	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
4M-2 Men's Restroom West - Lavatory Faucet-Righ	4	Copper	ppb	760	110	480	150	720	250	510	130	620	140	260	280	150	490	120	740	
4M-2 Men's Restroom West - Lavatory Faucet-Righ	4	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	
4M-2 Men's Restroom West - Lavatory Faucet-Righ	4	Lead	ppb	13	0.49	10	0.49	12	0.49	5.6	0.49	6.7	0.49	2.6	3.6	0.49	5	0	7	
4M-2 Men's Restroom West - Lavatory Faucet-Righ	4	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	
4 Corridor West - Drinking Fountain-Left	4	Legionella Culture	CFU/mL																	
4 Corridor West - Drinking Fountain-Left	4	Copper	ppb																	
4 Corridor West - Drinking Fountain-Left	4	E.Coli	--																	
4 Corridor West - Drinking Fountain-Left	4	Lead	ppb																	
4 Corridor West - Drinking Fountain-Left	4	Total Coliform	--																	
Suite 410 Kitchenette Faucet (NW)	4	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Suite 410 Kitchenette Faucet (NW)	4	Copper	ppb	140	180	10000	410	7800	710	1900	560	290	370	460	250	470	190	370		
Suite 410 Kitchenette Faucet (NW)	4	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	
Suite 410 Kitchenette Faucet (NW)	4	Lead	ppb	0.49	0.49	41	0.49	11	0.49	2.3	0.49	0.49	1.1	0.49	0	0	0	0		
Suite 410 Kitchenette Faucet (NW)	4	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	
Suite 415 Kitchenette - Faucet (N)	4	Legionella Culture	CFU/mL			ND	ND			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Suite 415 Kitchenette - Faucet (N)	4	Copper	ppb			200	130	300	240	510	190	730	360	190	50	220	390	240		
Suite 415 Kitchenette - Faucet (N)	4	E.Coli	--			Absent	Absent		Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent		
Suite 415 Kitchenette - Faucet (N)	4	Lead	ppb			0.49	0.49	0.49	0.49	0.49	0.49	0.86	0.49	0.49	0	0	4	0		
Suite 415 Kitchenette - Faucet (N)	4	Total Coliform	--			Absent	Absent		Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent		
Suite 416 Kitchenette - Faucet (NE) - North	4	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND			ND	ND	ND	ND	ND	ND	ND	ND	
Suite 416 Kitchenette - Faucet (NE) - North	4	Copper	ppb	1400	680	3600	820	940	360			860	600	140	320	490	330	310		
Suite 416 Kitchenette - Faucet (NE) - North	4	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent	Absent	Absent	Absent		
Suite 416 Kitchenette - Faucet (NE) - North	4	Lead	ppb	3.3	0.49	2.1	0.49	0.58	0.49			0.57	0.49	0.49	0.53	0.49	0	0		
Suite 416 Kitchenette - Faucet (NE) - North	4	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent	Absent	Absent	Absent		
Suite 420 Kitchenette - Faucet (NE) - South	4	Legionella Culture	CFU/mL	ND	ND	0.8	ND			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Suite 420 Kitchenette - Faucet (NE) - South	4	Copper	ppb	1300	820	980	1100			530	430	1400	990	340	320	530	320	350	220	
Suite 420 Kitchenette - Faucet (NE) - South	4	E.Coli	--	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	210	
Suite 420 Kitchenette - Faucet (NE) - South	4	Lead	ppb	1.6	0.49	1.8	0.49			0.49	0.49	0.49	0.49	0.49	0.72	0.49	2	0	0	
Suite 420 Kitchenette - Faucet (NE) - South	4	Total Coliform	--	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	0	
Suite 435 Kitchenette Faucet (SE)	4	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Suite 435 Kitchenette Faucet (SE)	4	Copper	ppb	210	270	390	930	69	220	390	380	67	260		180	260	1000	310	1100	
Suite 435 Kitchenette Faucet (SE)	4	E.Coli	--	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	610	
Suite 435 Kitchenette Faucet (SE)	4	Lead	ppb	0.49	0.49	3.3	0.49	0.49	0.49	2.2	0.49	0.49	0.49	0.49	0.49	0.49	10	0	0	
Suite 435 Kitchenette Faucet (SE)	4	Total Coliform	--	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	0	
Suite 435 Kitchenette Faucet (SE) A (Second fixture	4	Copper	ppb	190	1100	240	150	3900	290	360	170	60	390		200	230	210	21	800	
Suite 435 Kitchenette Faucet (SE) A (Second fixture	4	E.Coli	--	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	650	
Suite 435 Kitchenette Faucet (SE) A (Second fixture	4	Lead	ppb	0.96	1.3	1.5	0.49	1.7	0.49	0.49	0.49	0.49	0.49		0.53	0.49	0	0	0	
Suite 435 Kitchenette Faucet (SE) A (Second fixture	4	Total Coliform	--	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	0	
Suite 435 Kitchenette Faucet (SE) A (Second fixture	4	Legionella Culture	CFU/mL	ND	ND	34	ND	ND	ND	ND	ND	ND	ND		ND	ND	ND	ND	ND	

C407 Janitor's Closet-Mop/Slop Sink	4	Legionella Culture	CFU/mL			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
C407 Janitor's Closet-Mop/Slop Sink	4	Copper	ppb			130	130	120	65	230	130	240	110	200		140	700				
C407 Janitor's Closet-Mop/Slop Sink	4	E.Coli	--			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent					
C407 Janitor's Closet-Mop/Slop Sink	4	Lead	ppb			2.3	6.5	2.5	1.2	15	0.49	15	0.49	15		1.2	1.2				
C407 Janitor's Closet-Mop/Slop Sink	4	Total Coliform	--			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent					
Suite 540 Kitchenette - Faucet (507-25)	5	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Suite 540 Kitchenette - Faucet (507-25)	5	Copper	ppb	600	380	510	290	300	180	95	190	1200	220	220	330	1700		210	390	710	990
Suite 540 Kitchenette - Faucet (507-25)	5	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	Absent
Suite 540 Kitchenette - Faucet (507-25)	5	Lead	ppb	1.3	0.49	0.68	0.49	0.49	0.49	0.49	0.49	0.61	0.49	0.51	0.49	0.93		0	0	0	0
Suite 540 Kitchenette - Faucet (507-25)	5	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
Suite 535 Break Room-Kitchen Faucet (507-36)	5	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Suite 535 Break Room-Kitchen Faucet (507-36)	5	Copper	ppb	240	310	1100	640	180	170	850	660	450	670	1300	630	2400		630	610	300	490
Suite 535 Break Room-Kitchen Faucet (507-36)	5	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
Suite 535 Break Room-Kitchen Faucet (507-36)	5	Lead	ppb	0.49	0.49	1.6	0.49	0.49	0.49	1.5	0.49	0.49	0.49	1.1	0.49	1.1		4	0	0	0
Suite 535 Break Room-Kitchen Faucet (507-36)	5	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
540 Faucet (507-26)	5	Legionella Culture	CFU/mL	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND	ND			ND	ND	ND	ND
540 Faucet (507-26)	5	Copper	ppb	81	81	470	310	250	160	200	200	200	230	170	310			310	280	960	680
540 Faucet (507-26)	5	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent
540 Faucet (507-26)	5	Lead	ppb	0.49	0.49	0.81	0.49	0.49	0.49	1.1	0.49	0.72	0.49	1.6	0.49			2	0	0	0
540 Faucet (507-26)	5	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent
540 Faucet (507-26) A (Second fixture)	5	E.Coli	--			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent						
540 Faucet (507-26) A (Second fixture)	5	Total Coliform	--			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent						
540 Faucet (507-26) A (Second fixture)	5	Lead	ppb			0.72	0.79	0.7	0.66	0.49	0.49	0.51	0.49	1.3	0.49	1.2					
540 Faucet (507-26) A (Second fixture)	5	Copper	ppb			520	400	350	170	160	190	220	120	190	180	1600					
540 Faucet (507-26) A (Second fixture)	5	Legionella Culture	CFU/mL				ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
5W-2 Women's Restroom West - Lavatory Faucet-L	5	Legionella Culture	CFU/mL																		
5W-2 Women's Restroom West - Lavatory Faucet-L	5	Copper	ppb																		
5W-2 Women's Restroom West - Lavatory Faucet-L	5	E.Coli	--																		
5W-2 Women's Restroom West - Lavatory Faucet-L	5	Lead	ppb																		
5W-2 Women's Restroom West - Lavatory Faucet-L	5	Total Coliform	--																		
5W-2 Women's Restroom West - Lavatory Faucet-C	5	Legionella Culture	CFU/mL		ND	ND	ND	ND	ND	ND	ND	ND	0.4	ND	ND	ND	ND	ND	ND	ND	ND
5W-2 Women's Restroom West - Lavatory Faucet-C	5	Copper	ppb	1400	85	650	120	470	250	200	180	160	160	190	140	240		330	140	130	170
5W-2 Women's Restroom West - Lavatory Faucet-C	5	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent
5W-2 Women's Restroom West - Lavatory Faucet-C	5	Lead	ppb	91	1.2	100	0.49	7.9	0.49	13	0.49	4.9	0.49	9.9	0.49	11		35	0	0	0
5W-2 Women's Restroom West - Lavatory Faucet-C	5	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent
5W-2 Women's Restroom West - Lavatory Faucet-R	5	Legionella Culture	CFU/mL																		
5W-2 Women's Restroom West - Lavatory Faucet-R	5	Copper	ppb																		
5W-2 Women's Restroom West - Lavatory Faucet-R	5	E.Coli	--																		
5W-2 Women's Restroom West - Lavatory Faucet-R	5	Lead	ppb																		
5W-2 Women's Restroom West - Lavatory Faucet-R	5	Total Coliform	--																		
5M-2 Men's Restroom West - Lavatory Faucet-Left	5	Legionella Culture	CFU/mL																		
5M-2 Men's Restroom West - Lavatory Faucet-Left	5	Copper	ppb																		
5M-2 Men's Restroom West - Lavatory Faucet-Left	5	E.Coli	--																		
5M-2 Men's Restroom West - Lavatory Faucet-Left	5	Lead	ppb																		
5M-2 Men's Restroom West - Lavatory Faucet-Left	5	Total Coliform	--																		
5M-2 Men's Restroom West - Lavatory Faucet-Right	5	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.4	ND	0.6	ND	2.8	ND	2.4	ND	2.4
5M-2 Men's Restroom West - Lavatory Faucet-Right	5	Copper	ppb	150	150	480	110	1000	260	330	180	340	170	380	140	640		360	140	630	150
5M-2 Men's Restroom West - Lavatory Faucet-Right	5	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent
5M-2 Men's Restroom West - Lavatory Faucet-Right	5	Lead	ppb	3.3	0.49	41	0.49	30	0.49	4.5	0.49	7.1	0.49	6.8	0.49	9		3	0	0	0
5M-2 Men's Restroom West - Lavatory Faucet-Right	5	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent
5 Corridor West - Drinking Fountain-Right	5	Legionella Culture	CFU/mL																		
5 Corridor West - Drinking Fountain-Right	5	Copper	ppb																		
5 Corridor West - Drinking Fountain-Right	5	E.Coli	--																		
5 Corridor West - Drinking Fountain-Right	5	Lead	ppb																		
5 Corridor West - Drinking Fountain-Right	5	Total Coliform	--																		
Suite 540 Kitchenette - Faucet (507-15)	5	Legionella Culture	CFU/mL	ND	0.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Suite 540 Kitchenette - Faucet (507-15)	5	Copper	ppb	1100	350	290	150	180	250	22	310	64	120	76	290	1000		110	300	880	610

Suite 540 Kitchenette - Faucet (507-15)	5	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
Suite 540 Kitchenette - Faucet (507-15)	5	Lead	ppb	3	0.49	0.88	0.49	0.69	0.49	0.49	0.49	0.55	0.49	0.49	0.49	0.86	1	0	0	0
Suite 540 Kitchenette - Faucet (507-15)	5	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
Suite 540 Training Lobby - Faucet (507-12)	5	Legionella Culture	CFU/mL																	
Suite 540 Training Lobby - Faucet (507-12)	5	Copper	ppb																	
Suite 540 Training Lobby - Faucet (507-12)	5	E.Coli	--																	
Suite 540 Training Lobby - Faucet (507-12)	5	Lead	ppb																	
Suite 540 Training Lobby - Faucet (507-12)	5	Total Coliform	--																	
5M-1 Men's Restroom East - Lavatory Faucet-Left	5	Legionella Culture	CFU/mL																	
5M-1 Men's Restroom East - Lavatory Faucet-Left	5	Copper	ppb																	
5M-1 Men's Restroom East - Lavatory Faucet-Left	5	E.Coli	--																	
5M-1 Men's Restroom East - Lavatory Faucet-Left	5	Lead	ppb																	
5M-1 Men's Restroom East - Lavatory Faucet-Left	5	Total Coliform	--																	
5M-1 Men's Restroom East - Lavatory Faucet-Right	5	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.8	ND
5M-1 Men's Restroom East - Lavatory Faucet-Right	5	Copper	ppb	190	95	140	80	670	190	180	150	610	120	260	83	290	580	90	770	90
5M-1 Men's Restroom East - Lavatory Faucet-Right	5	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
5M-1 Men's Restroom East - Lavatory Faucet-Right	5	Lead	ppb	74	0.97	96	0.51	53	0.49	4.1	0.49	19	0.49	9.6	0.49	7.3	17	0	29	0
5M-1 Men's Restroom East - Lavatory Faucet-Right	5	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
5W-1 Women's Restroom East - Lavatory Faucet-Left	5	Legionella Culture	CFU/mL																	
5W-1 Women's Restroom East - Lavatory Faucet-Left	5	Copper	ppb																	
5W-1 Women's Restroom East - Lavatory Faucet-Left	5	E.Coli	--																	
5W-1 Women's Restroom East - Lavatory Faucet-Left	5	Lead	ppb																	
5W-1 Women's Restroom East - Lavatory Faucet-Left	5	Total Coliform	--																	
5W-1 Women's Restroom East - Lavatory Faucet-C	5	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.4	ND
5W-1 Women's Restroom East - Lavatory Faucet-C	5	Copper	ppb	1200	120	3700	110	770	180	1400	130	230	110	650	89	610	450	70	70	70
5W-1 Women's Restroom East - Lavatory Faucet-C	5	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
5W-1 Women's Restroom East - Lavatory Faucet-C	5	Lead	ppb	98	0.49	210	0.49	32	0.49	24	0.49	6.6	0.49	38	0.49	17	25	0	0	0
5W-1 Women's Restroom East - Lavatory Faucet-C	5	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
5W-1 Women's Restroom East - Lavatory Faucet-R	5	Legionella Culture	CFU/mL																	
5W-1 Women's Restroom East - Lavatory Faucet-R	5	Copper	ppb																	
5W-1 Women's Restroom East - Lavatory Faucet-R	5	E.Coli	--																	
5W-1 Women's Restroom East - Lavatory Faucet-R	5	Lead	ppb																	
5W-1 Women's Restroom East - Lavatory Faucet-R	5	Total Coliform	--																	
Suite 530 Kitchenette - Faucet (509-10)	5	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND			ND	ND	ND	ND	ND	ND	ND	ND	ND
Suite 530 Kitchenette - Faucet (509-10)	5	Copper	ppb	75	97	970	310	470	180		250			590	430	92	560	290	830	820
Suite 530 Kitchenette - Faucet (509-10)	5	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent		Absent			Absent	Absent	Absent	Absent	Absent	Absent	Absent
Suite 530 Kitchenette - Faucet (509-10)	5	Lead	ppb	0.49	0.49	0.93	0.49	1.7	0.49		0.49			0.49	0.49	0.49	0	0	2	0
Suite 530 Kitchenette - Faucet (509-10)	5	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent		Absent			Absent	Absent	Absent	Absent	Absent	Absent	Absent
Suite 520 Kitchenette Faucet (508-13)	5	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND									
Suite 520 Kitchenette Faucet (508-13)	5	Copper	ppb	70	220	4400	240	220	110	620										
Suite 520 Kitchenette Faucet (508-13)	5	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent										
Suite 520 Kitchenette Faucet (508-13)	5	Lead	ppb	0.49	0.49	9.3	0.59	0.49	0.49	0.66										
Suite 520 Kitchenette Faucet (508-13)	5	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent										
Suite 532 Lactation Room - Faucet	5	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Suite 532 Lactation Room - Faucet	5	Copper	ppb	140	360	760	720	230	160	630	220	1200	430	650	540	5400	530	670	220	330
Suite 532 Lactation Room - Faucet	5	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
Suite 532 Lactation Room - Faucet	5	Lead	ppb	0.49	0.49	1.8	0.49	0.49	0.49	1.3	0.49	4.9	0.49	0.49	0.49	3.7	0	0	0	0
Suite 532 Lactation Room - Faucet	5	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
Suite . 540 Kitchenette - Faucet	5	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Suite . 540 Kitchenette - Faucet	5	Copper	ppb	1600	940	1200	390	900	430	1700	860	170	210	230	230	2500				
Suite . 540 Kitchenette - Faucet	5	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent				
Suite . 540 Kitchenette - Faucet	5	Lead	ppb	2.2	0.49	1.2	0.49	0.89	0.49	0.49	0.49	0.49	0.49	0.49	0.49	1.6				
Suite . 540 Kitchenette - Faucet	5	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent				
C507 Janitor's Closet - Mop/Slop Sink	5	Legionella Culture	CFU/mL			ND	ND	ND	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND	ND
C507 Janitor's Closet - Mop/Slop Sink	5	Copper	ppb			190	220	100	75	110	120	64	70	160	50	280				
C507 Janitor's Closet - Mop/Slop Sink	5	E.Coli	--			Absent	Absent			Absent	Absent	Absent	Absent	Absent	Absent	Absent				
C507 Janitor's Closet - Mop/Slop Sink	5	Lead	ppb			4.1	0.68	1.5	1.6	2.2	1.1	3	0.49	17	0.49	3				

C507 Janitor's Closet - Mop/Slop Sink	5	Total Coliform	--			Absent	Absent			Absent	Absent	Absent	Absent	Absent	Absent	Absent						
Suite 614 Room-Kitchen Faucet (610-03)	6	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
Suite 614 Room-Kitchen Faucet (610-03)	6	Copper	ppb	280	210	160	110	120	94	250	260	110	69	160	850	890		100	160	1300	410	
Suite 614 Room-Kitchen Faucet (610-03)	6	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
Suite 614 Room-Kitchen Faucet (610-03)	6	Lead	ppb	2.1	0.49	0.49	0.49	1.2	0.49	0.86	0.49	0.94	0.49	0.69	0.49	0.75		0	0	4	0	
Suite 614 Room-Kitchen Faucet (610-03)	6	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
C607-Janitor's Closet - Mop/Slop Sink	6	Legionella Culture	CFU/mL			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND					
C607-Janitor's Closet - Mop/Slop Sink	6	Copper	ppb			300	370	45	60	180	360	280	260	600	200	370						
C607-Janitor's Closet - Mop/Slop Sink	6	E.Coli	--			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent						
C607-Janitor's Closet - Mop/Slop Sink	6	Lead	ppb			3.9	2.2	1.2	1.1	8.5	0.97	14	0.98	31	40	2.9						
C607-Janitor's Closet - Mop/Slop Sink	6	Total Coliform	--			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent						
6 Corridor West - Drinking Fountain-Left	6	Legionella Culture	CFU/mL																			
6 Corridor West - Drinking Fountain-Left	6	Copper	ppb																			
6 Corridor West - Drinking Fountain-Left	6	E.Coli	--																			
6 Corridor West - Drinking Fountain-Left	6	Lead	ppb																			
6 Corridor West - Drinking Fountain-Left	6	Total Coliform	--																			
6W-2 Women's Restroom West - Lavatory Faucet-L	6	Legionella Culture	CFU/mL																			
6W-2 Women's Restroom West - Lavatory Faucet-L	6	Copper	ppb																			
6W-2 Women's Restroom West - Lavatory Faucet-L	6	E.Coli	--																			
6W-2 Women's Restroom West - Lavatory Faucet-L	6	Lead	ppb																			
6W-2 Women's Restroom West - Lavatory Faucet-L	6	Total Coliform	--																			
6W-2 Women's Restroom West - Lavatory Faucet-C	6	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND		ND	ND	ND	0.4	ND	ND		2.4	ND	0.4	ND
6W-2 Women's Restroom West - Lavatory Faucet-C	6	Copper	ppb	440	140	410	140	730	150	940	230	1500	300	690	330	840		930	410	650	400	
6W-2 Women's Restroom West - Lavatory Faucet-C	6	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
6W-2 Women's Restroom West - Lavatory Faucet-C	6	Lead	ppb	53	0.74	21	0.79	26	0.49	7.6	0.49	32	0.49	9.9	0.49	11		5	0	1	0	
6W-2 Women's Restroom West - Lavatory Faucet-C	6	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
6W-2 Women's Restroom West - Lavatory Faucet-R	6	Legionella Culture	CFU/mL																			
6W-2 Women's Restroom West - Lavatory Faucet-R	6	Copper	ppb																			
6W-2 Women's Restroom West - Lavatory Faucet-R	6	E.Coli	--																			
6W-2 Women's Restroom West - Lavatory Faucet-R	6	Lead	ppb																			
6W-2 Women's Restroom West - Lavatory Faucet-R	6	Total Coliform	--																			
6M-2 Men's Restroom West - Lavatory Faucet-Left	6	Legionella Culture	CFU/mL																			
6M-2 Men's Restroom West - Lavatory Faucet-Left	6	Copper	ppb																			
6M-2 Men's Restroom West - Lavatory Faucet-Left	6	E.Coli	--																			
6M-2 Men's Restroom West - Lavatory Faucet-Left	6	Lead	ppb																			
6M-2 Men's Restroom West - Lavatory Faucet-Left	6	Total Coliform	--																			
6M-2 Men's Restroom West - Lavatory Faucet-Right	6	Legionella Culture	CFU/mL	2	ND	ND	ND	ND	ND	ND		ND	ND	ND	ND	ND	ND		0.8	ND	0.4	ND
6M-2 Men's Restroom West - Lavatory Faucet-Right	6	Copper	ppb	160	270	1400	180	670	140	400	260	2900	290	400	300	840		950	400	1000	370	
6M-2 Men's Restroom West - Lavatory Faucet-Right	6	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
6M-2 Men's Restroom West - Lavatory Faucet-Right	6	Lead	ppb	10	0.82	100	0.49	15	0.49	2.3	0.49	20	0.49	5.1	0.49	8.6		19	0	13	0	
6M-2 Men's Restroom West - Lavatory Faucet-Right	6	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
Suite 615 Break Room-Kitchen Faucet (607-06)	6	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND			ND	ND	ND	ND	ND	ND				ND	ND
Suite 615 Break Room-Kitchen Faucet (607-06)	6	Copper	ppb	150	120	690	200	180	130			220	210	250	180	60					1300	280
Suite 615 Break Room-Kitchen Faucet (607-06)	6	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					Absent	Absent
Suite 615 Break Room-Kitchen Faucet (607-06)	6	Lead	ppb	4.2	0.49	4.9	0.49	1.3	0.49	0.49	0.49	4.4	0.49	4.4	0.49	23					23	0
Suite 615 Break Room-Kitchen Faucet (607-06)	6	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					Absent	Absent
Suite 615 Break Room-Kitchen Faucet (607-06A) A	6	Copper	ppb	200	170	200	99	470	98			120	140	300	110	55					90	80
Suite 615 Break Room-Kitchen Faucet (607-06A) A	6	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					Absent	Absent
Suite 615 Break Room-Kitchen Faucet (607-06A) A	6	Lead	ppb	1.3	0.49	0.83	0.57	1.3	0.49	2.6	0.49	2.6	0.49	2.6	0.49	0.49					0	0
Suite 615 Break Room-Kitchen Faucet (607-06A) A	6	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					Absent	Absent
Suite 615 Break Room-Kitchen Faucet (607-06A) A	6	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND			ND	ND	ND	ND	ND	ND				ND	ND
6M-1 Men's Restroom East - Lavatory Faucet-Left	6	Legionella Culture	CFU/mL																		ND	ND
6M-1 Men's Restroom East - Lavatory Faucet-Left	6	Copper	ppb																		2300	250
6M-1 Men's Restroom East - Lavatory Faucet-Left	6	E.Coli	--																		Absent	Absent
6M-1 Men's Restroom East - Lavatory Faucet-Left	6	Lead	ppb																		91	0
6M-1 Men's Restroom East - Lavatory Faucet-Left	6	Total Coliform	--																		Absent	Absent
6M-1 Men's Restroom East - Lavatory Faucet-Right	6	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND			ND	ND	ND	ND	ND	ND		20	ND	ND	

6M-1 Men's Restroom East - Lavatory Faucet-Right	6	Copper	ppb	1700	100	580	160	510	140	610	320	710	290	510	260	610		920	360		
6M-1 Men's Restroom East - Lavatory Faucet-Right	6	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent		
6M-1 Men's Restroom East - Lavatory Faucet-Right	6	Lead	ppb	44	0.49	7.7	0.49	8.8	0.49	17	0.49	8.2	0.49	5.2	0.49	4.2		12	0		
6M-1 Men's Restroom East - Lavatory Faucet-Right	6	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent		
6W-1 Women's Restroom East - Lavatory Faucet-Left	6	Legionella Culture	CFU/mL																		
6W-1 Women's Restroom East - Lavatory Faucet-Left	6	Copper	ppb																		
6W-1 Women's Restroom East - Lavatory Faucet-Left	6	E.Coli	--																		
6W-1 Women's Restroom East - Lavatory Faucet-Left	6	Lead	ppb																		
6W-1 Women's Restroom East - Lavatory Faucet-Left	6	Total Coliform	--																		
6W-1 Women's Restroom East - Lavatory Faucet-Left	6	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
6W-1 Women's Restroom East - Lavatory Faucet-Left	6	Copper	ppb	950	100	420	150	630	160	610	290	1100	320	680	290	610		840	340	480	210
6W-1 Women's Restroom East - Lavatory Faucet-Left	6	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
6W-1 Women's Restroom East - Lavatory Faucet-Left	6	Lead	ppb	37	0.57	6.1	0.6	14	0.49	3.7	0.49	15	0.49	7.2	0.49	6.9		7	0	6	0
6W-1 Women's Restroom East - Lavatory Faucet-Left	6	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
6W-1 Women's Restroom East - Lavatory Faucet-Right	6	Legionella Culture	CFU/mL																		
6W-1 Women's Restroom East - Lavatory Faucet-Right	6	Copper	ppb																		
6W-1 Women's Restroom East - Lavatory Faucet-Right	6	E.Coli	--																		
6W-1 Women's Restroom East - Lavatory Faucet-Right	6	Lead	ppb																		
6W-1 Women's Restroom East - Lavatory Faucet-Right	6	Total Coliform	--																		
Suite 620 Break Room-Kitchen Faucet (608-12)	6	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Suite 620 Break Room-Kitchen Faucet (608-12)	6	Copper	ppb	520	240	580	240	960	310	690	150	270	110	1500	500	330		250	1100	720	580
Suite 620 Break Room-Kitchen Faucet (608-12)	6	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
Suite 620 Break Room-Kitchen Faucet (608-12)	6	Lead	ppb	2.8	0.49	5.5	0.49	3.6	0.49	3	0.49	0.49	0.49	3.2	0.49	0.49		2	0	0	0
Suite 620 Break Room-Kitchen Faucet (608-12)	6	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
Suite 620 Break Room Kitchen - Faucet (608-12A)	6	Copper	ppb	660	1800	400	580	510	380			290	400	610	290	390		400	450	740	240
Suite 620 Break Room Kitchen - Faucet (608-12A)	6	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
Suite 620 Break Room Kitchen - Faucet (608-12A)	6	Lead	ppb	4.8	0.91	3.6	0.49	1.5	0.49			0.49	0.49	0.49	0.49	0.49		2	0	1	0
Suite 620 Break Room Kitchen - Faucet (608-12A)	6	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
Suite 620 Break Room Kitchen - Faucet (608-12A)	6	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Suite 608 Kitchen - Faucet	6	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Suite 608 Kitchen - Faucet	6	Copper	ppb	200	160	1600	1500	200	100	1800	1100	290	360	310	260	620		1400	860	1800	510
Suite 608 Kitchen - Faucet	6	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
Suite 608 Kitchen - Faucet	6	Lead	ppb	0.64	0.49	0.49	0.49	1.1	0.49	1.3	0.49	0.49	0.49	0.49	0.49	4.3		2	0	26	0
Suite 608 Kitchen - Faucet	6	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
C707-Janitor's Closet-Mop/Slop Sink	7	Legionella Culture	CFU/mL			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
C707-Janitor's Closet-Mop/Slop Sink	7	Copper	ppb			410	500	440	90	420	230	190	130	180	160	380					
C707-Janitor's Closet-Mop/Slop Sink	7	E.Coli	--			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					
C707-Janitor's Closet-Mop/Slop Sink	7	Lead	ppb			1.2	3	6.4	0.59	19	0.6	4.8	0.64	5.5	1.3	2.4					
C707-Janitor's Closet-Mop/Slop Sink	7	Total Coliform	--			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					
7 Corridor East - Drinking Fountain-Left	7	Legionella Culture	CFU/mL																		
7 Corridor East - Drinking Fountain-Left	7	Copper	ppb																		
7 Corridor East - Drinking Fountain-Left	7	E.Coli	--																		
7 Corridor East - Drinking Fountain-Left	7	Lead	ppb																		
7 Corridor East - Drinking Fountain-Left	7	Total Coliform	--																		
Suite 707-01 Break Room - Faucet (707-2)	7	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Suite 707-01 Break Room - Faucet (707-2)	7	Copper	ppb	470	110	130	97	130	160	360	370	860	520	220	370	84		330	420	330	320
Suite 707-01 Break Room - Faucet (707-2)	7	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
Suite 707-01 Break Room - Faucet (707-2)	7	Lead	ppb	2.8	0.49	0.57	0.49	0.49	0.49	0.49	0.49	1.6	0.49	0.49	0.49	0.49		2	0	0	0
Suite 707-01 Break Room - Faucet (707-2)	7	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
7W-2 Women's Restroom West - Lavatory Faucet-Left	7	Legionella Culture	CFU/mL																		
7W-2 Women's Restroom West - Lavatory Faucet-Left	7	Copper	ppb																		
7W-2 Women's Restroom West - Lavatory Faucet-Left	7	E.Coli	--																		
7W-2 Women's Restroom West - Lavatory Faucet-Left	7	Lead	ppb																		
7W-2 Women's Restroom West - Lavatory Faucet-Left	7	Total Coliform	--																		
7W-2 Women's Restroom West - Lavatory Faucet-Left	7	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	0.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
7W-2 Women's Restroom West - Lavatory Faucet-Left	7	Copper	ppb	1400	110	160	150	740	160	670	230	570	230	710	230	1300		480	330	1300	370
7W-2 Women's Restroom West - Lavatory Faucet-Left	7	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent

7W-2 Women's Restroom West - Lavatory Faucet-C	7	Lead	ppb	33	0.49	5.6	0.49	6.7	0.49	17	0.49	8.1	0.49	8.4	0.49	11		3	0	2	0
7W-2 Women's Restroom West - Lavatory Faucet-C	7	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
7W-2 Women's Restroom West - Lavatory Faucet-R	7	Legionella Culture	CFU/mL																		
7W-2 Women's Restroom West - Lavatory Faucet-R	7	Copper	ppb																		
7W-2 Women's Restroom West - Lavatory Faucet-R	7	E.Coli	--																		
7W-2 Women's Restroom West - Lavatory Faucet-R	7	Lead	ppb																		
7W-2 Women's Restroom West - Lavatory Faucet-R	7	Total Coliform	--																		
7M-2 Men's Restroom West - Lavatory Faucet-Left	7	Legionella Culture	CFU/mL																		
7M-2 Men's Restroom West - Lavatory Faucet-Left	7	Copper	ppb																		
7M-2 Men's Restroom West - Lavatory Faucet-Left	7	E.Coli	--																		
7M-2 Men's Restroom West - Lavatory Faucet-Left	7	Lead	ppb																		
7M-2 Men's Restroom West - Lavatory Faucet-Left	7	Total Coliform	--																		
7M-2 Men's Restroom West - Lavatory Faucet-Righ	7	Legionella Culture	CFU/mL	ND	0.8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
7M-2 Men's Restroom West - Lavatory Faucet-Righ	7	Copper	ppb	110	76	190	180	390	190	480	250	980	190	590	240	740		790	350	1000	420
7M-2 Men's Restroom West - Lavatory Faucet-Righ	7	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
7M-2 Men's Restroom West - Lavatory Faucet-Righ	7	Lead	ppb	4.3	0.49	4	0.49	3.2	0.49	2	0.49	15	0.49	4.6	0.49	12		12	0	9	0
7M-2 Men's Restroom West - Lavatory Faucet-Righ	7	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
7M-1 Men's Restroom East - Lavatory Faucet-Left	7	Legionella Culture	CFU/mL																		
7M-1 Men's Restroom East - Lavatory Faucet-Left	7	Copper	ppb																		
7M-1 Men's Restroom East - Lavatory Faucet-Left	7	E.Coli	--																		
7M-1 Men's Restroom East - Lavatory Faucet-Left	7	Lead	ppb																		
7M-1 Men's Restroom East - Lavatory Faucet-Left	7	Total Coliform	--																		
7M-1 Men's Restroom East - Lavatory Faucet-Right	7	Legionella Culture	CFU/mL	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
7M-1 Men's Restroom East - Lavatory Faucet-Right	7	Copper	ppb	460	53	360	160	910	160	420	200	480	180	520	240	980		980	330	1000	360
7M-1 Men's Restroom East - Lavatory Faucet-Right	7	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
7M-1 Men's Restroom East - Lavatory Faucet-Right	7	Lead	ppb	9.1	0.49	3.8	0.49	9.4	0.49	7.3	0.49	7.8	0.49	8.8	0.49	8.4		51	0	19	0
7M-1 Men's Restroom East - Lavatory Faucet-Right	7	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
7W-1 Women's Restroom East - Lavatory Faucet-Le	7	Legionella Culture	CFU/mL																		
7W-1 Women's Restroom East - Lavatory Faucet-Le	7	Copper	ppb																		
7W-1 Women's Restroom East - Lavatory Faucet-Le	7	E.Coli	--																		
7W-1 Women's Restroom East - Lavatory Faucet-Le	7	Lead	ppb																		
7W-1 Women's Restroom East - Lavatory Faucet-Le	7	Total Coliform	--																		
7W-1 Women's Restroom East - Lavatory Faucet-C	7	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
7W-1 Women's Restroom East - Lavatory Faucet-C	7	Copper	ppb	1200	140	560	270	380	180	340	240	1600	280	2700	290	640					
7W-1 Women's Restroom East - Lavatory Faucet-C	7	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					
7W-1 Women's Restroom East - Lavatory Faucet-C	7	Lead	ppb	31	0.53	24	0.97	6.1	0.49	4.4	0.49	21	0.49	37	0.49	2.1					
7W-1 Women's Restroom East - Lavatory Faucet-C	7	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					
7W-1 Women's Restroom East - Lavatory Faucet-R	7	Legionella Culture	CFU/mL															ND	0.4	ND	2
7W-1 Women's Restroom East - Lavatory Faucet-R	7	Copper	ppb															1100	360	1400	330
7W-1 Women's Restroom East - Lavatory Faucet-R	7	E.Coli	--															Absent	Absent	Absent	Absent
7W-1 Women's Restroom East - Lavatory Faucet-R	7	Lead	ppb															8	0	5	0
7W-1 Women's Restroom East - Lavatory Faucet-R	7	Total Coliform	--															Absent	Absent	Absent	Absent
Suite 710 Faucet (710-03)	7	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Suite 710 Faucet (710-03)	7	Copper	ppb	300	43	110	140	190	150	130	210	150	160	280	340	1100		400	500	280	220
Suite 710 Faucet (710-03)	7	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
Suite 710 Faucet (710-03)	7	Lead	ppb	0.63	0.49	0.49	0.49	0.94	0.49	0.49	0.49	0.49	0.49	1.3	0.49	1.8		3	0	0	0
Suite 710 Faucet (710-03)	7	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
Suite 707-10 Faucet (707-07)	7	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
Suite 707-10 Faucet (707-07)	7	Copper	ppb	890	700	1000	770	890	880	150	100	240	210	280	290	1100		240	210	400	210
Suite 707-10 Faucet (707-07)	7	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
Suite 707-10 Faucet (707-07)	7	Lead	ppb	1.1	0.49	0.57	0.49	0.5	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49		0	0	0	0
Suite 707-10 Faucet (707-07)	7	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
Suite 810 Kitchen Faucet	8	Legionella Culture	CFU/mL	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
Suite 810 Kitchen Faucet	8	Copper	ppb	160	84	87	54	28	130	110	180	76	99	150	190	620		200	200	480	390
Suite 810 Kitchen Faucet	8	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
Suite 810 Kitchen Faucet	8	Lead	ppb	1.9	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49	2.3	0.49	0.49		0	0	0	0
Suite 810 Kitchen Faucet	8	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent

C807-Janitor's Closet-Mop/Slop Sink	8	Legionella Culture	CFU/mL			ND	ND	ND	ND	ND		ND	ND	ND	ND	ND					
C807-Janitor's Closet-Mop/Slop Sink	8	Copper	ppb			240	600	150	80	140	420	120	150	100	90	330					
C807-Janitor's Closet-Mop/Slop Sink	8	E.Coli	--			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					
C807-Janitor's Closet-Mop/Slop Sink	8	Lead	ppb			3.4	48	1.4	0.49	1.1	14	1.6	0.49	0.62	0.49	0.67					
C807-Janitor's Closet-Mop/Slop Sink	8	Total Coliform	--			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					
8 Corridor West - Drinking Fountain-Left	8	Legionella Culture	CFU/mL																		
8 Corridor West - Drinking Fountain-Left	8	Copper	ppb																		
8 Corridor West - Drinking Fountain-Left	8	E.Coli	--																		
8 Corridor West - Drinking Fountain-Left	8	Lead	ppb																		
8 Corridor West - Drinking Fountain-Left	8	Total Coliform	--																		
8W-2 Women's Restroom West - Lavatory Faucet-L	8	Legionella Culture	CFU/mL																		
8W-2 Women's Restroom West - Lavatory Faucet-L	8	Copper	ppb																		
8W-2 Women's Restroom West - Lavatory Faucet-L	8	E.Coli	--																		
8W-2 Women's Restroom West - Lavatory Faucet-L	8	Lead	ppb																		
8W-2 Women's Restroom West - Lavatory Faucet-L	8	Total Coliform	--																		
8W-2 Women's Restroom West - Lavatory Faucet-C	8	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.4	ND	ND	
8W-2 Women's Restroom West - Lavatory Faucet-C	8	Copper	ppb	900	220	390	190	390	150	900	200	340	270	340	280	700		440	320	610	310
8W-2 Women's Restroom West - Lavatory Faucet-C	8	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
8W-2 Women's Restroom West - Lavatory Faucet-C	8	Lead	ppb	25	1.5	5.7	0.61	8.6	0.49	5.1	0.49	3.4	0.49	3.2	0.49	7.9		3	0	1	0
8W-2 Women's Restroom West - Lavatory Faucet-C	8	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
8W-2 Women's Restroom West - Lavatory Faucet-R	8	Legionella Culture	CFU/mL																		
8W-2 Women's Restroom West - Lavatory Faucet-R	8	Copper	ppb																		
8W-2 Women's Restroom West - Lavatory Faucet-R	8	E.Coli	--																		
8W-2 Women's Restroom West - Lavatory Faucet-R	8	Lead	ppb																		
8W-2 Women's Restroom West - Lavatory Faucet-R	8	Total Coliform	--																		
8M-2 Men's Restroom West - Lavatory Faucet-Left	8	Legionella Culture	CFU/mL																		
8M-2 Men's Restroom West - Lavatory Faucet-Left	8	Copper	ppb																		
8M-2 Men's Restroom West - Lavatory Faucet-Left	8	E.Coli	--																		
8M-2 Men's Restroom West - Lavatory Faucet-Left	8	Lead	ppb																		
8M-2 Men's Restroom West - Lavatory Faucet-Left	8	Total Coliform	--																		
8M-2 Men's Restroom West - Lavatory Faucet-Righ	8	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	2	ND	ND	ND	ND	ND	ND	ND	0.4	ND
8M-2 Men's Restroom West - Lavatory Faucet-Righ	8	Copper	ppb	170	230	540	260	550	160	520	220	470	260	450	280	670		490	310	580	340
8M-2 Men's Restroom West - Lavatory Faucet-Righ	8	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
8M-2 Men's Restroom West - Lavatory Faucet-Righ	8	Lead	ppb	8.7	0.95	12	0.79	4.5	0.49	3.3	0.49	3.2	0.49	1.5	0.49	2		16	0	2	0
8M-2 Men's Restroom West - Lavatory Faucet-Righ	8	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
8M-1 Men's Restroom East - Lavatory Faucet-Left	8	Legionella Culture	CFU/mL																		
8M-1 Men's Restroom East - Lavatory Faucet-Left	8	Copper	ppb																		
8M-1 Men's Restroom East - Lavatory Faucet-Left	8	E.Coli	--																		
8M-1 Men's Restroom East - Lavatory Faucet-Left	8	Lead	ppb																		
8M-1 Men's Restroom East - Lavatory Faucet-Left	8	Total Coliform	--																		
8M-1 Men's Restroom East - Lavatory Faucet-Right	8	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.8	ND
8M-1 Men's Restroom East - Lavatory Faucet-Right	8	Copper	ppb	540	280	450	300	510	160	730	230	720	290	640	290	690		1200	320	2900	410
8M-1 Men's Restroom East - Lavatory Faucet-Right	8	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
8M-1 Men's Restroom East - Lavatory Faucet-Right	8	Lead	ppb	19	0.49	4.4	0.63	12	0.49	5.3	0.49	8.5	0.49	6.5	0.49	2.2		35	0	6	0
8M-1 Men's Restroom East - Lavatory Faucet-Right	8	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
8W-1 Women's Restroom East - Lavatory Faucet-Le	8	Legionella Culture	CFU/mL																		
8W-1 Women's Restroom East - Lavatory Faucet-Le	8	Copper	ppb																		
8W-1 Women's Restroom East - Lavatory Faucet-Le	8	E.Coli	--																		
8W-1 Women's Restroom East - Lavatory Faucet-Le	8	Lead	ppb																		
8W-1 Women's Restroom East - Lavatory Faucet-Le	8	Total Coliform	--																		
8W-1 Women's Restroom East - Lavatory Faucet-C	8	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	0.8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
8W-1 Women's Restroom East - Lavatory Faucet-C	8	Copper	ppb	1400	260	600	240	410	160	700	250	970	330	780	310	730		470	330	520	390
8W-1 Women's Restroom East - Lavatory Faucet-C	8	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
8W-1 Women's Restroom East - Lavatory Faucet-C	8	Lead	ppb	43	0.49	7.6	0.49	6.8	0.49	3.8	0.49	9.9	0.49	8.3	0.49	5.5		3	0	1	0
8W-1 Women's Restroom East - Lavatory Faucet-C	8	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
8W-1 Women's Restroom East - Lavatory Faucet-R	8	Legionella Culture	CFU/mL																		
8W-1 Women's Restroom East - Lavatory Faucet-R	8	Copper	ppb																		



8W-1 Women's Restroom East - Lavatory Faucet-R	8	E.Coli	--																	
8W-1 Women's Restroom East - Lavatory Faucet-R	8	Lead	ppb																	
8W-1 Women's Restroom East - Lavatory Faucet-R	8	Total Coliform	--																	
Suite 808A Break Room Faucet (809-02)	8	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Suite 808A Break Room Faucet (809-02)	8	Copper	ppb	180	91	590	370	67	86	210	140	55	120	140	150	940	290	140	1000	350
Suite 808A Break Room Faucet (809-02)	8	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
Suite 808A Break Room Faucet (809-02)	8	Lead	ppb	1.6	0.49	1.3	0.49	0.49	0.49	0.72	0.49	0.49	0.49	0.85	0.49	1	3	0	5	0
Suite 808A Break Room Faucet (809-02)	8	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
C907-Janitor's Closet-Mop/Slop Sink	9	Legionella Culture	CFU/mL			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
C907-Janitor's Closet-Mop/Slop Sink	9	Copper	ppb			370	570	220	94	240	170	220	120	210	140	270				
C907-Janitor's Closet-Mop/Slop Sink	9	E.Coli	--			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent				
C907-Janitor's Closet-Mop/Slop Sink	9	Lead	ppb			2.3	12	3.9	1.3	19	0.49	5.7	0.57	16	0.49	3				
C907-Janitor's Closet-Mop/Slop Sink	9	Total Coliform	--			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent				
9 Corridor East - Drinking Fountain-Left	9	Legionella Culture	CFU/mL																	
9 Corridor East - Drinking Fountain-Left	9	Copper	ppb																	
9 Corridor East - Drinking Fountain-Left	9	E.Coli	--																	
9 Corridor East - Drinking Fountain-Left	9	Lead	ppb																	
9 Corridor East - Drinking Fountain-Left	9	Total Coliform	--																	
Suite 907A Break Room Faucet (907-22)	9	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Suite 907A Break Room Faucet (907-22)	9	Copper	ppb	1100	670	1000	750	130	89	280	290	330	170	260	270	600	430	320	730	200
Suite 907A Break Room Faucet (907-22)	9	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
Suite 907A Break Room Faucet (907-22)	9	Lead	ppb	0.66	0.51	0.53	0.49	1.2	0.49	0.49	0.49	0.75	0.49	4	0.49	0.49	10	0	1	0
Suite 907A Break Room Faucet (907-22)	9	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
Suite 910A Faucet (910-05)	9	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Suite 910A Faucet (910-05)	9	Copper	ppb	3800	560	120	150	1700	430	890	290	560	260	580	270	930	340	260	940	740
Suite 910A Faucet (910-05)	9	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
Suite 910A Faucet (910-05)	9	Lead	ppb	15	0.8	0.49	0.49	1.6	0.49	0.88	0.49	0.54	0.49	1.1	0.49	1.5	1	0	0	0
Suite 910A Faucet (910-05)	9	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
9W-2 Women's Restroom West - Lavatory Faucet-L	9	Legionella Culture	CFU/mL																	
9W-2 Women's Restroom West - Lavatory Faucet-L	9	Copper	ppb																	
9W-2 Women's Restroom West - Lavatory Faucet-L	9	E.Coli	--																	
9W-2 Women's Restroom West - Lavatory Faucet-L	9	Lead	ppb																	
9W-2 Women's Restroom West - Lavatory Faucet-L	9	Total Coliform	--																	
9W-2 Women's Restroom West - Lavatory Faucet-C	9	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	0.8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
9W-2 Women's Restroom West - Lavatory Faucet-C	9	Copper	ppb	1400	210	430	150	640	200	540	190	540	230	850	4200	180	540	310		
9W-2 Women's Restroom West - Lavatory Faucet-C	9	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
9W-2 Women's Restroom West - Lavatory Faucet-C	9	Lead	ppb	20	0.49	14	0.49	13	0.49	12	0.49	7.2	0.49	7.3	21	0	3	0		
9W-2 Women's Restroom West - Lavatory Faucet-C	9	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
9W-2 Women's Restroom West - Lavatory Faucet-R	9	Legionella Culture	CFU/mL																	
9W-2 Women's Restroom West - Lavatory Faucet-R	9	Copper	ppb																	
9W-2 Women's Restroom West - Lavatory Faucet-R	9	E.Coli	--																	
9W-2 Women's Restroom West - Lavatory Faucet-R	9	Lead	ppb																	
9W-2 Women's Restroom West - Lavatory Faucet-R	9	Total Coliform	--																	
9M-2 Men's Restroom West - Lavatory Faucet-Left	9	Legionella Culture	CFU/mL																	
9M-2 Men's Restroom West - Lavatory Faucet-Left	9	Copper	ppb																	
9M-2 Men's Restroom West - Lavatory Faucet-Left	9	E.Coli	--																	
9M-2 Men's Restroom West - Lavatory Faucet-Left	9	Lead	ppb																	
9M-2 Men's Restroom West - Lavatory Faucet-Left	9	Total Coliform	--																	
9M-2 Men's Restroom West - Lavatory Faucet-Right	9	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.4	ND	ND
9M-2 Men's Restroom West - Lavatory Faucet-Right	9	Copper	ppb	800	200	530	170	1600	150	560	200	1300	180	670	230	1000	2000	180	3200	290
9M-2 Men's Restroom West - Lavatory Faucet-Right	9	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
9M-2 Men's Restroom West - Lavatory Faucet-Right	9	Lead	ppb	7.8	0.49	4.7	0.49	28	0.49	3.5	0.49	13	0.49	6.8	0.49	15	24	0	13	0
9M-2 Men's Restroom West - Lavatory Faucet-Right	9	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
9M-1 Men's Restroom East - Lavatory Faucet-Left	9	Legionella Culture	CFU/mL																	
9M-1 Men's Restroom East - Lavatory Faucet-Left	9	Copper	ppb																	
9M-1 Men's Restroom East - Lavatory Faucet-Left	9	E.Coli	--																	
9M-1 Men's Restroom East - Lavatory Faucet-Left	9	Lead	ppb																	

9M-1 Men's Restroom East - Lavatory Faucet-Left	9	Total Coliform	--																		
9M-1 Men's Restroom East - Lavatory Faucet-Right	9	Legionella Culture	CFU/mL	ND	ND			ND	ND	ND	ND	2	ND	ND	ND	ND	ND	ND	ND	0.4	
9M-1 Men's Restroom East - Lavatory Faucet-Right	9	Copper	ppb	850	180			1400	150	1000	220	1300	210	560	220	720		1900	290	2200	350
9M-1 Men's Restroom East - Lavatory Faucet-Right	9	E.Coli	--	Absent	Absent			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
9M-1 Men's Restroom East - Lavatory Faucet-Right	9	Lead	ppb	130	0.54			15	0.49	21	0.49	11	0.49	18	0.49	4.2		33	0	10	0
9M-1 Men's Restroom East - Lavatory Faucet-Right	9	Total Coliform	--	Absent	Absent			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
9W-1 Women's Restroom East - Lavatory Faucet-Left	9	Legionella Culture	CFU/mL																		
9W-1 Women's Restroom East - Lavatory Faucet-Left	9	Copper	ppb																		
9W-1 Women's Restroom East - Lavatory Faucet-Left	9	E.Coli	--																		
9W-1 Women's Restroom East - Lavatory Faucet-Left	9	Lead	ppb																		
9W-1 Women's Restroom East - Lavatory Faucet-Left	9	Total Coliform	--																		
9W-1 Women's Restroom East - Lavatory Faucet-C	9	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND		ND	48	ND	ND	ND	ND	ND	13.6	8	ND	ND
9W-1 Women's Restroom East - Lavatory Faucet-C	9	Copper	ppb	1800	180			870	160	410	240	2400	220	5600	230	1100		970	330	820	490
9W-1 Women's Restroom East - Lavatory Faucet-C	9	E.Coli	--	Absent	Absent			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
9W-1 Women's Restroom East - Lavatory Faucet-C	9	Lead	ppb	61	0.49			17	0.49	6	0.49	33	0.49	110	0.49	11		7	0	3	0
9W-1 Women's Restroom East - Lavatory Faucet-C	9	Total Coliform	--	Absent	Absent			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
9W-1 Women's Restroom East - Lavatory Faucet-R	9	Legionella Culture	CFU/mL																		
9W-1 Women's Restroom East - Lavatory Faucet-R	9	Copper	ppb																		
9W-1 Women's Restroom East - Lavatory Faucet-R	9	E.Coli	--																		
9W-1 Women's Restroom East - Lavatory Faucet-R	9	Lead	ppb																		
9W-1 Women's Restroom East - Lavatory Faucet-R	9	Total Coliform	--																		
Suite 908 Break Room Faucet (908-15)	9	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Suite 908 Break Room Faucet (908-15)	9	Copper	ppb	89	160	1100	500	100	290	340	380	270	260	250	300	740		280	460	1000	820
Suite 908 Break Room Faucet (908-15)	9	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
Suite 908 Break Room Faucet (908-15)	9	Lead	ppb	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.63	0.49	0.49		0	0	0	0
Suite 908 Break Room Faucet (908-15)	9	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
C1007-Janitor's Closet-Mop/Slop Sink	10	Legionella Culture	CFU/mL			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
C1007-Janitor's Closet-Mop/Slop Sink	10	Copper	ppb			3200	290	340	140	180	130	220	170	95	160	250					
C1007-Janitor's Closet-Mop/Slop Sink	10	E.Coli	--			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					
C1007-Janitor's Closet-Mop/Slop Sink	10	Lead	ppb			35	0.49	7.7	0.79	5.3	3.8	3	0.49	4	0.49	2.3					
C1007-Janitor's Closet-Mop/Slop Sink	10	Total Coliform	--			Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					
10 Corridor West - Drinking Fountain-Left	10	Legionella Culture	CFU/mL																		
10 Corridor West - Drinking Fountain-Left	10	Copper	ppb																		
10 Corridor West - Drinking Fountain-Left	10	E.Coli	--																		
10 Corridor West - Drinking Fountain-Left	10	Lead	ppb																		
10 Corridor West - Drinking Fountain-Left	10	Total Coliform	--																		
Suite 1010 Lavatory Faucet	10	Legionella Culture	CFU/mL																		
Suite 1010 Lavatory Faucet	10	Copper	ppb																		
Suite 1010 Lavatory Faucet	10	E.Coli	--																		
Suite 1010 Lavatory Faucet	10	Lead	ppb																		
Suite 1010 Lavatory Faucet	10	Total Coliform	--																		
Suite 1010 Kitchenette Faucet	10	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND			ND	ND	ND	ND	ND	ND		
Suite 1010 Kitchenette Faucet	10	Copper	ppb	550	130	3200	170	2600	290	2300	680			2100	460	2400		990	590		
Suite 1010 Kitchenette Faucet	10	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent		Absent	Absent		
Suite 1010 Kitchenette Faucet	10	Lead	ppb	0.49	0.49	20	0.49	12	0.49	3.1	0.49			2.6	3.1	0.49	5.7	2	0		
Suite 1010 Kitchenette Faucet	10	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent			Absent	Absent	Absent		Absent	Absent		
10W-2 Women's Restroom West - Lavatory Faucet-	10	Legionella Culture	CFU/mL																		
10W-2 Women's Restroom West - Lavatory Faucet-	10	Copper	ppb																		
10W-2 Women's Restroom West - Lavatory Faucet-	10	E.Coli	--																		
10W-2 Women's Restroom West - Lavatory Faucet-	10	Lead	ppb																		
10W-2 Women's Restroom West - Lavatory Faucet-	10	Total Coliform	--																		
10W-2 Women's Restroom West - Lavatory Faucet-	10	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND	0.8	ND	ND
10W-2 Women's Restroom West - Lavatory Faucet-	10	Copper	ppb	2700	140	780	150	280	130	430	190	470	160	460	170	560		440	220	12000	270
10W-2 Women's Restroom West - Lavatory Faucet-	10	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
10W-2 Women's Restroom West - Lavatory Faucet-	10	Lead	ppb	130	0.49	32	0.49	3.7	0.49	5	0.49	10	0.49	22	0.49	3.4		7	0	86	0
10W-2 Women's Restroom West - Lavatory Faucet-	10	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
10W-2 Women's Restroom West - Lavatory Faucet-	10	Legionella Culture	CFU/mL																		

10W-2 Women's Restroom West - Lavatory Faucet-	10	Copper	ppb																	
10W-2 Women's Restroom West - Lavatory Faucet-	10	E.Coli	--																	
10W-2 Women's Restroom West - Lavatory Faucet-	10	Lead	ppb																	
10W-2 Women's Restroom West - Lavatory Faucet-	10	Total Coliform	--																	
10M-2 Men's Restroom West - Lavatory Faucet-Left	10	Legionella Culture	CFU/mL																	
10M-2 Men's Restroom West - Lavatory Faucet-Left	10	Copper	ppb																	
10M-2 Men's Restroom West - Lavatory Faucet-Left	10	E.Coli	--																	
10M-2 Men's Restroom West - Lavatory Faucet-Left	10	Lead	ppb																	
10M-2 Men's Restroom West - Lavatory Faucet-Left	10	Total Coliform	--																	
10M-2 Men's Restroom West - Lavatory Faucet-Rig	10	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	0.8	ND	ND	ND	ND	ND	ND	ND	ND	ND	
10M-2 Men's Restroom West - Lavatory Faucet-Rig	10	Copper	ppb	150	130	430	130	450	190	430	150	460	190	440		620	300	420	210	
10M-2 Men's Restroom West - Lavatory Faucet-Rig	10	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	
10M-2 Men's Restroom West - Lavatory Faucet-Rig	10	Lead	ppb	0.91	0.49	19	0.49	4	0.49	5.2	0.49	4.1	0.49	1.9		2	0	36	0	
10M-2 Men's Restroom West - Lavatory Faucet-Rig	10	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
10M-1 Men's Restroom East - Lavatory Faucet-Left	10	Legionella Culture	CFU/mL																	
10M-1 Men's Restroom East - Lavatory Faucet-Left	10	Copper	ppb																	
10M-1 Men's Restroom East - Lavatory Faucet-Left	10	E.Coli	--																	
10M-1 Men's Restroom East - Lavatory Faucet-Left	10	Lead	ppb																	
10M-1 Men's Restroom East - Lavatory Faucet-Left	10	Total Coliform	--																	
10M-1 Men's Restroom East - Lavatory Faucet-Righ	10	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.8	ND	ND	ND	
10M-1 Men's Restroom East - Lavatory Faucet-Righ	10	Copper	ppb			350	140	630	160	730	200	1100	270	450	260	630	1500	450	860	400
10M-1 Men's Restroom East - Lavatory Faucet-Righ	10	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
10M-1 Men's Restroom East - Lavatory Faucet-Righ	10	Lead	ppb	5.3	0.49	12	0.49	3.3	0.49	26	0.49	6.3	0.49	12		25	0	8	0	
10M-1 Men's Restroom East - Lavatory Faucet-Righ	10	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent	
10W-1 Women's Restroom East - Lavatory Faucet-L	10	Legionella Culture	CFU/mL																	
10W-1 Women's Restroom East - Lavatory Faucet-L	10	Copper	ppb																	
10W-1 Women's Restroom East - Lavatory Faucet-L	10	E.Coli	--																	
10W-1 Women's Restroom East - Lavatory Faucet-L	10	Lead	ppb																	
10W-1 Women's Restroom East - Lavatory Faucet-L	10	Total Coliform	--																	
10W-1 Women's Restroom East - Lavatory Faucet-C	10	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	0.4	ND	ND	ND	0.2	ND				ND	0.4
10W-1 Women's Restroom East - Lavatory Faucet-C	10	Copper	ppb	1200	160	370	190	400	160	4700	290	1100	320	340	350	720			600	330
10W-1 Women's Restroom East - Lavatory Faucet-C	10	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent				Absent	Absent
10W-1 Women's Restroom East - Lavatory Faucet-C	10	Lead	ppb	31	0.49	22	0.49	13	0.49	25	0.49	7.2	0.49	1.8	0.49	4.1			0	0
10W-1 Women's Restroom East - Lavatory Faucet-C	10	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent				Absent	Absent
10W-1 Women's Restroom East - Lavatory Faucet-f	10	Legionella Culture	CFU/mL														62.4	0.8		
10W-1 Women's Restroom East - Lavatory Faucet-f	10	Copper	ppb																	
10W-1 Women's Restroom East - Lavatory Faucet-f	10	E.Coli	--																	
10W-1 Women's Restroom East - Lavatory Faucet-f	10	Lead	ppb																	
10W-1 Women's Restroom East - Lavatory Faucet-f	10	Total Coliform	--																	
Suite 1009C Break Room-Kitchen Faucet (1009-19)	10	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Suite 1009C Break Room-Kitchen Faucet (1009-19)	10	Copper	ppb	180	460	170	170	110	140	240	180	160	190	230	240	650	1400	440	770	710
Suite 1009C Break Room-Kitchen Faucet (1009-19)	10	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
Suite 1009C Break Room-Kitchen Faucet (1009-19)	10	Lead	ppb	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.75	0.49	3.2	23	0	0	0
Suite 1009C Break Room-Kitchen Faucet (1009-19)	10	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent		Absent	Absent	Absent	Absent
Suite 1015 GSA Kitchenette Faucet (1000-03)	10	Legionella Culture	CFU/mL	ND	ND	ND	ND	0.8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Suite 1015 GSA Kitchenette Faucet (1000-03)	10	Copper	ppb	130	100	160	610	540	490	240	260	640	500	260	430	820	1100	810	1100	850
Suite 1015 GSA Kitchenette Faucet (1000-03)	10	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
Suite 1015 GSA Kitchenette Faucet (1000-03)	10	Lead	ppb	0.59	0.49	0.49	0.49	0.55	0.49	0.49	0.49	0.7	0.49	0.49	0.49	0.72			0	0
Suite 1015 GSA Kitchenette Faucet (1000-03)	10	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	2	0	0	0
Suite 1008 Break Room-Kitchen Faucet (1009-07)	10	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Suite 1008 Break Room-Kitchen Faucet (1009-07)	10	Copper	ppb	720	460	180	120	1100	380	350	230	320	160	280	230	1200	900	300	910	460
Suite 1008 Break Room-Kitchen Faucet (1009-07)	10	E.Coli	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
Suite 1008 Break Room-Kitchen Faucet (1009-07)	10	Lead	ppb	1.9	0.49	0.62	0.49	3.4	0.49	0.5	0.49	0.86	0.49	0.49	0.49	0.89	1	0	0	0
Suite 1008 Break Room-Kitchen Faucet (1009-07)	10	Total Coliform	--	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent
EC Roof -Cooling Tower	EC Roof	Legionella Culture	CFU/mL																	
EC Roof -Cooling Tower	EC Roof	E.Coli	--																	
EC Roof -Cooling Tower	EC Roof	Total Coliform	--																	

EC Roof -Cooling Tower	EC Roof	Copper	ppb																	
EC Roof -Cooling Tower	EC Roof	Lead	ppb																	
Water Cooler 108 Left	1	Legionella Culture	CFU/mL	ND	ND			ND		ND		ND		ND		ND		ND		ND
Water Cooler 108 Left	1	Copper	ppb	0.1		0.1		0.1		0.9		0.1		0.1		0.9		0		0
Water Cooler 108 Left	1	E.Coli	--	Absent		Absent		Absent		Absent		Absent		Absent		Absent		Absent		Absent
Water Cooler 108 Left	1	Lead	ppb	0.49		0.49		0.49		0.49		0.49		0.49		0.49		0		0
Water Cooler 108 Left	1	Total Coliform	--	Present		Absent		Absent		Absent		Absent		Absent		Absent		Absent		Absent
Water Cooler 108 Right	1	Legionella Culture	CFU/mL	ND	ND			ND		ND		ND		ND		ND		ND		ND
Water Cooler 108 Right	1	Copper	ppb			0.1		0.1		0.9		0.1				0.9		0		0
Water Cooler 108 Right	1	E.Coli	--			Absent		Absent		Absent		Absent				Absent		Absent		Absent
Water Cooler 108 Right	1	Lead	ppb			0.49		0.49		0.49		0.49				0.49		0		0
Water Cooler 108 Right	1	Total Coliform	--			Absent		Absent		Absent		Present				Absent		Absent		Absent
Water Cooler #3	1	Legionella Culture	CFU/mL		ND			ND		ND			ND		ND		ND		ND	
Water Cooler #3	1	Copper	ppb			0.1		0.1		0.9		0.1				0.9		0		
Water Cooler #3	1	E.Coli	--			Absent		Absent		Absent					Absent		Absent		Absent	
Water Cooler #3	1	Lead	ppb			0.49		0.49		0.49		0.49				0.49		0		
Water Cooler #3	1	Total Coliform	--			Absent		Absent		Absent					Absent		Absent		Absent	
Water Cooler Loading Dock	1	Legionella Culture	CFU/mL		ND			ND		ND		ND		ND		ND		ND		ND
Water Cooler Loading Dock	1	Copper	ppb			0.1		0.1		0.9		0.9				0.9		0		0
Water Cooler Loading Dock	1	E.Coli	--			Absent		Absent		Absent				Absent		Absent		Absent		Absent
Water Cooler Loading Dock	1	Lead	ppb			0.49		0.49		0.49		0.49				0.49		0		0
Water Cooler Loading Dock	1	Total Coliform	--			Absent		Absent		Absent				Absent		Absent		Absent		Absent
Water Cooler Housekeeping	1	Legionella Culture	CFU/mL		ND		ND	ND		ND		ND				ND		ND		ND
Water Cooler Housekeeping	1	Copper	ppb			0.1		0.1		0.9		0.9				0.9		0.9		
Water Cooler Housekeeping	1	E.Coli	--			Absent		Absent		Absent				Absent		Absent		Absent		Absent
Water Cooler Housekeeping	1	Lead	ppb			0.49		0.49		0.49		0.49				0.49		0.49		
Water Cooler Housekeeping	1	Total Coliform	--			Absent		Absent		Absent				Absent		Absent		Absent		Absent
STE 614 Water Cooler	6	Legionella Culture	CFU/mL											ND						
STE 614 Water Cooler	6	Copper	ppb											0.9						
STE 614 Water Cooler	6	E.Coli	--											Absent						
STE 614 Water Cooler	6	Lead	ppb											0.49						
STE 614 Water Cooler	6	Total Coliform	--											Absent						
STE 615 Water Cooler	6	Legionella Culture	CFU/mL											ND						
STE 615 Water Cooler	6	Copper	ppb											0.9						
STE 615 Water Cooler	6	E.Coli	--											Absent						
STE 615 Water Cooler	6	Lead	ppb											0.49						
STE 615 Water Cooler	6	Total Coliform	--											Absent						
STE 620 Water Cooler	6	Legionella Culture	CFU/mL											ND						
STE 620 Water Cooler	6	Copper	ppb											0.9						
STE 620 Water Cooler	6	E.Coli	--											Absent						
STE 620 Water Cooler	6	Lead	ppb											0.49						
STE 620 Water Cooler	6	Total Coliform	--											Absent						
STE 608 Water Cooler	6	Legionella Culture	CFU/mL											ND						
STE 608 Water Cooler	6	Copper	ppb											0.9						
STE 608 Water Cooler	6	E.Coli	--											Absent						
STE 608 Water Cooler	6	Lead	ppb											0.49						
STE 608 Water Cooler	6	Total Coliform	--											Absent						
STE 710 Water Cooler	7	Legionella Culture	CFU/mL											ND						
STE 710 Water Cooler	7	Copper	ppb											0.9						
STE 710 Water Cooler	7	E.Coli	--											Absent						
STE 710 Water Cooler	7	Lead	ppb											0.49						
STE 710 Water Cooler	7	Total Coliform	--											Absent						
STE 707 Break Room Water Cooler	7	Legionella Culture	CFU/mL											ND						
STE 707 Break Room Water Cooler	7	Copper	ppb											0.9						
STE 707 Break Room Water Cooler	7	E.Coli	--											Absent						
STE 707 Break Room Water Cooler	7	Lead	ppb											0.49						
STE 707 Break Room Water Cooler	7	Total Coliform	--											Absent						

STE 707-10 Water Cooler	7	Legionella Culture	CFU/mL											ND		ND			
STE 707-10 Water Cooler	7	Copper	ppb											0.9		0.9			
STE 707-10 Water Cooler	7	E.Coli	--											Absent		Absent			
STE 707-10 Water Cooler	7	Lead	ppb											0.49		0.49			
STE 707-10 Water Cooler	7	Total Coliform	--											Absent		Absent			
STE 810 Water Cooler	8	Legionella Culture	CFU/mL											ND		ND			
STE 810 Water Cooler	8	Copper	ppb											0.9		0.9			
STE 810 Water Cooler	8	E.Coli	--											Absent		Absent			
STE 810 Water Cooler	8	Lead	ppb											0.49		0.49			
STE 810 Water Cooler	8	Total Coliform	--											Absent		Absent			
STE 808A Water Cooler	8	Legionella Culture	CFU/mL											ND		ND			
STE 808A Water Cooler	8	Copper	ppb											0.9		0.9			
STE 808A Water Cooler	8	E.Coli	--											Absent		Absent			
STE 808A Water Cooler	8	Lead	ppb											0.49		0.49			
STE 808A Water Cooler	8	Total Coliform	--											Absent		Absent			
STE 910A Water Cooler	9	Legionella Culture	CFU/mL											ND		ND			
STE 910A Water Cooler	9	Copper	ppb											0.9		0.9			
STE 910A Water Cooler	9	E.Coli	--											Absent		Absent			
STE 910A Water Cooler	9	Lead	ppb											0.49		0.49			
STE 910A Water Cooler	9	Total Coliform	--											Absent		Absent			
STE 907A Water Cooler	9	Legionella Culture	CFU/mL											ND					
STE 907A Water Cooler	9	Copper	ppb											0.9					
STE 907A Water Cooler	9	E.Coli	--											Absent					
STE 907A Water Cooler	9	Lead	ppb											0.49					
STE 907A Water Cooler	9	Total Coliform	--											Absent					
STE 908 Water Cooler	9	Legionella Culture	CFU/mL											ND		ND			
STE 908 Water Cooler	9	Copper	ppb											0.49		0.9			
STE 908 Water Cooler	9	E.Coli	--											Absent		Absent			
STE 908 Water Cooler	9	Lead	ppb											0.9		0.49			
STE 908 Water Cooler	9	Total Coliform	--											Absent		Absent			
STE 1009C Water Cooler	10	Legionella Culture	CFU/mL											ND		ND			
STE 1009C Water Cooler	10	Copper	ppb											0.49		0.9			
STE 1009C Water Cooler	10	E.Coli	--											Absent		Absent			
STE 1009C Water Cooler	10	Lead	ppb											0.9		0.49			
STE 1009C Water Cooler	10	Total Coliform	--											Absent		Absent			
STE 1015 Water Cooler	10	Legionella Culture	CFU/mL											ND		ND			
STE 1015 Water Cooler	10	Copper	ppb											0.49		0.9			
STE 1015 Water Cooler	10	E.Coli	--											Absent		Absent			
STE 1015 Water Cooler	10	Lead	ppb											0.9		0.49			
STE 1015 Water Cooler	10	Total Coliform	--											Absent		Absent			
STE 535 Break Room Water Cooler	5	Legionella Culture	CFU/mL											ND		ND			
STE 535 Break Room Water Cooler	5	Copper	ppb											0.49		0.9			
STE 535 Break Room Water Cooler	5	E.Coli	--											Absent		Absent			
STE 535 Break Room Water Cooler	5	Lead	ppb											0.9		0.49			
STE 535 Break Room Water Cooler	5	Total Coliform	--											Absent		Absent			
STE 540 Water Cooler	5	Legionella Culture	CFU/mL											ND		ND			
STE 540 Water Cooler	5	Copper	ppb											0.49		0.9			
STE 540 Water Cooler	5	E.Coli	--											Absent		Absent			
STE 540 Water Cooler	5	Lead	ppb											0.9		0.49			
STE 540 Water Cooler	5	Total Coliform	--											Absent		Absent			
STE 530 Water Cooler	5	Legionella Culture	CFU/mL											ND		ND			
STE 530 Water Cooler	5	Copper	ppb											0.49		0.9			
STE 530 Water Cooler	5	E.Coli	--											Absent		Absent			
STE 530 Water Cooler	5	Lead	ppb											0.9		0.49			
STE 530 Water Cooler	5	Total Coliform	--											Absent		Absent			
STE 410 Water Cooler	4	Legionella Culture	CFU/mL											ND		ND			
STE 410 Water Cooler	4	Copper	ppb													0.9			

STE 410 Water Cooler	4	E.Coli	--											Absent			
STE 410 Water Cooler	4	Lead	ppb											0.49			
STE 410 Water Cooler	4	Total Coliform	--											Absent			
STE 415 Water Cooler	4	Legionella Culture	CFU/mL									ND					
STE 415 Water Cooler	4	Copper	ppb														
STE 415 Water Cooler	4	E.Coli	--														
STE 415 Water Cooler	4	Lead	ppb														
STE 415 Water Cooler	4	Total Coliform	--														
STE 420 Water Cooler	4	Legionella Culture	CFU/mL									ND		ND			
STE 420 Water Cooler	4	Copper	ppb											0.9			
STE 420 Water Cooler	4	E.Coli	--											Absent			
STE 420 Water Cooler	4	Lead	ppb											0.49			
STE 420 Water Cooler	4	Total Coliform	--											Absent			
STE 416 Water Cooler	4	Legionella Culture	CFU/mL									ND					
STE 416 Water Cooler	4	Copper	ppb														
STE 416 Water Cooler	4	E.Coli	--														
STE 416 Water Cooler	4	Lead	ppb														
STE 416 Water Cooler	4	Total Coliform	--														
STE 254 Water Cooler	2	Legionella Culture	CFU/mL									ND		ND			
STE 254 Water Cooler	2	Copper	ppb											0.9			
STE 254 Water Cooler	2	E.Coli	--											Absent			
STE 254 Water Cooler	2	Lead	ppb											0.49			
STE 254 Water Cooler	2	Total Coliform	--											Absent			
STE 123 Health Unit Water Cooler	1	Legionella Culture	CFU/mL									ND					
STE 123 Health Unit Water Cooler	1	Copper	ppb														
STE 123 Health Unit Water Cooler	1	E.Coli	--														
STE 123 Health Unit Water Cooler	1	Lead	ppb														
STE 123 Health Unit Water Cooler	1	Total Coliform	--														