



January 20, 2021

Diane Czarnecki  
Industrial Hygienist  
Facilities Management Division  
GSA Public Buildings Service – Heartland Region  
2300 Main Street  
Kansas City, MO 64108

Re: Goodfellow Federal Center – Bldg. 102E Air Sampling  
Project No. 121244

Dear Ms. Czarnecki:

Thank you for the opportunity to provide the General Services Administration (GSA) with the Resource Conservation and Recovery Act (RCRA) metals air sampling investigation of the above referenced building located at the Goodfellow Federal Complex, in St. Louis, Missouri. Burns & McDonnell understands that the purpose of the investigation was to provide sampling data regarding existing conditions to supplement previous investigation reports prepared for the facility. The following report summarizes air-sample collection activities and the laboratory analytical results of the samples submitted.

#### **METHODOLOGY**

On November 30, 2020, Emily Ahlemeyer of Burns & McDonnell and Jeff Smith of OCCU-TEC conducted area air-sampling for the presence of seven (7) of the RCRA metals including arsenic, barium, cadmium, chromium, lead, selenium, and silver. Sampling was conducted in various locations throughout Building 102E.

The sampling scheme, number of samples, sample distribution, and general methodology was developed based on previous investigation methodology and in coordination with the GSA. Sample locations and samples collected from discretionary locations were determined by sampling personnel while on-site.

Air samples for RCRA metals were collected on 37-millimeter (mm) cassettes with 0.8 micrometer ( $\mu\text{m}$ ) mixed cellulose ester (MCE) filters, using powered air sampling pumps, in accordance with the National Institute for Occupational Safety and Health (NIOSH) Method 7300. The sampling strategy included collecting a minimum sample volume of 500 liters based on the calibrated pump flow rate and sample duration. Air samples were submitted under chain-of-custody to Environmental Hazards Services, LLC (EHS) in Richmond, Virginia for independent analysis of 7 RCRA metals according to NIOSH method 7300. EHS is accredited under the American Industrial Hygiene Association (AIHA) Industrial Hygiene Laboratory Accreditation Program (IHLAP) program, identification number LAP-100420.

Diane Czarnecki  
 Facilities Management Division  
 January 20, 2021  
 Page 2

**RESULTS AND DISCUSSION**

Results of the air sampling are summarized in the table below by identifying the range of results for Building 102E for each of the seven (7) metals that were sampled. Results indicate that all 9 air samples collected from Building 102E and analyzed for RCRA metals were below their respective OSHA Permissible Exposure Limit (PEL), as based on a time-weighted-average.

**Table 1. Summary of Air Sampling Results**

Analyte	Lowest Concentration <sup>(a)</sup> ( $\mu\text{g}/\text{m}^3$ ) <sup>(b)</sup>	Highest Concentration <sup>(a)</sup> ( $\mu\text{g}/\text{m}^3$ ) <sup>(b)</sup>	Permissible Exposure Limit (PEL) ( $\mu\text{g}/\text{m}^3$ ) <sup>(b)</sup>
Arsenic	<0.27	<0.29	10
Barium	<0.27	<0.29	500
Cadmium	<0.054	<0.057	5
Chromium (Total)	<1.4	<1.5	500
Lead	<0.27	<0.29	50
Selenium	<1.4	<1.5	200
Silver	<0.27	<0.29	10

Notes:

- (a) Samples with a “<” sign indicate that the results were below the laboratory’s reporting limit, which varies based on sample air volume.
- (b)  $\mu\text{g}/\text{m}^3$  = micrograms per cubic meter of air.

GSA may choose to compare results with guidance limits from additional organizations for risk evaluation, including but not limited to the American Conference of Governmental Industrial Hygienists (ACGIH) and/or the World Health Organization (WHO).

A summary table of all sampling results by location is included in Appendix A. The complete laboratory report for the air sampling from EHS is attached in Appendix B. The air sampling professional’s Missouri Lead license is included in Appendix C.

**LIMITATIONS**

The scope of this assessment was limited as follows. Burns & McDonnell collected samples from a select number of locations in an effort to minimize cost while providing a general overview of the air quality at the site. Sample locations do not encompass every indoor space at the site. Additionally, based on previous sampling history, samples were only analyzed for a select number of potential contaminants likely to affect the air quality at the site. Burns &



Diane Czarnecki  
Facilities Management Division  
January 20, 2021  
Page 3

McDonnell is not responsible for potential contaminants not identified in this report. This report was prepared for the sole use of GSA.

Burns & McDonnell appreciates the opportunity to work with the General Services Administration on this project. Please contact us if you have any questions regarding this report or if we may be of any additional service.

Sincerely,

(b) (6)

A large black rectangular redaction box covers the signature area, with the text "(b) (6)" in white at the top left corner.

Matt Shanahan, CHMM  
Project Manager

Attachments:

- Appendix A – Results Summary by Location
- Appendix B – Air Sample Laboratory Report
- Appendix C – Licenses

Information in Appendices B and C is not accessible for people using screen reader technology. If this information is required, it can be furnished upon request by contacting 816-223-6198 or [r6environmental@gsa.gov](mailto:r6environmental@gsa.gov).

**APPENDIX A – RESULTS SUMMARY BY LOCATION**

## Appendix A

### Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits <sup>1</sup>
102E-A-01	1st floor, break room	Arsenic	< 0.28	µg/m <sup>3</sup>	10
		Barium	< 0.28	µg/m <sup>3</sup>	500
		Cadmium	< 0.055	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.28	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.28	µg/m <sup>3</sup>	10
102E-A-02	1st floor, north conference room	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.054	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10
102E-A-03	1st floor, north stairwell	Arsenic	< 0.28	µg/m <sup>3</sup>	10
		Barium	< 0.28	µg/m <sup>3</sup>	500
		Cadmium	< 0.056	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.28	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.28	µg/m <sup>3</sup>	10
102E-A-04	1st floor, north lobby	Arsenic	< 0.28	µg/m <sup>3</sup>	10
		Barium	< 0.28	µg/m <sup>3</sup>	500
		Cadmium	< 0.056	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.28	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.28	µg/m <sup>3</sup>	10
102E-A-05	2nd floor, elevator mechanical room	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.054	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10

## Appendix A

### Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits <sup>1</sup>
102E-A-06R	2nd floor, office area	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.054	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10
102E-A-07	2nd floor, southeast storage area	Arsenic	< 0.29	µg/m <sup>3</sup>	10
		Barium	< 0.29	µg/m <sup>3</sup>	500
		Cadmium	< 0.057	µg/m <sup>3</sup>	5
		Chromium	< 1.5	µg/m <sup>3</sup>	500
		Lead	< 0.29	µg/m <sup>3</sup>	50
		Selenium	< 1.5	µg/m <sup>3</sup>	200
		Silver	< 0.29	µg/m <sup>3</sup>	10
102E-A-08	Basement	Arsenic	< 0.28	µg/m <sup>3</sup>	10
		Barium	< 0.28	µg/m <sup>3</sup>	500
		Cadmium	< 0.056	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.28	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.28	µg/m <sup>3</sup>	10
102E-A-09	Field blank	Arsenic	< 0.15	µg	--
		Barium	< 0.15	µg	--
		Cadmium	< 0.030	µg	--
		Chromium	< 0.75	µg	--
		Lead	< 0.15	µg	--
		Selenium	< 0.75	µg	--
		Silver	< 0.15	µg	--

Notes:

<sup>1</sup>Limits equal to the Occupational Safety and Health Administration (OSHA) Permissible Exposure Limits (PELs)

**APPENDIX B – AIR SAMPLE LABORATORY REPORT**



Environmental Hazards Services, L.L.C.  
 7469 Whitepine Rd  
 Richmond, VA 23237  
 Telephone: 800.347.4010

## Air Metals Analysis Report

Client: Burns & McDonnell Engineering  
 9400 Ward Pkwy.  
 Kansas City, MO 64114

Report Number: 20-12-00697  
 Received Date: 12/07/2020  
 Reported Date: 12/22/2020

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 102E-A-01-102E-A-09

Client Number:  
26-3514

Fax Number:  
816-822-3494

# Laboratory Results

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m <sup>3</sup> )	Narrative ID
20-12-00697-001	102E-A-01	12/09/2020	Arsenic (As)	553	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
20-12-00697-002	102E-A-02	12/09/2020	Arsenic (As)	556	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
20-12-00697-003	102E-A-03	12/09/2020	Arsenic (As)	544	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.056	



# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-00697

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 102E-A-01-102E-A-09

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m <sup>3</sup> )	Narrative ID
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
20-12-00697-004	102E-A-04	12/09/2020	Arsenic (As)	545	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.056	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
20-12-00697-005	102E-A-05	12/09/2020	Arsenic (As)	559	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
20-12-00697-006	102E-A-06	12/09/2020	Arsenic (As)	561	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-00697

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 102E-A-01-102E-A-09

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m <sup>3</sup> )	Narrative ID
20-12-00697-007	102E-A-07	12/09/2020	Arsenic (As)	527	<0.15	<0.29	
			Barium (Ba)		<0.15	<0.29	
			Cadmium (Cd)		<0.030	<0.057	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.29	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.29	
20-12-00697-008	102E-A-08	12/09/2020	Arsenic (As)	536	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.056	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
20-12-00697-009	102E-A-09	12/09/2020	Arsenic (As)	--	<0.15	---	
			Barium (Ba)		<0.15	---	
			Cadmium (Cd)		<0.030	---	
			Chromium (Cr)		<0.75	---	
			Lead (Pb)		<0.15	---	
			Selenium (Se)		<0.75	---	
			Silver (Ag)		<0.15	---	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-00697

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 102E-A-01-102E-A-09

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m <sup>3</sup> )	Narrative ID
Sample Narratives:							

Method: NIOSH 7300M  
Analyst: Brittany Meyer

(b) (6)

Reviewed By Authorized Signatory:

*Tasha Eaddy*  
QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit for each particular metal, based on a 15mL volume. The reporting limit is 0.03ug for Cadmium, 0.15ug for Arsenic, Barium, Lead and Silver, and 0.75ug for Chromium and Selenium.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. EHS sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of the Environmental Hazards Service, L.L.C. California Certification #2319 NY ELAP #11714.

LEGEND	ug = microgram	ug/m <sup>3</sup> = micrograms per cubic meter
	mL = milliliter	L= Liters

# ENVIRONMENTAL HAZARDS SERVICES, LLC

## Metals Chain of Custody Form

Company Name	Burns & McDonnell	Account #	26-3514
Company Address	9400 Ward Parkway	City/State/Zip	Kansas City, MO 64114
Phone	314-302-4661	Email	eaanlemeyer@burns mcd.com
Project Name / Testing Address		GFC / 4300 Goodfellow Blvd	
PO Number	168765	Collected By	Emily Anlemeyer & Jeff Smith
Turn-Around Time	<input checked="" type="radio"/> 3 DAY <input type="radio"/> 2 DAY <input type="radio"/> 1 DAY <input type="radio"/> SAME DAY OR WEEKEND - Must Call Ahead		

LAB NUMBER	Client Sample ID	Collection Date & Time	METALS						Other Metals	PARTICULATES					AIR			WIPES	
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP		CA 17 Total	Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM-10	Total Time	Flow Rate	Vol.	AREA <small>Circle The Unit of Measurement Used</small> cm or in
																Mins.	L/min.	Total Liters	
1	102E-A-01	11/30/2020 1119							Ag. As, Ba, Cd, Cr, Pb, Se						220	2.52	553	X	
2	102E-A-02	1122													218	2.55	556	X	
3	102E-A-03	1124													219	2.49	544	X	
4	102E-A-04	1125													218	2.50	545	X	
5	102E-A-05	1127													219	2.55	559	X	
6	102E-A-06R	12/11/2020 0918													220	2.55	561	X	
7	102E-A-07	11/30/2020 1130													217	2.43	527	X	
8	102E-A-08	1134													218	2.46	536	X	
9	102E-A-09	0953													NA	NA	NA	X	
10																		X	
11																	X		
12																	X		
13																	X		
14																	X		
15																	X		

Released By: Emily Anlemeyer	Date: 12/4/2020	Time: 1600
Signature: (b) (6)		

LAB USE ONLY - BELOW THIS LINE

Received By: Stone

Signature: (b) (6)

Date: 12/7/20 Time: 11:04  AM  PM

Portal Contact Added

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010

RESULTS VIA CLIENT PORTAL AVAILABLE @ [www.leadlab.com](http://www.leadlab.com)

20-12-00697

Due Date:  
12/10/2020  
(Thursday)  
EL

## **APPENDIX C – LICENSES**

**STATE OF MISSOURI  
DEPARTMENT OF HEALTH AND SENIOR SERVICES**

**LEAD OCCUPATION LICENSE REGISTRATION**

Issued to:

**Jeffrey T. Smith**

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

**Lead Risk Assessor**  
Category of License

Issuance Date: **3/16/2019**  
Expiration Date: **3/16/2021**  
License Number: **010316-200089640**



(b) (6)

Randall W. Williams, MD, FACOG  
Director  
Department of Health and Senior Services

Lead Licensing Program, PO Box 570, Jefferson City, MO 65102