



May 6, 2022

Diane Czarnecki
Industrial Hygienist
Facilities Management Division
GSA Public Buildings Service – Heartland Region
2300 Main Street
Kansas City, MO 64108

Re: Goodfellow Federal Center –Building 107 Air and Wipe Sampling Evaluation Addendum
Project No. 121244

Dear Ms. Czarnecki:

Thank you for the opportunity to provide the General Services Administration (GSA) with the above referenced environmental sampling activities. The following is our report.

INTRODUCTION

As requested, Burns & McDonnell conducted area air sampling and wipe sampling for the presence of seven (7) RCRA metals including arsenic, barium, cadmium, chromium, lead, selenium, and silver within the occupied areas of the first floor of building 107 of the Goodfellow Federal Center located at 4300 Goodfellow Boulevard in St. Louis, Missouri. The purpose of the investigation was to provide ongoing sampling data to monitor conditions at the site. This report serves as an addendum to the *Goodfellow Federal Center – Building 107 Air and Wipe Sampling Evaluation*, dated December 27, 2021.

SAMPLING METHODOLOGY

Dust wipe sampling was conducted in accordance with ASTM Standard E1728: *Standard Practice for Collection of Settled Dust Samples Using Wipe Sampling Methods for Subsequent Lead Determination* and ASTM Standard D6966: *Standard Practice for Collection of Settled Dust Samples Using Wipe Sampling Methods for Subsequent Determination of Metals*. ASTM Standards E1728 and D6966 are consistent with the methodology described in the Housing and Urban Development Guidelines-Appendix 13.1 and 40 CFR 745.63. The Brookhaven National Laboratory’s Surface Wipe Sampling Procedure (IH75190) was also used as a guideline.

A representative surface area of approximately one square foot (1 SF) was measured and delineated. The dust wipe samples were collected using dedicated dust wipe cloths meeting ASTM E1792 Standard. Each dust wipe cloth was pre-moistened and individually wrapped. Each sample was collected by wiping in a back and forth “S” pattern over a measured sampling area using a clean, disposable glove. Then, the wipe was folded over itself and the area was wiped again in a direction perpendicular to the first wipe orientation. Then, the wipe folded over itself again and the area was wiped around the perimeter. The wipe sample was then placed into a labeled, clean container.



Diane Czarnecki
Facilities Management Division
May 6, 2022
Page 2

Air samples for RCRA metals were collected on 37-millimeter (mm) cassettes with 0.8 micrometer (μm) mixed cellulose ester (MCE) filters, using powered air sampling pumps, in accordance with the National Institute for Occupational Safety and Health (NIOSH) Method 7300. The sampling strategy included collecting a minimum sample volume of 500 liters based on the calibrated pump flow rate and sample duration.

All samples were submitted under chain-of-custody to Environmental Hazards Services, LLC (EHS) in Richmond, Virginia for independent analysis of 7 RCRA metals. Air samples were analyzed by Inductively Coupled Plasma (ICP) according to NIOSH method 7300. Wipe samples were analyzed according to Environmental Protection Agency (EPA) method SW846-3050B/6010D. EHS is accredited under the American Industrial Hygiene Association (AIHA) Industrial Hygiene Laboratory Accreditation Program (IHLAP) program, identification number LAP-100420.

SAMPLE SUMMARY AND RESULTS

Air and wipe samples were collected on April 26, 2022, by Ashley Anstaett of Burns & McDonnell.

One (1) air sample was collected from the east windowsill between desks in room 106 on the first floor of building 107. All analytes were below laboratory reporting limits. The complete air sampling laboratory report from EHS is included in Appendix A.

Two (2) wipe samples were collected. The sample locations and results are listed below. The complete wipe sampling laboratory report from EHS is included in Appendix B.

- Room 106, center round table on the first floor of building 107
 - Arsenic, barium, chromium, lead, selenium, and silver were all below laboratory reporting limits.
 - Cadmium was detected at 0.34 $\mu\text{g}/\text{sq. ft}$, below the clean area limit of 31 $\mu\text{g}/\text{sq. ft}$.
- Room 106, rectangular conference table near the north wall on the first floor of building 107
 - All analytes were below laboratory reporting limits.

LIMITATIONS

The scope of this assessment was limited in nature. Burns & McDonnell collected samples from a representative number of surfaces in an effort to minimize cost while providing a general overview of site conditions. Sample locations do not encompass all surfaces at the site.



Diane Czarnecki
Facilities Management Division
May 6, 2022
Page 3

Additionally, samples were only analyzed for a select number of potential contaminants. Burns & McDonnell is not responsible for potential contaminants not identified in this report.

Burns & McDonnell appreciates the opportunity to work GSA on this project. Please contact us if you have any questions regarding this report or if we may be of any additional service.

Sincerely,

(b) (6)

A large black rectangular redaction box covers the signature area, with the text "(b) (6)" in red at the top left corner.

Matt Shanahan, CHMM
Project Manager

Attachments:

- Appendix A – Air Sampling Laboratory Report
- Appendix B – Wipe Sampling Laboratory Report

Information in Appendices A and B are not accessible for people using screen reader technology. If this information is required, it can be furnished upon request by contacting 816-223-6198 or r6environmental@gsa.gov.

APPENDIX A – AIR SAMPLING LABORATORY REPORT



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Air Metals Analysis Report

Client: Burns & McDonnell Engineering
 9400 Ward Pkwy.
 Kansas City, MO 64114

Report Number: 22-04-05849
 Received Date: 04/28/2022
 Reported Date: 04/29/2022

Project/Test Address: 168765; GFC / 4300 Goodfellow Blvd

Client Number:
26-3514

Fax Number:
816-822-3494

Laboratory Results

| Lab Sample Number | Client Sample Number | Analyzed Date | Analyte | Air Volume (L) | Total Metal (ug) | Concentration (ug/m ³) | Narrative ID |
|-------------------|----------------------|---------------|---------------|----------------|------------------|------------------------------------|--------------|
| 22-04-05849-001 | 107-A-01 | 04/28/2022 | Arsenic (As) | 702 | <0.15 | <0.22 | |
| | | | Barium (Ba) | | <0.15 | <0.22 | |
| | | | Cadmium (Cd) | | <0.030 | <0.043 | |
| | | | Chromium (Cr) | | <0.75 | <1.1 | |
| | | | Lead (Pb) | | <0.15 | <0.22 | |
| | | | Selenium (Se) | | <0.75 | <1.1 | |
| | | | Silver (Ag) | | <0.15 | <0.22 | |
| 22-04-05849-002 | 107-A-02 | 04/28/2022 | Arsenic (As) | -- | <0.15 | --- | |
| | | | Barium (Ba) | | <0.15 | --- | |
| | | | Cadmium (Cd) | | <0.030 | --- | |
| | | | Chromium (Cr) | | <0.75 | --- | |
| | | | Lead (Pb) | | <0.15 | --- | |
| | | | Selenium (Se) | | <0.75 | --- | |
| | | | Silver (Ag) | | <0.15 | --- | |

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 22-04-05849

Project/Test Address: 168765; GFC / 4300 Goodfellow Blvd

| Lab Sample Number | Client Sample Number | Analyzed Date | Analyte | Air Volume (L) | Total Metal (ug) | Concentration (ug/m ³) | Narrative ID |
|-------------------|----------------------|---------------|---------|----------------|------------------|------------------------------------|--------------|
|-------------------|----------------------|---------------|---------|----------------|------------------|------------------------------------|--------------|

Sample Narratives:

Method: NIOSH 7300M
Analyst: Ailea Cabatbat

(b) (6)

Reviewed By Authorized Signatory:

Tasha Eaddy
QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit for each particular metal, based on a 15mL volume. The reporting limit is 0.03ug for Cadmium, 0.15ug for Arsenic, Barium, Lead and Silver, and 0.75ug for Chromium and Selenium.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. These sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of Environmental Hazards Services, L.L.C. NY ELAP #11714.

LEGEND ug = microgram ug/m³ = micrograms per cubic meter
 mL = milliliter L = Liters


Metals Chain of Custody Form

| Company Name: Burns & McDonnell | | Account #: 25-3514 | | | | | | | | | | | | | | |
|---|------------------------|---------------------------------------|--------------------------|---------------------|----------------------|------------|----------------------|--------------|---------------------|-----------------|-----------------|--------|---------|------------|--------------|----------|
| Company Address: 9400 Ward Parkway | | City/State/Zip: Kansas City, MO 64114 | | | | | | | | | | | | | | |
| Phone: 314-302-4661 | | Email: eapulcher@burnsmcd.com | | | | | | | | | | | | | | |
| Project Name / Testing Address: GFC / 4300 Goodfellow Blvd | | | | | | | | | | | | | | | | |
| PO Number: 168765 | | Collected By: _____ | | | | | | | | | | | | | | |
| Turn-Around Time: <input checked="" type="checkbox"/> 5 DAY <input type="checkbox"/> 3 DAY <input type="checkbox"/> 2 DAY <input type="checkbox"/> 1 DAY <input type="checkbox"/> SAME DAY OR WEEKEND - Must Call Ahead | | | | | | | | | | | | | | | | |
| Client Sample ID | Collection Date & Time | METALS | | | | | | PARTICULATES | | | | AIR | | WIPES | | |
| | | Pb TCLP | TCLP RCRA & RCRA & Total | Toxic Metal Profile | Welding Fume Profile | TX 11 TCLP | CA17 Total | Other Metals | Total Nuisance Dust | Respirable Dust | TSP Gravimetric | TSP Pb | PM10-10 | Total Time | Flow Rate | Area |
| | | | | | | | Ag As Ba Cd Cr Pb Se | | | | | | Mass | Level | Total Liters | cm or in |
| 107-A-01 | 4/26/22 1251 | | | | | | | | | | | | 278 | - | 702 | x |
| 107-A-02 | 1300 | | | | | | | | | | | | | | | x |
| 107-W-01 | 1300 | | | | | | | | | | | | | | | 12 x 12 |
| 107-W-02 | 1303 | | | | | | | | | | | | | | | 12 x 12 |
| 107-W-03 | 1255 | | | | | | | | | | | | | | | NA x NA |
| | | | | | | | | | | | | | | | | x |
| | | | | | | | | | | | | | | | | x |
| | | | | | | | | | | | | | | | | x |
| | | | | | | | | | | | | | | | | x |
| | | | | | | | | | | | | | | | | x |
| | | | | | | | | | | | | | | | | x |
| | | | | | | | | | | | | | | | | x |
| | | | | | | | | | | | | | | | | x |
| Released By: A Anstaett | | Date: 4/27/22 | | Time: 0900 | | | | | | | | | | | | |
| Signature: (b) (6) | | | | | | | | | | | | | | | | |

LAB USE ONLY - BELOW THIS LINE

Received By: A Walker
 Signature: _____
 Date: 4/28/22 Time: 10:47 AM PM

22-04-05849



Due Date:
05/05/2022
(Thursday)
EL MM-L

Portal Contact Added

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010

RESULTS VIA CLIENT PORTAL AVAILABLE @ www.leadlab.com

APPENDIX B – WIPE SAMPLING LABORATORY REPORT



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Wipe Metals Analysis Report

Client: Burns & McDonnell Engineering
 9400 Ward Pkwy.
 Kansas City, MO 64114

Report Number: 22-04-05855

Received Date: 04/28/2022

Analyzed Date: 04/28/2022

Reported Date: 04/29/2022

Project/Test Address: 168765; GFC / 4300 Goodfellow Blvd

Client Number:
 26-3514

Laboratory Results

Fax Number:
 816-822-3494

| Lab Sample Number | Client Sample Number | Analyte: | Wipe Area (ft ²) | Total Metal (ug) | Concentration (ug/ft ²) | Narrative ID |
|-------------------|----------------------|---------------|------------------------------|------------------|-------------------------------------|--------------|
| 22-04-05855-001 | 107-W-01 | Arsenic (As) | 1.00 | <2.50 | <2.5 | |
| | | Barium (Ba) | 1.00 | <0.500 | <0.50 | |
| | | Cadmium (Cd) | 1.00 | 0.340 | 0.34 | |
| | | Chromium (Cr) | 1.00 | <1.00 | <1.0 | |
| | | Lead (Pb) | 1.00 | <0.500 | <0.50 | |
| | | Selenium (Se) | 1.00 | <2.50 | <2.5 | |
| | | Silver (Ag) | 1.00 | <0.500 | <0.50 | |
| 22-04-05855-002 | 107-W-02 | Arsenic (As) | 1.00 | <2.50 | <2.5 | |
| | | Barium (Ba) | 1.00 | <0.500 | <0.50 | |
| | | Cadmium (Cd) | 1.00 | <0.100 | <0.10 | |
| | | Chromium (Cr) | 1.00 | <1.00 | <1.0 | |

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 22-04-05855

Project/Test Address: 168765; GFC / 4300 Goodfellow Blvd

| Lab Sample Number | Client Sample Number | Analyte: | Wipe Area (ft ²) | Total Metal (ug) | Concentration (ug/ft ²) | Narrative ID |
|-------------------|----------------------|---------------|------------------------------|------------------|-------------------------------------|--------------|
| | | Lead (Pb) | 1.00 | <0.500 | <0.50 | |
| | | Selenium (Se) | 1.00 | <2.50 | <2.5 | |
| | | Silver (Ag) | 1.00 | <0.500 | <0.50 | |
| 22-04-05855-003 | 107-W-03 | Arsenic (As) | | <2.50 | --- | |
| | | Barium (Ba) | | <0.500 | --- | |
| | | Cadmium (Cd) | | <0.100 | --- | |
| | | Chromium (Cr) | | <1.00 | --- | |
| | | Lead (Pb) | | <0.500 | --- | |
| | | Selenium (Se) | | <2.50 | --- | |
| | | Silver (Ag) | | <0.500 | --- | |

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 22-04-05855

Project/Test Address: 168765; GFC / 4300 Goodfellow Blvd

| Lab Sample Number | Client Sample Number | Analyte: | Wipe Area (ft ²) | Total Metal (ug) | Concentration (ug/ft ²) | Narrative ID |
|-------------------|----------------------|----------|------------------------------|------------------|-------------------------------------|--------------|
|-------------------|----------------------|----------|------------------------------|------------------|-------------------------------------|--------------|

Sample Narratives:

Analyst: Ailea Cabatbat

Method: Mercury (Hg): EPA SW846 7471B

All other metals: EPA SW846 3050B/6010D

(b) (6)



Reviewed By Authorized Signatory:

Tasha Eaddy

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit for each particular metal, based on a 50mL volume. The reporting limit for Cadmium is 0.10ug, Barium, Lead and Silver are 0.50ug, Arsenic and Chromium are 1.0ug, and Selenium is 2.5ug.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. These sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of Environmental Hazards Services, L.L.C. NY ELAP #11714.

| | | |
|--------|-----------------|---|
| Legend | ug = microgram | ug/ft ² = micrograms per square foot |
| | mL = milliliter | ft ² = square foot |

ENVIRONMENTAL HAZARDS SERVICES, LLC

Metals Chain of Custody Form

Company Name: Burns & McDonnell

Account #: 26-3514

Company Address: 9400 Ward Parkway

City/State/Zip: Kansas City, MO 64114

Phone: 314-302-4661

Email: eapulcher@burnsmcd.com

Project Name / Testing Address: GFC / 4300 Goodfellow Blvd

PO Number: 168765

Collected By:

Turn-Around Time

5 DAY

3 DAY

2 DAY

1 DAY

SAME DAY OR WEEKEND - Must Call Ahead

| Client Sample ID | Collection Date & Time | METALS | | | | | | | Other Metals Ag, As, Ba, Cd, Cr, Pb, Se | PARTICULATES | | | | | AIR | | | WIPES AREA Circle the Unit of Measurement Used cm ² or (in) |
|--------------------------|------------------------|---------|-------------|--------------|---------------------|----------------------|------------|-------------|--|---------------------|-----------------|-----------------|--------|-------|------------|-----------|--------------|---|
| | | Pb TCLP | TCLP RCRA 8 | RCRA 8 Total | Toxic Metal Profile | Welding Fume Profile | TX 11 TCLP | CA 17 Total | | Total Nuisance Dust | Respirable Dust | TSP Gravimetric | TSP Pb | PM-10 | Total Time | Flow Rate | Vol. | |
| | | | | | | | | | | | | | | | Mins | L/min | Total Liters | |
| 107-A-01 | 4/26/22 1251 | | | | | | | | | | | | 278 | - | 702 | X | | |
| 107-A-02 | 1300 | | | | | | | | | | | | - | - | - | X | | |
| 107-W-01 | 1300 | | | | | | | | | | | | | | | 12 x 12 | | |
| 107-W-02 | 1303 | | | | | | | | | | | | | | | 12 x 12 | | |
| 107-W-03 | 1255 | | | | | | | | | | | | | | | NA x NA | | |
| | | | | | | | | | | | | | | | | X | | |
| | | | | | | | | | | | | | | | | X | | |
| | | | | | | | | | | | | | | | | X | | |
| | | | | | | | | | | | | | | | | X | | |
| | | | | | | | | | | | | | | | | X | | |
| | | | | | | | | | | | | | | | | X | | |
| | | | | | | | | | | | | | | | | X | | |
| | | | | | | | | | | | | | | | | X | | |
| | | | | | | | | | | | | | | | | X | | |
| | | | | | | | | | | | | | | | | X | | |
| | | | | | | | | | | | | | | | | X | | |
| | | | | | | | | | | | | | | | | X | | |
| | | | | | | | | | | | | | | | | X | | |
| Released By: A. Anstaett | | | | | | | | | Date: 4/27/22 | Time: 0900 | | | | | | | | |
| Signature: (b) (6) | | | | | | | | | | | | | | | | | | |

LAB USE ONLY - BELOW THIS LINE


Received By: A. Walker
Signature: (b) (6)

Date: 4/28/22 Time: 10:47 AM PM

Portal Contact Added

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010
RESULTS VIA CLIENT PORTAL AVAILABLE @ www.leadlab.com

22-04-05855



Due Date:
05/05/2022
(Thursday)
EL MM-L