



October 11, 2022  
Diane Czarnecki  
Industrial Hygienist  
Facilities Management Division  
GSA Public Buildings Service – Heartland Region  
2300 Main Street  
Kansas City, MO 64108

Re: Goodfellow Federal Center – Bldg. 105L Drinking Water Sampling  
Project No. 121244

Dear Ms. Czarnecki:

Thank you for the opportunity to provide the General Services Administration (GSA) with the above referenced environmental sampling activities. The following is our report.

## **INTRODUCTION**

As requested, Burns & McDonnell conducted drinking water sampling and testing for the presence of lead and copper at Building 105L of the Goodfellow Federal Center located at 4300 Goodfellow Boulevard in St. Louis, Missouri. Sampling was completed in response to the ongoing environmental condition assessment at the Goodfellow Federal Center which is documented at the Goodfellow Federal Center Reading Room located at <https://www.gsa.gov/portal/content/212361>.

Drinking water sampling was conducted to determine the current levels of lead and copper in representative sources throughout the complex. Drinking water sampling at Bldg. 105L was conducted on September 13, 2022 by Ashley Anstaett of Burns & McDonnell & Justin Arnold of OCCU-TEC.

## **METHODOLOGY**

The sampling methodology used during this investigation was developed in general accordance with the United States Environmental Protection Agency's (EPA) "Quick Guide to Drinking Water Sample Collection – Second Edition" developed by the EPA Region 8 in September 2016.

Samples were collected as first draw samples in accordance with the Lead and Copper Rule (40 CFR Part 141 Subpart I). First draw samples represent 'worst case' conditions with water that has been stationary within the plumbing systems for a minimum of six hours. The samples were collected in individually labeled 1000 milliliter (mL) plastic bottles capped with Teflon septa lined screw caps. The bottles were filled to the shoulder with water from the sample source. The samples were then placed in a cooler for safe transport. Each sample was acidified at the laboratory as needed.

Diane Czarnecki  
 Facilities Management Division  
 October 11, 2022  
 Page 2

Drinking water sampling for the presence of lead and copper was conducted at one (1) distinct locations within Building 105L. A total of two (2) samples were obtained including duplicate samples. After each drinking water sample was collected, Burns & McDonnell filled a separate sample cup with approximately 2 inches of water. Burns & McDonnell placed an Oakton EcoTestr pH and temperature meter into the sample cup. After readings stabilized, Burns & McDonnell recorded the readings for pH (the acidity or basicity of an aqueous solution) and the temperature (in degrees Celsius) on site specific sample logs.

Drinking water samples were submitted to Eurofins-Eaton Analytical in South Bend, IN for analyses of lead and copper. Eurofins-Eaton Analytical is certified by the State of Missouri Department of Natural Resources (MDNR) as an approved drinking water laboratory. Eurofins-Eaton Analytical’s Missouri Certification number is 880.

The drinking water samples were collected using media supplied by Eurofins-Eaton Analytical. Lead and Copper samples were collected and analyzed in accordance with EPA Method 200.8.

**RESULTS AND DISCUSSION**

The results for the subject testing are summarized in the table below.

<b>Analysis</b>	<b>Lowest Concentration<sup>(a)</sup></b>	<b>Highest Concentration<sup>(a)</sup></b>	<b>Action Level<sup>(b)</sup></b>
Lead	1.1 µg/L	1.2 µg/L	15 µg/L
Copper	32 µg/L	33 µg/L	1300 µg/L

Notes:

- (a) Samples with a “<” sign indicate that the results were below the reportable limit.
- (b) As per EPA Lead and Copper Rule (40 CFR Part 141 Subpart I).
- (c) µg/L – micrograms per liter

No samples resulted in lead or copper concentrations over the action levels.

A summary table of all sampling results by location is included in Appendix A. The complete laboratory report for the drinking water sampling from Eurofins-Eaton Analytical is attached in Appendix B.

**pH**

Normal pH levels for drinking water are between 6.0 to 8.5. Water with a pH < 6.5 is considered acidic, soft, and corrosive. Acidic water may contain metal ions, may cause premature damage to metal piping, and increases the likelihood of leaching. Water with a pH > 8.5 is considered alkaline or basic and can indicate that the water is hard. Hard water does not pose a health risk



Diane Czarnecki  
Facilities Management Division  
October 11, 2022  
Page 3

but can cause aesthetic problems. These problems include an alkali taste, the formation of scale deposits, and difficulty in getting soaps and detergents to lather.

Recorded pH levels in Building 105L ranged from 9.89 to 9.89 indicating the drinking water is slightly alkaline.

### **LIMITATIONS**

The scope of this assessment was limited in nature. Burns & McDonnell collected samples from a select number of drinking water sources in an effort to minimize cost while providing a general overview of the drinking water quality at the site. Sample locations do not encompass every drinking water source at the Site. Additionally, samples were only analyzed for a select number of potential contaminants likely to affect the drinking water quality at the site. Burns & McDonnell is not responsible for potential contaminants not identified in this report.

Burns & McDonnell appreciates the opportunity to work with the GSA on this project. Please contact us if you have any questions regarding this report or if we may be of any additional service.

Sincerely,

(b) (6)

A large black rectangular redaction box covers the signature area, with the text "(b) (6)" in red at the top left corner.

Matt Shanahan, CHMM  
Project Manager

### Attachments:

- Appendix A - Results Summary by Location
- Appendix B - Water Sample Laboratory Report

**APPENDIX A – RESULTS SUMMARY BY LOCATION**

## Appendix A

### Results Summary by Location

Sample Number	Location	pH	Temp (°C)	Water Source	Analyte	Result	Units	Above / Below	AL
105L-DW-01	South of break room	9.9	19.1	DF	Copper	33	µg/L	Below	1300
105L-DW-01	South of break room	9.9	19.1	DF	Lead	1.2	µg/L	Below	15
105L-DW-02	Duplicate of 105L-DW-01	9.9	19.1	DF D	Copper	32	µg/L	Below	1300
105L-DW-02	Duplicate of 105L-DW-01	9.9	19.1	DF D	Lead	1.1	µg/L	Below	15

Notes:

D - Duplicate

DF - Drinking Fountain

AL - Action Level

µg/L - micrograms per liter

**APPENDIX B – WATER SAMPLE LABORATORY REPORT**

## ANALYTICAL REPORT

Eurofins Eaton South Bend  
110 S Hill Street  
South Bend, IN 46617  
Tel: (574)233-4777

Laboratory Job ID: 810-38472-1  
Client Project/Site: Burns & McDonnell

For:  
Burns & McDonnell  
425 South Woods Mill Road  
Chesterfield, Missouri 63017

Attn: Mr. Matt Shanahan

(b) (6)

Authorized for release by:  
10/6/2022 9:43:34 AM

Amanda Scott, Project Manager  
(574)233-4777  
[Amanda.Scott@et.eurofinsus.com](mailto:Amanda.Scott@et.eurofinsus.com)

### LINKS

Review your project  
results through



Have a Question?



Visit us at:

[www.eurofinsus.com/Env](http://www.eurofinsus.com/Env)

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.



# Table of Contents

Cover Page . . . . .	1
Table of Contents . . . . .	2
Definitions/Glossary . . . . .	3
Case Narrative . . . . .	4
Client Sample Results . . . . .	5
Lab Chronicle . . . . .	6
Certification Summary . . . . .	7
Method Summary . . . . .	8
Sample Summary . . . . .	9
Chain of Custody . . . . .	10
Receipt Checklists . . . . .	11



# Definitions/Glossary

Client: Burns & McDonnell  
Project/Site: Burns & McDonnell

Job ID: 810-38472-1

## Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
▫	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

# Case Narrative

Client: Burns & McDonnell  
Project/Site: Burns & McDonnell

Job ID: 810-38472-1

---

**Job ID: 810-38472-1**

---

**Laboratory: Eurofins Eaton South Bend**

---

**Narrative**

**Job Narrative**  
**810-38472-1**

**Receipt**

The samples were received on 9/22/2022 9:15 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice.

**Metals**

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.



# Client Sample Results

Client: Burns & McDonnell  
 Project/Site: Burns & McDonnell

Job ID: 810-38472-1

**Client Sample ID: 105L-DW-01**

**Lab Sample ID: 810-38472-1**

Date Collected: 09/13/22 05:04

Matrix: Drinking Water

Date Received: 09/22/22 09:15

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.2		0.50	ug/L			10/05/22 19:58	1
Copper	33		1.0	ug/L			10/05/22 19:58	1

**Client Sample ID: 105L-DW-02**

**Lab Sample ID: 810-38472-2**

Date Collected: 09/13/22 05:04

Matrix: Drinking Water

Date Received: 09/22/22 09:15

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1		0.50	ug/L			10/05/22 20:01	1
Copper	32		1.0	ug/L			10/05/22 20:01	1



# Lab Chronicle

Client: Burns & McDonnell  
Project/Site: Burns & McDonnell

Job ID: 810-38472-1

**Client Sample ID: 105L-DW-01**

**Date Collected: 09/13/22 05:04**

**Date Received: 09/22/22 09:15**

**Lab Sample ID: 810-38472-1**

**Matrix: Drinking Water**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	34370	JK	EA SB	10/05/22 19:58

**Client Sample ID: 105L-DW-02**

**Date Collected: 09/13/22 05:04**

**Date Received: 09/22/22 09:15**

**Lab Sample ID: 810-38472-2**

**Matrix: Drinking Water**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	34370	JK	EA SB	10/05/22 20:01

**Laboratory References:**

EA SB = Eurofins Eaton South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777



# Accreditation/Certification Summary

Client: Burns & McDonnell  
Project/Site: Burns & McDonnell

Job ID: 810-38472-1

## Laboratory: Eurofins Eaton South Bend

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Missouri	State	880	09-30-24



# Method Summary

Client: Burns & McDonnell  
Project/Site: Burns & McDonnell

Job ID: 810-38472-1

---

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	EA SB

---

**Protocol References:**

EPA = US Environmental Protection Agency

**Laboratory References:**

EA SB = Eurofins Eaton South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777



# Sample Summary

Client: Burns & McDonnell  
Project/Site: Burns & McDonnell

Job ID: 810-38472-1

---

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
810-38472-1	105L-DW-01	Drinking Water	09/13/22 05:04	09/22/22 09:15
810-38472-2	105L-DW-02	Drinking Water	09/13/22 05:04	09/22/22 09:15





Eaton Analytical



810-38472 Chain of Custody

10 S. Hill Street  
 South Bend, IN 46617  
 T: 1.800.332.4345  
 F: 1.574.233.8207

Order #  
 Batch #

Page 1 of 1

CHAIN OF CUSTODY RECORD

Shaded area for EEA use only

REPORT TO: **capulcher@burnswcd.com** SAMPLER (Signature): [Redacted] PWS ID #: **MD** STATE (sample origin): **MD** PROJECT NAME: **GFC** PO#: **121244**

BILL TO: **capulcher@burnswcd.com** COMPLIANCE MONITORING: **Yes** POPULATION SERVED: **Lead & Copper** SOURCE WATER: **Lead & Copper** TEST NAME: **Lead & Copper** PRESERVATIVE CHECKS: **X** CHLORINATED: **X** # OF CONTAINERS: **1 DW SW**

LAB Number	COLLECTION		SAMPLING SITE	TEST NAME	DATE	TIME	RECEIVED BY (Signature)	DATE	TIME	LAB COMMENTS
	DATE	TIME								
1	9-13-22	0504	X	105L-DW-01	9/13/22	0504	X	0915	ambient	
2	9-13-22	0504	X	105L-DW-02	9/13/22	0504	X	0915	ambient	
3										
4										
5										
6										
7										
8										
9										
10										
11										
12										
13										
14										

RELINQUISHED BY (Signature): [Redacted] DATE: 9/20 TIME: 4:30 PM RECEIVED BY (Signature): [Redacted] DATE: 9/15 TIME: 0915 AM

RELINQUISHED BY (Signature): [Redacted] DATE: 9/20 TIME: 4:30 PM RECEIVED BY (Signature): [Redacted] DATE: 9/15 TIME: 0915 AM

RECEIVED FOR LABORATORY BY: [Redacted] DATE: 9/15 TIME: 0915 AM

CONDITIONS UPON RECEIPT (check one):  
 Iced  Wet/Blue  Ambient  C Upon Receipt

MATRIX CODES:  
 DW-DRINKING WATER RW-REAGENT WATER GW-  
 GROUND WATER WE-EXPOSURE WATER SW-  
 SURFACE WATER PW-POOL WATER  
 WW-WASTE WATER

TURN-AROUND TIME (TAT) - SURCHARGES  
 SW = Standard Written (15 working days) 0% RV = Rush Verbal (5 working days)  
 50% RW = Rush Written (5 working days) 75%  
 \* Please call, expedited service not available for all testing

IV = Immediate Verbal (3 working days) 100%  
 Immediate Written (3 working days) SP = 125%  
 Weekend Holiday CALL  
 STAT = Less than 48 hours

Sample analysis will be provided according to the standard EEA Water Services Terms, which are available upon request. Any other terms proposed by Customer are deemed material alterations and are rejected unless expressly agreed to in writing by EEA.



## Login Sample Receipt Checklist

Client: Burns & McDonnell

Job Number: 810-38472-1

**Login Number: 38472**

**List Source: Eurofins Eaton South Bend**

**List Number: 1**

**Creator: Wojcik, Mary**

Question	Answer	Comment
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
Samples were received on ice.	False	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	False	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

