



100 NW Business Park Lane
Riverside, MO 64150
Telephone: 816.231.5580
Fax: 816.231.5641
www.occutec.com

June 8, 2018

Ms. Diane Czarnecki
Industrial Hygienist
Facilities Management Division
GSA Public Buildings Service – Heartland Region
2300 Main Street
Kansas City, Missouri 64108

**RE: Goodfellow Federal Center - Metals in Air Investigation
Buildings – 103F
4300 Goodfellow Boulevard
St. Louis, Missouri 63120
OCCU-TEC Project No. 918004**

Dear Ms. Czarnecki:

Thank you for the opportunity to assist the General Services Administration (GSA) with the Resource Conservation and Recovery Act (RCRA) metals air sampling investigation of the above referenced buildings located at the Goodfellow Federal Complex, in St. Louis, Missouri. OCCU-TEC, Inc. (OCCU-TEC) understands that the purpose of the investigation was to provide sampling data regarding pre-existing conditions noted in investigation reports previously prepared for the facility. The following report summarizes the sample collection activities and the laboratory analytical results of the samples submitted.

On April 10, 2018, Missouri licensed air sampling professionals from OCCU-TEC conducted air sampling for the presence of seven (7) of the RCRA metals including Silver, Arsenic, Barium, Cadmium, Chromium, Lead, and Selenium. Sampling was conducted at Building 103F.

The proposed sampling scheme, the numbers of samples, sample distribution and general methodology was developed based on previous investigation methodology and in coordination with the GSA. Sample locations and samples collected from discretionary locations were determined by OCCU-TEC field personnel while on-site.

Resource Conservation and Recovery Act Metals Air Sampling

Air sampling for RCRA metals was collected on 37-millimeter (mm) cassettes with 0.8 micrometer (μm) mixed cellulose ester (MCE) filters using powered air sampling pumps in accordance with National Institute for Occupational Safety and Health (NIOSH) sampling methodology. Samples were collected in a method sufficient to collect a minimum sample volume of 300 liters. Air samples were submitted under chain-of-custody to Scientific Analytical Institute, Inc. (SAI), for independent analysis of RCRA metals according to NIOSH method 7300. SAI is accredited by the American Industrial Hygiene Association (AIHA) utilizing the Industrial Hygiene Proficiency Analytical Testing (IHPAT) program. SAI's AIHA IHPAT Laboratory identification number is 173190.

Results of the air sampling are summarized in the table below by identifying the range of results for Building 103F for each of the seven (7) metals that were sampled. **Samples with a “<” sign indicate that the results were below the laboratory’s method reporting limit.**

Analysis	Lowest Concentration ($\mu\text{g}/\text{m}^3$)	Highest Concentration ($\mu\text{g}/\text{m}^3$)
Silver Ag	<5.6	<5.6
Arsenic As	<0.77	<0.77
Barium Ba	<0.056	<0.56
Cadmium Cd	<0.077	<0.077
Total Chromium Cr	<5.6	<5.6
Lead Pb	<0.40	0.99
Selenium Se	<0.77	<0.77

Results indicate that the seven (7) air samples collected from Building 103F contained concentrations of RCRA metals below laboratory reporting limit or the OSHA Permissible Exposure Assessment (PEL). Sample locations and the corresponding result are summarized in the enclosed laboratory analytical report. The air sampling professional's Missouri Lead license is included in Appendix B.

It should be noted that this air sampling investigation was only a screening of airborne RCRA metals and should not be interpreted or used to determine compliance or non-compliance with OSHA personnel monitoring regulations.

OCCU-TEC appreciates the opportunity to work with GSA on this project. If you have any questions concerning this report, or if we may be of any additional service, please feel free to contact us.

Sincerely,

(b) (6)
[Redacted Signature]

Justin Arnold
Environmental Scientist.

(b) (6)
[Redacted Signature]

Kevin Heriford
Project Manager (QA/QC)

Appendices:

- A: Laboratory Analytical Results and Chain of Custody Documentation
- B: Qualifications and Licenses



Appendix A

Laboratory Analytical Report and Chain of Custody Documentation





Airborne Metals Concentration by Inductively-Coupled Plasma Analysis (ICP)

NIOSH Method 7300



Client: Occu-Tec, Inc. 100 NW Business Park Ln. Riverside, MO 64150	Attn: Justin Arnold	Lab Order ID: 11809547
		Date Received: 04/17/2018
		Date Reported: 04/27/2018
		Date Amended: 05/01/2018
Project: 918004.002		Page: 1 of 4

Sample ID	Description	Volume (L)	Element	Reporting Limit (µg)	Concentration (µg)	Concentration (µg/m ³)
Lab Sample ID	Lab Notes					
103F-MetA18-01	Column D12	323.2	Ag	1.8	<1.8	<5.6
			As	0.25	<0.25	<0.77
			Ba	0.18	<0.18	<0.56
			Cd	0.025	<0.025	<0.077
			Cr	1.8	<1.8	<5.6
11809547IPA_1			Pb	0.13	< 0.13	< 0.40
			Se	0.25	< 0.25	< 0.77
103F-MetA18-02	Column F9	323.2	Ag	1.8	<1.8	<5.6
			As	0.25	<0.25	<0.77
			Ba	0.18	<0.18	<0.56
			Cd	0.025	<0.025	<0.077
			Cr	1.8	<1.8	<5.6
11809547IPA_2			Pb	0.13	<0.13	<0.40
			Se	0.25	<0.25	<0.77

Melissa Ferrell/Daniel Olson

Analyst

(b) (6)

Lab Director

This report relates only to the samples tested and may not be reproduced, except in full, without the written approval of SAI. This report may not be used by the client to claim product endorsement by AIHA or any other agency of the U.S. government. Scientific Analytical Institute participates in the AIHA IHPAT program. IHPAT Laboratory ID: 173190. Unless otherwise noted blank sample correction was not performed on analytical results. MDLs are available upon request. Reporting limits stated above.



Airborne Metals Concentration by Inductively-Coupled Plasma Analysis (ICP)

NIOSH Method 7300



Client: Occu-Tec, Inc. 100 NW Business Park Ln. Riverside, MO 64150	Attn: Justin Arnold	Lab Order ID: 11809547 Date Received: 04/17/2018 Date Reported: 04/27/2018 Date Amended: 05/01/2018
Project: 918004.002		Page: 2 of 4

Sample ID	Description	Volume (L)	Element	Reporting Limit (µg)	Concentration (µg)	Concentration (µg/m ³)
Lab Sample ID	Lab Notes					
103F-MetA18-03	Column B7	323.2	Ag	1.8	<1.8	<5.6
			As	0.25	<0.25	<0.77
			Ba	0.18	<0.18	<0.56
			Cd	0.025	<0.025	<0.077
			Cr	1.8	<1.8	<5.6
			Pb	0.13	<0.13	<0.40
11809547IPA_3			Se	0.25	<0.25	<0.77
103F-MetA18-04	Column C4	323.2	Ag	1.8	<1.8	<5.6
			As	0.25	<0.25	<0.77
			Ba	0.18	<0.18	<0.056
			Cd	0.025	<0.025	<0.077
			Cr	1.8	<1.8	<5.6
			Pb	0.13	<0.13	<0.40
11809547IPA_4			Se	0.25	<0.25	<0.77

Melissa Ferrell/Daniel Olson

Analyst

(b) (6)


Lab Director

This report relates only to the samples tested and may not be reproduced, except in full, without the written approval of SAI. This report may not be used by the client to claim product endorsement by AIHA or any other agency of the U.S. government. Scientific Analytical Institute participates in the AIHA IHPAT program. IHPAT Laboratory ID: 173190. Unless otherwise noted blank sample correction was not performed on analytical results. MDLs are available upon request. Reporting limits stated above.



Airborne Metals Concentration by Inductively-Coupled Plasma Analysis (ICP)

NIOSH Method 7300



Client: Occu-Tec, Inc. 100 NW Business Park Ln. Riverside, MO 64150	Attn: Justin Arnold	Lab Order ID: 11809547
		Date Received: 04/17/2018
		Date Reported: 04/27/2018
		Date Amended: 05/01/2018
Project: 918004.002		Page: 3 of 4

Sample ID	Description	Volume (L)	Element	Reporting Limit (µg)	Concentration (µg)	Concentration (µg/m ³)
Lab Sample ID	Lab Notes					
103F-MetA18-05	Column E3	323.2	Ag	1.8	<1.8	<5.6
			As	0.25	<0.25	<0.77
			Ba	0.18	<0.18	<0.56
			Cd	0.025	<0.025	<0.077
			Cr	1.8	<1.8	<5.6
11809547IPA_5			Pb	0.13	<0.13	<0.40
			Se	0.25	<0.25	<0.77
103F-MetA18-06	Exterior Roof	323.2	Ag	1.8	<1.8	<5.6
			As	0.25	<0.25	<0.77
			Ba	0.18	<0.18	<0.56
			Cd	0.025	<0.025	<0.077
			Cr	1.8	<1.8	<5.6
11809547IPA_6			Pb	0.13	0.32	0.99
			Se	0.25	<0.25	<0.77

Melissa Ferrell/Daniel Olson

Analyst

(b) (6)


Lab Director

This report relates only to the samples tested and may not be reproduced, except in full, without the written approval of SAI. This report may not be used by the client to claim product endorsement by AIHA or any other agency of the U.S. government. Scientific Analytical Institute participates in the AIHA IHPAT program. IHPAT Laboratory ID: 173190. Unless otherwise noted blank sample correction was not performed on analytical results. MDLs are available upon request. Reporting limits stated above.



Airborne Metals Concentration by Inductively-Coupled Plasma Analysis (ICP)

NIOSH Method 7300



Client:	Occu-Tec, Inc. 100 NW Business Park Ln. Riverside, MO 64150	Attn: Justin Arnold	Lab Order ID: 11809547	Date Received: 04/17/2018
			Date Reported: 04/27/2018	Date Amended: 05/01/2018
Project: 918004.002			Page: 4 of 4	

Sample ID	Description	Volume (L)	Element	Reporting Limit (µg)	Concentration (µg)	Concentration (µg/m ³)
<i>Lab Sample ID</i>	<i>Lab Notes</i>					
103F-MetA18-07	<i>Blank</i>	-	Ag	1.8	<1.8	-
			As	0.25	<0.25	-
			Ba	0.18	<0.18	-
			Cd	0.025	<0.025	-
			Cr	1.8	<1.8	-
11809547IPA_7			Pb	0.13	0.40	-
			Se	0.25	<0.25	-

Melissa Ferrell/Daniel Olson

Analyst

(b) (6)

Lab Director

This report relates only to the samples tested and may not be reproduced, except in full, without the written approval of SAI. This report may not be used by the client to claim product endorsement by AIHA or any other agency of the U.S. government. Scientific Analytical Institute participates in the AIHA IHPAT program. IHPAT Laboratory ID: 173190. Unless otherwise noted blank sample correction was not performed on analytical results. MDLs are available upon request. Reporting limits stated above.

Appendix B

Qualifications and Licenses





Missouri Department of Health and Senior Services

P.O. Box 570, Jefferson City, MO 65102-0570 Phone: 573-751-6400 FAX: 573-751-6010
RELAY MISSOURI for Hearing and Speech Impaired 1-800-735-2966 VOICE 1-800-735-2466

Peter Lyskowski
Acting Director



Jeremiah W. (Jay) Nixon
Governor

May 27, 2016

Justin Arnold
Occu-Tec, Inc.
100 NW Business Park Lane
Riverside, MO 64150

Dear Licensee:

After review of your renewal application for a license with the Missouri Department of Health and Senior Services' Lead Licensing Program, your application for a Lead Risk Assessor license has been approved.

Enclosed is your Lead Risk Assessor license certificate and photo identification badge. Please have your identification badge with you at all times while conducting lead abatement activities.

Note the date your Lead Risk Assessor license expires. A renewal application and information will be mailed to you approximately three months before your license expiration date and will need to be completed and submitted 60 days prior to the expiration date.

A requirement of renewing your application will be attending a Lead Risk Assessor refresher class. A list of Missouri accredited lead abatement training providers will be included in your renewal packet. Additional information on training and lead abatement in general can be found at <http://health.mo.gov/safety/leadlicensing/index.php>.

Please contact the Lead Licensing Program at (573) 526-5873 or (888) 837-0927 if you have any questions concerning this letter or on lead abatement regulations in general.

Sincerely,

(b) (6)

Angie DeBroeck
Lead Licensing Program

AKD:ss

Enclosures



www.health.mo.gov

Healthy Missourians for
The Missouri Department of Health and Senior Services will be the lead

Expiration Date: **N/A**

Certificate Number: 7070111MOASP13670

Training Date: **7/1/2011**

Missouri State Certificate for Asbestos Related Occupations

issued by Department of Natural Resources

P.O. Box 176

Jefferson City, MO 65102

Phone (573) 751-4817

Justin E. Arnold

has successfully completed the requirements for certification as a AIR SAMPLING PROFESSIONAL. This Missouri State Certification is subject to review and the director may deny, suspend or revoke the certification per RSMo chapter 643.230.

7/5/2011

Date

(b) (6)

Director of Air Pollution Control Program



Expiration Date: **N/A**

Certificate Number: 7070111MOASP13670

Training Date: **7/1/2011**

Missouri State Certificate for Asbestos Related Occupations

issued by Department of Natural Resources

P.O. Box 176

Jefferson City, MO 65102

Phone (573) 751-4817

Justin E. Arnold

has successfully completed the requirements for certification as a AIR SAMPLING PROFESSIONAL. This Missouri State Certification is subject to review and the director may deny, suspend or revoke the certification per RSMo chapter 643.230.

7/5/2011

Date


Director of Air Pollution Control Program

