



July 23, 2020

Diane Czarnecki  
Industrial Hygienist  
Facilities Management Division  
GSA Public Buildings Service – Heartland Region  
2300 Main Street  
Kansas City, MO 64108

Re: Goodfellow Federal Center  
Metals in Settled Dust Sampling – Building 107  
Project No. 121244

Dear Ms. Czarnecki:

Thank you for the opportunity to assist the General Services Administration (GSA) with the metals in settled dust sampling investigation of Building 107 located at the Goodfellow Federal Center (GFC) in St. Louis, Missouri. Burns & McDonnell understands that the purpose of the investigation was to provide additional sampling data of existing environmental conditions that are present at GFC that could adversely impact the health and safety of building occupants as well as workers at the facility. The following report summarizes the sample collection activities and the laboratory analytical results of samples submitted.

## **INTRODUCTION**

Per historical use and previous characterization, Burns & McDonnell was contracted to perform settled dust sampling for the analysis of seven (7) of the Resource Conservation and Recovery Act (RCRA) target metals (arsenic, barium, cadmium, chromium, lead, selenium, and silver) from various surfaces within buildings. The purpose of this testing was to further characterize the presence and concentration of target metals in common tenant-occupied areas of the building.

The proposed sampling scheme, the number of samples, the sample distribution and general methodology was developed by GSA and Burns & McDonnell. Specific sample locations were determined by sampling personnel while on-site.

Settled dust wipe sampling at Bldg. 107 was conducted on June 10, 2020 by Emily Ahlemeyer of Burns & McDonnell and Jeff Smith of OCCU-TEC.

## **METALS IN SETTLED DUST SAMPLING**

Metals in settled dust sampling was conducted primarily within tenant-occupied areas. Dust wipe sampling was conducted in accordance with ASTM Standard E1728: *Standard Practice for Collection of Settled Dust Samples Using Wipe Sampling Methods for Subsequent Lead Determination*. ASTM Standard E1728 is consistent with the methodology described in the Housing and Urban Development Guidelines and 40 CFR 745.63. The Brookhaven National Laboratory's Surface Wipe Sampling Procedure (IH75190) was also used as a guideline.



Diane Czarnecki  
Facilities Management Division  
July 23, 2020  
Page 2

Dust wipe sampling for the target metals was conducted on a variety of representative surfaces that have the potential of being disturbed by building occupants. A representative surface area of approximately one square foot (1 SF) was measured and delineated with plastic templates. The dust wipe samples were collected using dedicated dust wipe cloths meeting ASTM E1792 Standard. Each dust wipe cloth was pre-moistened and individually wrapped. Each sample was collected by wiping in a back and forth “S” pattern over a measured sampling area using a clean, disposable glove. Then, the wipe was folded over itself and the area was wiped again in a direction perpendicular to the first wipe orientation. Then, the wipe folded over itself again and the area was wiped around the perimeter. The wipe sample was then placed into a labeled, clean container. Dust wipe samples were submitted to Environmental Hazards Services, LLC (EHS) in Richmond, Virginia for Inductively Coupled Plasma (ICP) analysis of metals analysis using Environmental Protection Agency (EPA) method SW846 3050B/6010D. EHS is accredited under the American Industrial Hygiene Association (AIHA) Laboratory Accreditation Program (LAP) identification number LAP-100420.

Whereas the Occupational Safety and Health Administration (OSHA) has not established regulatory limits for surface concentrations of metals, the OSHA Technical Manual Section II: Chapter 2 (III.A) describes a method for calculating “housekeeping” standards, as recommended acceptable surface limits. Brookhaven’s IH75190 procedure uses the housekeeping standards to derive a lower, “clean area limit” for non-operational areas that can be accessed or contacted without special training or precautions. Burns & McDonnell calculated clean area limits for metals not included in the Brookhaven procedure, specifically barium, chromium (total), selenium and silver. Wipe results were compared to the Brookhaven procedure’s clean area limits for each metal.

Results of the dust wipe samples collected from the building indicate that three (3) of the nine (9) samples contained concentrations of target metals above laboratory reporting limits. The following table identifies the range of results for each of the seven metals that were analyzed. Samples with a “<” sign indicate that the results were below the lab’s reportable limit.

Diane Czarnecki  
 Facilities Management Division  
 July 23, 2020  
 Page 3

**Table 1. Summary of Dust Wipe Results**

Analyte	Lowest Concentration <sup>(a)</sup> (µg/sq. ft) <sup>(b)</sup>	Highest Concentration <sup>(a)</sup> (µg/sq. ft) <sup>(b)</sup>	Clean Area Limit <sup>(c)</sup> µg/sq. ft <sup>(b)</sup>
Silver	<2.0	<2.0	62
Arsenic	<2.0	<2.0	62
Barium	<2.0	22	3,094
Cadmium	<2.0	<2.0	31
Chromium (Total)	<2.0	4.2	3,094
Lead	<2.0	27	10 <sup>(d)</sup>
Selenium	<5.0	<5.0	1,236

- (a) Samples with a “<” sign indicate that the results were below the reportable limit.
- (b) µg/sq. ft = micrograms per square foot of surface area.
- (c) Clean Area Limit per Brookhaven IH75190=OSHA Housekeeping Limit [PEL (µg/m<sup>3</sup>) x 10 m<sup>3</sup>/100cm<sup>2</sup>] / 15.
- (d) Lead clean area limit: Brookhaven references EPA/HUD limit for floors, set at 10 µg/sq. ft. as of January 2020.

Two (2) samples exceeded the lead clean area limit. Samples 107-W-06 and 107-W-08 resulted in lead concentrations of 27 and 15 µg/sq. ft, respectively. The remaining target metal sample results were below housekeeping and clean area limits, as recommended and described by OSHA and the Brookhaven Procedure.

Burns & McDonnell appreciates the opportunity to work with the GSA on this project. Please contact us if you have any questions regarding this report or if we may be of any additional service.

Sincerely,

(b) (6)

Matt Shanahan, CHMM  
 Project Manager

- Attachments:
- Appendix A – Sample Summary Table
  - Appendix B – Laboratory Analysis Report
  - Appendix C – Licenses

**APPENDIX A – SAMPLE SUMMARY TABLE**

**Appendix A**  
**Sample Summary Table**

**Goodfellow Federal Center - Building # 107 - Wipe Sample Data**

Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
107-W-01	1st Floor South Lobby	Floor along north wall	Silver	< 2.0	µg/ft <sup>2</sup>	62
			Arsenic	< 2.0	µg/ft <sup>2</sup>	62
			Barium	< 2.0	µg/ft <sup>2</sup>	3,094
			Cadmium	< 2.0	µg/ft <sup>2</sup>	31
			Chromium	< 2.0	µg/ft <sup>2</sup>	3,094
			Lead	< 2.0	µg/ft <sup>2</sup>	10
			Selenium	< 5.0	µg/ft <sup>2</sup>	1,236
107-W-02	1st Floor GSA Office	Floor under sink in break room	Silver	< 2.0	µg/ft <sup>2</sup>	62
			Arsenic	< 2.0	µg/ft <sup>2</sup>	62
			Barium	< 2.0	µg/ft <sup>2</sup>	3,094
			Cadmium	< 2.0	µg/ft <sup>2</sup>	31
			Chromium	< 2.0	µg/ft <sup>2</sup>	3,094
			Lead	< 2.0	µg/ft <sup>2</sup>	10
			Selenium	< 5.0	µg/ft <sup>2</sup>	1,236
107-W-03	1st Floor GSA Office	Top of upper cabinet in break room	Silver	< 2.0	µg/ft <sup>2</sup>	62
			Arsenic	< 2.0	µg/ft <sup>2</sup>	62
			Barium	10	µg/ft <sup>2</sup>	3,094
			Cadmium	< 2.0	µg/ft <sup>2</sup>	31
			Chromium	4.2	µg/ft <sup>2</sup>	3,094
			Lead	3.7	µg/ft <sup>2</sup>	10
			Selenium	< 5.0	µg/ft <sup>2</sup>	1,236

**Appendix A**  
**Sample Summary Table**

Goodfellow Federal Center - Building # 107 - Wipe Sample Data						
Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
107-W-04	1st Floor GSA Office	Top of cabinet in key room	Silver	< 2.0	µg/ft <sup>2</sup>	62
			Arsenic	< 2.0	µg/ft <sup>2</sup>	62
			Barium	< 2.0	µg/ft <sup>2</sup>	3,094
			Cadmium	< 2.0	µg/ft <sup>2</sup>	31
			Chromium	< 2.0	µg/ft <sup>2</sup>	3,094
			Lead	< 2.0	µg/ft <sup>2</sup>	10
			Selenium	< 5.0	µg/ft <sup>2</sup>	1,236
107-W-05	1st Floor NW Vestibule	Tile floor	Silver	< 2.0	µg/ft <sup>2</sup>	62
			Arsenic	< 2.0	µg/ft <sup>2</sup>	62
			Barium	< 2.0	µg/ft <sup>2</sup>	3,094
			Cadmium	< 2.0	µg/ft <sup>2</sup>	31
			Chromium	< 2.0	µg/ft <sup>2</sup>	3,094
			Lead	< 2.0	µg/ft <sup>2</sup>	10
			Selenium	< 5.0	µg/ft <sup>2</sup>	1,236
107-W-06	1st Floor Stairwell to Basement	Floor in decon area	Silver	< 2.0	µg/ft <sup>2</sup>	62
			Arsenic	< 2.0	µg/ft <sup>2</sup>	62
			Barium	22	µg/ft <sup>2</sup>	3,094
			Cadmium	< 2.0	µg/ft <sup>2</sup>	31
			Chromium	3.5	µg/ft <sup>2</sup>	3,094
			Lead	27	µg/ft <sup>2</sup>	10
			Selenium	< 5.0	µg/ft <sup>2</sup>	1,236

**Appendix A**  
**Sample Summary Table**

Goodfellow Federal Center - Building # 107 - Wipe Sample Data						
Sample Number	Location	Area Description	Analyte	Result	Units	Clean Area Limit*
107-W-07	1st Floor Badging Office	West window sill	Silver	< 2.0	µg/ft <sup>2</sup>	62
			Arsenic	< 2.0	µg/ft <sup>2</sup>	62
			Barium	< 2.0	µg/ft <sup>2</sup>	3,094
			Cadmium	< 2.0	µg/ft <sup>2</sup>	31
			Chromium	< 2.0	µg/ft <sup>2</sup>	3,094
			Lead	< 2.0	µg/ft <sup>2</sup>	10
			Selenium	< 5.0	µg/ft <sup>2</sup>	1,236
107-W-08	1st Floor Hallway	Floor outside of room 134	Silver	< 2.0	µg/ft <sup>2</sup>	62
			Arsenic	< 2.0	µg/ft <sup>2</sup>	62
			Barium	19	µg/ft <sup>2</sup>	3,094
			Cadmium	< 2.0	µg/ft <sup>2</sup>	31
			Chromium	3.9	µg/ft <sup>2</sup>	3,094
			Lead	15	µg/ft <sup>2</sup>	10
			Selenium	< 5.0	µg/ft <sup>2</sup>	1,236
107-W-09	Field Blank	--	Silver	< 2.0	µg	--
			Arsenic	< 2.0	µg	--
			Barium	< 2.0	µg	--
			Cadmium	< 2.0	µg	--
			Chromium	< 2.0	µg	--
			Lead	< 2.0	µg	--
			Selenium	< 5.0	µg	--

\* Clean Area Limit per Brookhaven IH75190=OSHA Housekeeping Limit [PEL (µg/m<sup>3</sup>) x 10 m<sup>3</sup>/100cm<sup>2</sup>] / 15. Lead clean area limit: Brookhaven references EPA/HUD limit for floors, set at 10 µg/sq. ft. as of January 2020.

Indicates results at or above the Clean Area Limit

**APPENDIX B – LABORATORY ANALYSIS REPORT**





Environmental Hazards Services, L.L.C.  
 7469 Whitepine Rd  
 Richmond, VA 23237  
 Telephone: 800.347.4010

## Wipe Metals Analysis Report

**Client:** Burns & McDonnell Engineering  
 9400 Ward Pkwy.  
 Kansas City, MO 64114

**Report Number:** 20-06-01780  
**Received Date:** 06/15/2020  
**Analyzed Date:** 06/17/2020  
**Reported Date:** 06/18/2020

**Project/Test Address:** 168765; Goodfellow IH Services; 4300 Goodfellow Blvd.

**Client Number:**  
 26-3514

# Laboratory Results

**Fax Number:**  
 816-822-3494

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
20-06-01780-001	107-W-01	Arsenic (As)	1.00	<2.00	<2.0	
		Barium (Ba)	1.00	<2.00	<2.0	
		Cadmium (Cd)	1.00	<2.00	<2.0	
		Chromium (Cr)	1.00	<2.00	<2.0	
		Lead (Pb)	1.00	<2.00	<2.0	
		Selenium (Se)	1.00	<5.00	<5.0	
		Silver (Ag)	1.00	<2.00	<2.0	
20-06-01780-002	107-W-02	Arsenic (As)	1.00	<2.00	<2.0	
		Barium (Ba)	1.00	<2.00	<2.0	
		Cadmium (Cd)	1.00	<2.00	<2.0	
		Chromium (Cr)	1.00	<2.00	<2.0	

# Environmental Hazards Services, L.L.C

**Client Number:** 26-3514

**Report Number:** 20-06-01780

**Project/Test Address:** 168765; Goodfellow IH Services; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
		Lead (Pb)	1.00	<2.00	<2.0	
		Selenium (Se)	1.00	<5.00	<5.0	
		Silver (Ag)	1.00	<2.00	<2.0	
20-06-01780-003	107-W-03	Arsenic (As)	1.00	<2.00	<2.0	
		Barium (Ba)	1.00	10.5	10	
		Cadmium (Cd)	1.00	<2.00	<2.0	
		Chromium (Cr)	1.00	4.20	4.2	
		Lead (Pb)	1.00	3.72	3.7	
		Selenium (Se)	1.00	<5.00	<5.0	
		Silver (Ag)	1.00	<2.00	<2.0	
20-06-01780-004	107-W-04	Arsenic (As)	1.00	<2.00	<2.0	
		Barium (Ba)	1.00	<2.00	<2.0	
		Cadmium (Cd)	1.00	<2.00	<2.0	
		Chromium (Cr)	1.00	<2.00	<2.0	
		Lead (Pb)	1.00	<2.00	<2.0	
		Selenium (Se)	1.00	<5.00	<5.0	
		Silver (Ag)	1.00	<2.00	<2.0	
20-06-01780-005	107-W-05	Arsenic (As)	1.00	<2.00	<2.0	

# Environmental Hazards Services, L.L.C

**Client Number:** 26-3514

**Report Number:** 20-06-01780

**Project/Test Address:** 168765; Goodfellow IH Services; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
		Barium (Ba)	1.00	<2.00	<2.0	
		Cadmium (Cd)	1.00	<2.00	<2.0	
		Chromium (Cr)	1.00	<2.00	<2.0	
		Lead (Pb)	1.00	<2.00	<2.0	
		Selenium (Se)	1.00	<5.00	<5.0	
		Silver (Ag)	1.00	<2.00	<2.0	
20-06-01780-006	107-W-06	Arsenic (As)	1.00	<2.00	<2.0	
		Barium (Ba)	1.00	22.2	22	
		Cadmium (Cd)	1.00	<2.00	<2.0	
		Chromium (Cr)	1.00	3.54	3.5	
		Lead (Pb)	1.00	27.2	27	
		Selenium (Se)	1.00	<5.00	<5.0	
		Silver (Ag)	1.00	<2.00	<2.0	
20-06-01780-007	107-W-07	Arsenic (As)	1.00	<2.00	<2.0	
		Barium (Ba)	1.00	<2.00	<2.0	
		Cadmium (Cd)	1.00	<2.00	<2.0	
		Chromium (Cr)	1.00	<2.00	<2.0	
		Lead (Pb)	1.00	<2.00	<2.0	

# Environmental Hazards Services, L.L.C

**Client Number:** 26-3514

**Report Number:** 20-06-01780

**Project/Test Address:** 168765; Goodfellow IH Services; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
		Selenium (Se)	1.00	<5.00	<5.0	
		Silver (Ag)	1.00	<2.00	<2.0	
20-06-01780-008	107-W-08	Arsenic (As)	1.00	<2.00	<2.0	
		Barium (Ba)	1.00	18.8	19	
		Cadmium (Cd)	1.00	<2.00	<2.0	
		Chromium (Cr)	1.00	3.90	3.9	
		Lead (Pb)	1.00	15.4	15	
		Selenium (Se)	1.00	<5.00	<5.0	
		Silver (Ag)	1.00	<2.00	<2.0	
20-06-01780-009	107-W-09	Arsenic (As)		<2.00	---	
		Barium (Ba)		<2.00	---	
		Cadmium (Cd)		<2.00	---	
		Chromium (Cr)		<2.00	---	
		Lead (Pb)		<2.00	---	
		Selenium (Se)		<5.00	---	
		Silver (Ag)		<2.00	---	

# Environmental Hazards Services, L.L.C

**Client Number:** 26-3514

**Report Number:** 20-06-01780

**Project/Test Address:** 168765; Goodfellow IH Services; 4300 Goodfellow Blvd.

---

Lab Sample Number	Client Sample Number	Analyte:	Wipe Area (ft <sup>2</sup> )	Total Metal (ug)	Concentration (ug/ft <sup>2</sup> )	Narrative ID
-------------------	----------------------	----------	------------------------------	------------------	-------------------------------------	--------------

---

Sample Narratives:

---

**Analyst:** Anthony Dee

**Method:** Mercury (Hg): EPA SW846 7471B

All other metals: EPA SW846 3050B/6010D

(b) (6)

Reviewed By Authorized Signatory:

*Tasha Eaddy*

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit for each particular metal, based on a 100mL volume. The reporting limit for Mercury is 0.10ug, Aluminum, Iron and Zinc are 50ug, Antimony and Selenium are 5.0ug and 2.0ug for all other metals.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. EHS sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of the Environmental Hazards Service, L.L.C. California Certification #2319 NY ELAP #11714.

---

Legend	ug = microgram	ug/ft <sup>2</sup> = micrograms per square foot
	mL = milliliter	ft <sup>2</sup> = square foot

---

# ENVIRONMENTAL HAZARDS SERVICES, LLC

## Metals Chain of Custody Form

Company Name		Burns & McDonnell			Account #		26-3514		
Company Address		9400 Ward Parkway			City/State/Zip		Kansas City, MO 64114		
Phone		816-349-6646			Email		msharahan@burnsmcd.com		
Project Name / Testing Address		Goodfellow IH Services / 4300 Goodfellow Blvd.							
PO Number		168765			Collected By		Emily Ahlemeyer & Jeff Smith		
Turn-Around Time		<input checked="" type="radio"/> 3 DAY <input type="radio"/> 2 DAY <input type="radio"/> 1 DAY <input type="radio"/> SAME DAY OR WEEKEND - Must Call Ahead							

  

LAB NUMBER	Client Sample ID	Collection Date & Time	METALS							Other Metals	PARTICULATES					AIR			WIPES
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP	CA 17 Total		Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM-10	Total Time	Flow Rate	Vol.	
																Mins.	L/min.	Total Liters	
1	107-W-01	6/10/2020							As, Pb, Cd, Se, Cr, Ag, Ba										12 x 12
2	107-W-02																	12 x 12	
3	107-W-03																	12 x 12	
4	107-W-04																	12 x 12	
5	107-W-05																	12 x 12	
6	107-W-06																	12 x 12	
7	107-W-07																	12 x 12	
8	107-W-08																	12 x 12	
9	107-W-09																	NA x NA	
10																		x	
11																	x		
12																	x		
13																	x		
14																	x		
15																	x		

Wipe area per Emily 6/15/20

Released By:	Emily Ahlemeyer	Date:	6/12/2020	Time:	4:00 PM
Signature:	(b) (6)				

LAB USE ONLY – BELOW THIS LINE

Received By: TStone

Signature: (b) (6)

Date: 6/15/20 Time: 1:04  AM  PM

Portal Contact Added

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010

RESULTS VIA CLIENT PORTAL AVAILABLE @ [www.leadlab.com](http://www.leadlab.com)

20-06-01780

Due Date:  
06/18/2020  
(Thursday)  
EL

## **APPENDIX C – LICENSES**

**STATE OF MISSOURI  
DEPARTMENT OF HEALTH AND SENIOR SERVICES**

**LEAD OCCUPATION LICENSE REGISTRATION**

Issued to:

**Jeffrey T. Smith**

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

**Lead Risk Assessor**  
Category of License

Issuance Date: **3/16/2019**  
Expiration Date: **3/16/2021**  
License Number: **010316-200089640**



(b) (6)

Randall W. Williams, MD, FACOG  
Director  
Department of Health and Senior Services

Lead Licensing Program, PO Box 570, Jefferson City, MO 65102