
January 28, 2025

Ms. Diane Czarnecki
Industrial Hygienist
Facilities Management Division
GSA Public Buildings Service – Heartland Region
2300 Main Street
Kansas City, Missouri 64108

**RE: Goodfellow Federal Center - Metals in Air Investigation
Buildings – 105
4300 Goodfellow Boulevard
St. Louis, Missouri 63120
OCCU-TEC Project No. 925001**

Dear Ms. Czarnecki:

Thank you for the opportunity to assist the General Services Administration (GSA) with the Resource Conservation and Recovery Act (RCRA) metals in air sampling investigation of the above referenced buildings located at the Goodfellow Federal Complex, in St. Louis, Missouri. OCCU-TEC understands that the purpose of the investigation was to provide sampling data regarding existing conditions to supplement previous investigation reports prepared for the facility. The following report summarizes the sample collection activities, and the laboratory analytical results for the samples submitted.

On January 8, 2025, a Missouri licensed air sampling professional from OCCU-TEC conducted air sampling for the presence of seven of the RCRA metals including Silver, Arsenic, Barium, Cadmium, Chromium, Lead, and Selenium. Sampling was conducted within the occupied areas of Building 105.

The proposed sampling scheme, the numbers of samples, sample distribution and general methodology was developed based on previous investigation methodology and coordination with the GSA. Sample locations and samples collected from discretionary locations were determined by OCCU-TEC field personnel while on-site.

Resource Conservation and Recovery Act Metals Air Sampling

Air sampling for RCRA metals was collected on 37-millimeter (mm) cassettes with 0.8 micrometer (μm) mixed cellulose ester (MCE) filters using powered air sampling pumps in accordance with National Institute for Occupational Safety and Health (NIOSH) sampling methods. Samples were collected in a method sufficient to collect a minimum sample volume of 500 liters. Air samples were submitted under chain-of-custody to Environmental Hazards Services, LLC (EHS) in Richmond, Virginia for independent analysis of RCRA metals according to NIOSH Method 7300. EHS is accredited by the American Industrial Hygiene Association (AIHA) utilizing the Industrial Hygiene Proficiency Analytical Testing (IHPAT) program. EHS's IHPAT Laboratory ID is LAP-100420.

Results of the air sampling are summarized in the table below by identifying the range of results for building 105 for each of the seven metals that were sampled. **Samples with a "<" sign indicate that the results were below the laboratory's method reporting limit.**

Analysis	Lowest Concentration ($\mu\text{g}/\text{m}^3$)	Highest Concentration ($\mu\text{g}/\text{m}^3$)
Arsenic	<0.15	<0.30
Barium	<0.15	<0.30
Cadmium	<0.057	<0.060
Chromium	<0.75	<1.5
Lead	<0.15	<0.30
Selenium	<0.75	<1.5
Silver	<0.15	<0.30

Results of the air samples collected indicate that all of the air samples collected from Building 105 contained concentrations of RCRA metals below the laboratory's method reporting limit or the OSHA Permissible Exposure Limit (PEL). Sample locations and the corresponding result are summarized in the enclosed in

the laboratory analytical results are included in the attached tables. The air sampling professional's Missouri Lead license is included in Appendix A.

It should be noted that this air sampling investigation was only a screening of airborne RCRA metals and should not be interpreted or used to determine compliance or non-compliance with OSHA personnel monitoring regulations. GSA may choose to compare results with guidance limits from additional organizations for risk evaluation, including but not limited to the American Conference of Governmental Industrial Hygienists (ACGIH) and/or the World Health Organization (WHO).

OCCU-TEC appreciates the opportunity to work with GSA on this project. If you have any questions concerning this report, or if we may be of any additional service, please feel free to contact us.

Sincerely,

(b) (6)

Jeff T. Smith
Senior Project Manager

(b) (6)

Kevin Heriford
Director of EH&S Depts. (QA/QC)

Appendices:

- A: Air Sample Results Summary Table
- B: Laboratory Analytical Results and Chain of Custody Documentation
- C: Qualifications and Licenses

APPENDIX A

AIR SAMPLE RESULTS SUMMARY TABLE

Appendix A
Sample Summary Table

Building 105 Air Sample Results Summary Table				
Sample ID	Location	Analyte	Concentration (ug/m ³)	Recommended Limits ¹ (ug/m ³)
105-A-01	1st Floor Storage @ Column E-51	Arsenic	<0.30	10
		Barium	<0.30	500
		Cadmium	<0.060	5
		Chromium	<1.5	500
		Lead ²	<0.30	1
		Selenium	<1.5	200
		Silver	<0.30	10
105-A-02	1st Floor - Loading Dock @ Column C-52	Arsenic	<0.30	10
		Barium	<0.30	500
		Cadmium	<0.060	5
		Chromium	<1.5	500
		Lead ²	<0.30	1
		Selenium	<1.5	200
		Silver	<0.30	10
105-A-03	1st Floor - Office by Column B-51	Arsenic	<0.30	10
		Barium	<0.30	500
		Cadmium	<0.060	5
		Chromium	<1.5	500
		Lead ²	<0.30	1
		Selenium	<1.5	200
		Silver	<0.30	10
105-A-04	1st Floor - Receiving at Column B-46	Arsenic	<0.30	10
		Barium	<0.30	500
		Cadmium	<0.059	5
		Chromium	<1.5	500
		Lead ²	<0.30	1
		Selenium	<1.5	200
		Silver	<0.30	10
105-A-05	1st Floor - near walk-in coolers at Column D-43	Arsenic	<0.30	10
		Barium	<0.30	500
		Cadmium	<0.060	5
		Chromium	<1.5	500
		Lead ²	<0.30	1
		Selenium	<1.5	200
		Silver	<0.30	10
105-A-06	1st Floor - Warehouse at Column G-45	Arsenic	<0.30	10
		Barium	<0.30	500
		Cadmium	<0.059	5
		Chromium	<1.5	500
		Lead ²	<0.30	1
		Selenium	<1.5	200
		Silver	<0.30	10

Appendix A
Sample Summary Table

Building 105 Air Sample Results Summary Table				
Sample ID	Location	Analyte	Concentration (ug/m ³)	Recommended Limits ¹ (ug/m ³)
105-A-07	1st Floor - Hallway next to elevator at Column C-49.	Arsenic	<0.30	10
		Barium	<0.30	500
		Cadmium	<0.060	5
		Chromium	<1.5	500
		Lead ²	<0.30	1
		Selenium	<1.5	200
		Silver	<0.30	10
105-A-08	1st Floor - Storage at Column H-49.	Arsenic	<0.30	10
		Barium	<0.30	500
		Cadmium	<0.060	5
		Chromium	<1.5	500
		Lead ²	<0.30	1
		Selenium	<1.5	200
		Silver	<0.30	10
105-A-09	Field Blank	Arsenic	<0.15 ug	10
		Barium	<0.15 ug	500
		Cadmium	<0.030 ug	5
		Chromium	<0.75 ug	500
		Lead ²	<0.15 ug	1
		Selenium	<0.75 ug	200
		Silver	<0.15 ug	10
105-A-10	2nd Floor - Badging Office	Arsenic	<0.29	10
		Barium	<0.29	500
		Cadmium	<0.058	5
		Chromium	<1.5	500
		Lead ²	<0.29	1
		Selenium	<1.5	200
		Silver	<0.30	10
105-A-11	2nd Floor - Small Conference Room - Room #331	Arsenic	<0.30	10
		Barium	<0.30	500
		Cadmium	<0.059	5
		Chromium	<1.5	500
		Lead ²	<0.30	1
		Selenium	<1.5	200
		Silver	<0.30	10
105-A-12	2nd Floor Lab #324 - East	Arsenic	<0.30	10
		Barium	<0.30	500
		Cadmium	<0.059	5
		Chromium	<1.5	500
		Lead ²	<0.30	1
		Selenium	<1.5	200
		Silver	<0.30	10

Appendix A
Sample Summary Table

Building 105 Air Sample Results Summary Table				
Sample ID	Location	Analyte	Concentration (ug/m ³)	Recommended Limits ¹ (ug/m ³)
105-A-13	2nd Floor - Break Room	Arsenic	<0.30	10
		Barium	<0.30	500
		Cadmium	<0.059	5
		Chromium	<1.5	500
		Lead ²	<0.30	1
		Selenium	<1.5	200
		Silver	<0.30	10
105-A-14	2nd Floor - Gas Storage Room #320	Arsenic	<0.30	10
		Barium	<0.30	500
		Cadmium	<0.059	5
		Chromium	<1.5	500
		Lead ²	<0.30	1
		Selenium	<1.5	200
		Silver	<0.30	10
105-A-15	2nd Floor - Lab #318 near eye wash	Arsenic	<0.30	10
		Barium	<0.30	500
		Cadmium	<0.059	5
		Chromium	<1.5	500
		Lead ²	<0.30	1
		Selenium	<1.5	200
		Silver	<0.30	10
105-A-16	2nd Floor - Lab #314 - North Shelf	Arsenic	<0.30	10
		Barium	<0.30	500
		Cadmium	<0.060	5
		Chromium	<1.5	500
		Lead ²	<0.30	1
		Selenium	<1.5	200
		Silver	<0.30	10
105-A-17	2nd Floor - Lab #349 - Northwest	Arsenic	<0.30	10
		Barium	<0.30	500
		Cadmium	<0.060	5
		Chromium	<1.5	500
		Lead ²	<0.30	1
		Selenium	<1.5	200
		Silver	<0.30	10
105-A-18	Field Blank	Arsenic	<0.15 ug	10
		Barium	<0.15 ug	500
		Cadmium	<0.030 ug	5
		Chromium	<0.75 ug	500
		Lead ²	<0.15 ug	1
		Selenium	<0.75 ug	200
		Silver	<0.15 ug	10

Appendix A
Sample Summary Table

Building 105 Air Sample Results Summary Table				
Sample ID	Location	Analyte	Concentration (ug/m ³)	Recommended Limits ¹ (ug/m ³)
105-A-19	1st Floor - West Hallway - Southwest Entrance	Arsenic	<0.29	10
		Barium	<0.29	500
		Cadmium	<0.057	5
		Chromium	<1.5	500
		Lead ²	<0.29	1
		Selenium	<1.5	200
		Silver	<0.29	10
105-A-20	1st Floor - Hallway by West Elevator	Arsenic	<0.29	10
		Barium	<0.29	500
		Cadmium	<0.057	5
		Chromium	<1.5	500
		Lead ²	<0.29	1
		Selenium	<1.5	200
		Silver	<0.29	10
105-A-21	2nd Floor - Hallway at Southwest Entrance	Arsenic	<0.30	10
		Barium	<0.30	500
		Cadmium	<0.059	5
		Chromium	<1.5	500
		Lead ²	<0.30	1
		Selenium	<1.5	200
		Silver	<0.30	10
105-A-22	2nd Floor - Hallway at West Entrance by Room #305	Arsenic	<0.29	10
		Barium	<0.29	500
		Cadmium	<0.058	5
		Chromium	<1.5	500
		Lead ²	<0.29	1
		Selenium	<1.5	200
		Silver	<0.29	10
105-A-23	2nd Floor - Hallway by Column B-38	Arsenic	<0.30	10
		Barium	<0.30	500
		Cadmium	<0.059	5
		Chromium	<1.5	500
		Lead ²	<0.30	1
		Selenium	<1.5	200
		Silver	<0.30	10
105-A-24	2nd Floor - East Hallway by freight elevator	Arsenic	<0.30	10
		Barium	<0.30	500
		Cadmium	<0.059	5
		Chromium	<1.5	500
		Lead ²	<0.30	1
		Selenium	<1.5	200
		Silver	<0.30	10

Appendix A
Sample Summary Table

Building 105 Air Sample Results Summary Table				
Sample ID	Location	Analyte	Concentration (ug/m ³)	Recommended Limits ¹ (ug/m ³)
105-A-25	1st Floor - East Hallway by freight elevator	Arsenic	<0.30	10
		Barium	<0.30	500
		Cadmium	<0.059	5
		Chromium	<1.5	500
		Lead ²	<0.30	1
		Selenium	<1.5	200
		Silver	<0.30	10
105-A-26	East Stairwell Landing by freight elevator	Arsenic	<0.30	10
		Barium	<0.30	500
		Cadmium	<0.059	5
		Chromium	<1.5	500
		Lead ²	<0.30	1
		Selenium	<1.5	200
		Silver	<0.30	10
105-A-27	Field Blank	Arsenic	<0.15 ug	10
		Barium	<0.15 ug	500
		Cadmium	<0.030 ug	5
		Chromium	<0.75 ug	500
		Lead ²	<0.15 ug	1
		Selenium	<0.75 ug	200
		Silver	<0.15 ug	10

Notes:

¹Limits equal to the OSHA Permissible Exposure Limits (PELs)

² Limits equal to the World Health Organization (WHO) Ambient Air Limit

APPENDIX B

LABORATORY ANALYTICAL RESULTS AND CHAIN OF CUSTODY
DOCUMENTATION



7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Air Metals Analysis Report

Client: OCCU-Tec Inc
2604 NE Industrial Drive
Suite 230
North Kansas City, MO 64117

Report Number: 25-01-01637

Received Date: 01/13/2025

Reported Date: 01/21/2025

Project/Test Address: Goodfellow; Bldg. 105

Client Number:
202507

Fax Number:

Laboratory Results

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
25-01-01637-001	105-A-01	01/16/2025	Arsenic (As)	508	<0.15	<0.30	
			Barium (Ba)		<0.15	<0.30	
			Cadmium (Cd)		<0.030	<0.060	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.30	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.30	
25-01-01637-002	105-A-02	01/16/2025	Arsenic (As)	508	<0.15	<0.30	
			Barium (Ba)		<0.15	<0.30	
			Cadmium (Cd)		<0.030	<0.060	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.30	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.30	
25-01-01637-003	105-A-03	01/16/2025	Arsenic (As)	502	<0.15	<0.30	
			Barium (Ba)		<0.15	<0.30	
			Cadmium (Cd)		<0.030	<0.060	

Environmental Hazards Services, L.L.C

Client Number: 202507

Report Number: 25-01-01637

Project/Test Address: Goodfellow; Bldg. 105

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
25-01-01637-004	105-A-04	01/16/2025	Chromium (Cr)	513	<0.75	<1.5	
			Lead (Pb)		<0.15	<0.30	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.30	
			Arsenic (As)		<0.15	<0.30	
			Barium (Ba)		<0.15	<0.30	
			Cadmium (Cd)		<0.030	<0.059	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.30	
			Selenium (Se)		<0.75	<1.5	
25-01-01637-005	105-A-05	01/16/2025	Silver (Ag)	506	<0.15	<0.30	
			Arsenic (As)		<0.15	<0.30	
			Barium (Ba)		<0.15	<0.30	
			Cadmium (Cd)		<0.030	<0.060	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.30	
			Selenium (Se)		<0.75	<1.5	
25-01-01637-006	105-A-06	01/16/2025	Silver (Ag)	510	<0.15	<0.30	
			Arsenic (As)		<0.15	<0.30	
			Barium (Ba)		<0.15	<0.30	
			Cadmium (Cd)		<0.030	<0.059	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.30	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.30	

Environmental Hazards Services, L.L.C

Client Number: 202507

Report Number: 25-01-01637

Project/Test Address: Goodfellow; Bldg. 105

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
25-01-01637-007	105-A-07	01/16/2025	Arsenic (As)	501	<0.15	<0.30	
			Barium (Ba)		<0.15	<0.30	
			Cadmium (Cd)		<0.030	<0.060	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.30	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.30	
25-01-01637-008	105-A-08	01/16/2025	Arsenic (As)	501	<0.15	<0.30	
			Barium (Ba)		<0.15	<0.30	
			Cadmium (Cd)		<0.030	<0.060	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.30	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.30	
25-01-01637-009	105-A-09	01/16/2025	Arsenic (As)	--	<0.15	---	
			Barium (Ba)		<0.15	---	
			Cadmium (Cd)		<0.030	---	
			Chromium (Cr)		<0.75	---	
			Lead (Pb)		<0.15	---	
			Selenium (Se)		<0.75	---	
			Silver (Ag)		<0.15	---	
25-01-01637-010	105-A-10	01/16/2025	Arsenic (As)	519	<0.15	<0.29	
			Barium (Ba)		<0.15	<0.29	
			Cadmium (Cd)		<0.030	<0.058	
			Chromium (Cr)		<0.75	<1.5	

Environmental Hazards Services, L.L.C

Client Number: 202507

Report Number: 25-01-01637

Project/Test Address: Goodfellow; Bldg. 105

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
25-01-01637-011	105-A-11	01/16/2025	Lead (Pb)	516	<0.15	<0.29	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.29	
			Arsenic (As)		<0.15	<0.30	
			Barium (Ba)		<0.15	<0.30	
			Cadmium (Cd)		<0.030	<0.059	
			Chromium (Cr)		<0.75	<1.5	
25-01-01637-012	105-A-12	01/16/2025	Lead (Pb)	514	<0.15	<0.30	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.30	
			Arsenic (As)		<0.15	<0.30	
			Barium (Ba)		<0.15	<0.30	
			Cadmium (Cd)		<0.030	<0.059	
			Chromium (Cr)		<0.75	<1.5	
25-01-01637-013	105-A-13	01/16/2025	Lead (Pb)	516	<0.15	<0.30	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.30	
			Arsenic (As)		<0.15	<0.30	
			Barium (Ba)		<0.15	<0.30	
			Cadmium (Cd)		<0.030	<0.059	
			Chromium (Cr)		<0.75	<1.5	
25-01-01637-014	105-A-14	01/16/2025	Lead (Pb)	509	<0.15	<0.30	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.30	
			Arsenic (As)		<0.15	<0.30	
			Barium (Ba)		<0.15	<0.30	
			Cadmium (Cd)		<0.030	<0.059	
			Chromium (Cr)		<0.75	<1.5	

Environmental Hazards Services, L.L.C

Client Number: 202507

Report Number: 25-01-01637

Project/Test Address: Goodfellow; Bldg. 105

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
25-01-01637-015	105-A-15	01/16/2025	Barium (Ba)	515	<0.15	<0.30	
			Cadmium (Cd)		<0.030	<0.059	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.30	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.30	
			Arsenic (As)		<0.15	<0.30	
			Barium (Ba)		<0.15	<0.30	
			Cadmium (Cd)		<0.030	<0.059	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.30	
			Selenium (Se)		<0.75	<1.5	
25-01-01637-016	105-A-16	01/16/2025	Silver (Ag)	506	<0.15	<0.30	
			Arsenic (As)		<0.15	<0.30	
			Barium (Ba)		<0.15	<0.30	
			Cadmium (Cd)		<0.030	<0.060	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.30	
			Selenium (Se)		<0.75	<1.5	
25-01-01637-017	105-A-17	01/16/2025	Silver (Ag)	501	<0.15	<0.30	
			Arsenic (As)		<0.15	<0.30	
			Barium (Ba)		<0.15	<0.30	
			Cadmium (Cd)		<0.030	<0.060	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.30	

Environmental Hazards Services, L.L.C

Client Number: 202507

Report Number: 25-01-01637

Project/Test Address: Goodfellow; Bldg. 105

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
25-01-01637-018	105-A-18	01/16/2025	Selenium (Se)	--	<0.75	<1.5	
			Silver (Ag)		<0.15	<0.30	
			Arsenic (As)		<0.15	---	
			Barium (Ba)		<0.15	---	
			Cadmium (Cd)		<0.030	---	
			Chromium (Cr)		<0.75	---	
			Lead (Pb)		<0.15	---	
			Selenium (Se)		<0.75	---	
			Silver (Ag)		<0.15	---	
25-01-01637-019	105-A-19	01/16/2025	Arsenic (As)	531	<0.15	<0.29	
			Barium (Ba)		<0.15	<0.29	
			Cadmium (Cd)		<0.030	<0.057	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.29	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.29	
25-01-01637-020	105-A-20	01/16/2025	Arsenic (As)	529	<0.15	<0.29	
			Barium (Ba)		<0.15	<0.29	
			Cadmium (Cd)		<0.030	<0.057	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.29	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.29	
25-01-01637-021	105-A-21	01/16/2025	Arsenic (As)	517	<0.15	<0.30	
			Barium (Ba)		<0.15	<0.30	

Environmental Hazards Services, L.L.C

Client Number: 202507

Report Number: 25-01-01637

Project/Test Address: Goodfellow; Bldg. 105

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
25-01-01637-022	105-A-22	01/16/2025	Cadmium (Cd)	518	<0.030	<0.059	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.30	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.30	
			Arsenic (As)		<0.15	<0.29	
			Barium (Ba)		<0.15	<0.29	
			Cadmium (Cd)		<0.030	<0.058	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.29	
25-01-01637-023	105-A-23	01/16/2025	Selenium (Se)	512	<0.75	<1.5	
			Silver (Ag)		<0.15	<0.29	
			Arsenic (As)		<0.15	<0.30	
			Barium (Ba)		<0.15	<0.30	
			Cadmium (Cd)		<0.030	<0.059	
			Chromium (Cr)		<0.75	<1.5	
25-01-01637-024	105-A-24	01/16/2025	Lead (Pb)	515	<0.15	<0.30	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.30	
			Arsenic (As)		<0.15	<0.30	
			Barium (Ba)		<0.15	<0.30	
			Cadmium (Cd)		<0.030	<0.059	

Environmental Hazards Services, L.L.C

Client Number: 202507

Report Number: 25-01-01637

Project/Test Address: Goodfellow; Bldg. 105

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
25-01-01637-025	105-A-25	01/16/2025	Silver (Ag)		<0.15	<0.30	
			Arsenic (As)	509	<0.15	<0.30	
			Barium (Ba)		<0.15	<0.30	
			Cadmium (Cd)		<0.030	<0.059	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.30	
			Selenium (Se)		<0.75	<1.5	
25-01-01637-026	105-A-26	01/16/2025	Silver (Ag)		<0.15	<0.30	
			Arsenic (As)	509	<0.15	<0.30	
			Barium (Ba)		<0.15	<0.30	
			Cadmium (Cd)		<0.030	<0.059	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.30	
			Selenium (Se)		<0.75	<1.5	
25-01-01637-027	105-A-27	01/16/2025	Silver (Ag)		<0.15	<0.30	
			Arsenic (As)	--	<0.15	---	
			Barium (Ba)		<0.15	---	
			Cadmium (Cd)		<0.030	---	
			Chromium (Cr)		<0.75	---	
			Lead (Pb)		<0.15	---	
			Selenium (Se)		<0.75	---	
			Silver (Ag)		<0.15	---	

Environmental Hazards Services, L.L.C

Client Number: 202507

Report Number: 25-01-01637

Project/Test Address: Goodfellow; Bldg. 105

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
-------------------	----------------------	---------------	---------	----------------	------------------	------------------------------------	--------------

Sample Narratives:

Method: NIOSH 7300M
Analyst: Carlos Gonzalez, Max Dichek

(b) (6)

Reviewed By Authorized Signatory:

Tasha Eaddy
QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit for each particular metal, based on a 15mL volume. The reporting limit is 0.03ug for Cadmium, 0.15ug for Arsenic, Barium, Lead and Silver, and 0.75ug for Chromium and Selenium.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. These sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of Environmental Hazards Services, L.L.C.

LEGEND	ug = microgram mL = milliliter	ug/m ³ = micrograms per cubic meter L= Liters
--------	-----------------------------------	---

ENVIRONMENTAL HAZARDS SERVICES, LLC

Metals Chain of Custody Form

Page 1 of 5

Company Name		OCCU-TEC Inc.		Account #		202507	
Company Address		2604 NE Industrial Drive Suite 230		City/State/Zip		North Kansas City, MO 64117	
Phone		816-231-5580		Email		jarnold@occutec.com	
Project Name / Testing Address		Gondfellow-Bldg 105					
PO Number				Collected By		Jeff Smith	
Turn-Around Time		☒ 5 Day ☐ 3 Day ☐ 2 Day ☐ 1 Day ☐ Same Day / Weekend - Must Call Ahead					

LAB NUMBER	Client Sample ID	Collection Date & Time	METALS							Other Metals	PARTICULATES					AIR			WIPES	
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP	CA 17 Total		Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM-10	Total Time	Flow Rate	Vol.	AREA	
																Min.	L/min	Total Liters		Circle Unit of Measurement Used cm or in
1	105-A-01	1-8-25 754							Ag, As, Ba,						201	2.53	508		x	
2	A-02	755							Cd, Pb, Se						201	2.53	508		x	
3	A-03	758													206	2.51	502		x	
4	A-04	759													202	2.54	513		x	
5	A-05	801													201	2.52	506		x	
6	A-06	803													206	2.55	510		x	
7	A-07	805													199	2.52	501		x	
8	A-08	808													199	2.52	501		x	
9	A-09	809													—	—	—		x	
10	A-10	1145													205	2.53	519		x	
11	A-11	1147													204	2.53	516		x	
12	A-12	1148													205	2.51	514		x	
13	A-13	1151													203	2.54	516		x	
14	A-14	1154													202	2.52	509		x	
15	A-15	1156													202	2.55	515		x	

Released By:	Jeff Smith	Date:	1-10-25	Time:	1600
Signature:	(b) (6)				

LAB USE ONLY - BELOW THIS LINE

Received By: TStone
 Signature: (b) (6)
 Date: 1/13/25 Time: 12:37 ☐ AM ☒ PM
☐ Portal Contact Added

25-01-01637



Due Date:
 01/21/2025
 (Tuesday)
 AE

P

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010

RESULTS VIA CLIENT PORTAL AVAILABLE @ www.leadlab.com

ENVIRONMENTAL HAZARDS SERVICES, LLC

Metals Chain of Custody Form

Page 2 of 5

Company Name				OCCU-TEC Inc.				Account #		202507	
Company Address				2604 NE Industrial Drive Suite 230				City/State/Zip		North Kansas City, MO 64117	
Phone				816-231-5580				Email		jarnold@occutech.com	
Project Name / Testing Address				Goodfellow - Bldg 105							
PO Number								Collected By		Jeff Smith	
Turn-Around Time				☒ 5 Day ☐ 3 Day ☐ 2 Day ☐ 1 Day ☐ Same Day / Weekend - Must Call Ahead							

LAB NUMBER	Client Sample ID	Collection Date & Time	METALS							Other Metals	PARTICULATES					AIR			WIPES	
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP	CA 17 Total		Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM-10	Total Time	Flow Rate	Vol.	AREA	
																Min.	L/min	Total Liters		Circle Unit of Measurement Used cm or ☒ in
1	105-A-16	1-8-25 1158							Ag, As, Ba, Cd, Cr, Pb, SE						201	2.52	506		x	
2	A-17	↓ 1201												199	2.52	501		x		
3	A-18	↓ 1202												—	—	—		x		
4	A-19	1-9-25 0730												210	2.53	531		x		
5	A-20	↓ 0732												209	2.53	529		x		
6	A-21	↓ 0737												206	2.51	517		x		
7	A-22	↓ 0740												204	2.54	518		x		
8	A-23	↓ 0743												203	2.52	512		x		
9	A-24	↓ 0745												202	2.55	515		x		
10	A-25	↓ 0747												202	2.52	509		x		
11	A-26	↓ 0748												202	2.52	509		x		
12	A-27	↓ 0750												—	—	—		x		
13	105-W-01	1-9-25 0823																12 x 12		
14	W-02	↓ 0826																12 x 12		
15	W-03	↓ 0833																12 x 12		

Released By:		Jeff Smith		Date:		1-10-25		Time:		1600	
Signature:		(b) (6)									


LAB USE ONLY - BELOW THIS LINE

Received By: T Stone

Signature: (b) (6)

Date: 1, 13, 25 Time: 12:37 ☐ AM ☒ PM

☐ Portal Contact Added



APPENDIX C

QUALIFICATIONS AND LICENSES

STATE OF MISSOURI
DEPARTMENT OF HEALTH AND SENIOR SERVICES

LEAD OCCUPATION LICENSE REGISTRATION

Issued to:

Jeffrey T. Smith

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

Lead Risk Assessor
Category of License

Issuance Date: **2/17/2023**
Expiration Date: **3/16/2025**
License Number: **010316-200089640**

(b) (6)

Paula F. Nickelson
Acting Director
Department of Health and Senior Services

Lead Licensing Program, PO Box 570, Jefferson City, MO 65102