

GSA Great Lakes Region

DATE: November 14, 2023

Mark A. McCready

DocuSigned by:

FROM: Mark A. McCready, Michigan Service Center Director, Northern Service Genter 1445A...

Operations Division

GSA Region 5 Public Buildings Service

TO: Operations and Maintenance Services, K'oyitl'ots'ina, Limited (K Corp)

Custodial Services, Americlean Janitorial Services Corp

General Services Administration (GSA)

Patrick V. McNamara Federal Building Tenant Agencies

CC: Angel Dizon, Regional Commissioner

Rob Green, Deputy Regional Commissioner

Michele Sharples, Director Northern Service Center Operations Division William Renner, Director, Facilities Management Services Programs Division Massiel Lucca Amador, Manager, Energy, Environmental, & Sustainability Branch

Thomas Hawkins, Regional Counsel Robert Foltman, Regional Counsel

SUBJECT: Update on Notification Concerning Cooling Tower Legionella Testing Results

This is an update to our last memo to PVM tenants on November 1, 2023. GSA has just received the Legionella test results from the retesting that occurred on November 1, 2023 at the cooling tower on the 27th level that we previously notified you of Legionella detected.

The latest results from this location were negative for Legionella (No Legionella Isolated). MRL is the Minimum Reporting Limit. Below are the results.

Legionella Summary Sheet

			,		
Client Sample #	Sample Location	Volume (mL)	MRL (CFU/mL)	Results (CFU/mL)	Legionella Isolated
1: 1	Domestic Water Supply	250	0.4	NLI	
2; 2	Main CT	1	10	NLI	
NLI = No Legionella Isolated					

As a reminder, the cooling tower was shut down for the season during the week of October 30 and cleaned. This test result confirms No Legionella Isolated in the samples.

We appreciate your patience while we addressed this issue.

If you have questions, please feel free to contact the building Supervisory Property Manager Brian Green at 313-226-2628.